

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 113年02月06日

報表日期: 113年02月06日

[illegible]

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 113年02月06日

| 項目<br>單位<br>小時\限標 | #2-HCl_C | #2-CO_C  | #2-NOx_C | #2-SO2_C | #2-H2O   | #2-O2_C  | #2-OPAC  | #2-FLOW_C |
|-------------------|----------|----------|----------|----------|----------|----------|----------|-----------|
|                   | ppm      | ppm      | ppm      | ppm      | %        | %        | %        | m3/Hour   |
|                   | 60.00    | 150.00   | 220.00   | 150.00   | 100.00   | 25.00    | 10.00    | 999999.00 |
| 0                 | 9.07     | 7.38     | 41.45    | 2.55     | 13.58    | 11.55    | 0.99     | 78996.26  |
| 1                 | 9.37     | 6.04     | 40.57    | 2.76     | 16.28    | 11.56    | 0.99     | 76569.91  |
| 2                 | 9.77     | 3.99     | 46.13    | 2.64     | 13.24    | 11.79    | 0.98     | 78176.34  |
| 3                 | 9.26     | 3.64     | 46.30    | 2.93     | 12.52    | 11.81    | 0.99     | 78656.27  |
| 4                 | 9.94     | 3.33     | 48.85    | 2.54     | 14.17    | 11.62    | 1.01     | 78912.06  |
| 5                 | 8.22     | 3.16     | 46.04    | 2.57     | 13.23    | 11.73    | 1.02     | 78776.56  |
| 6                 | 14.45    | 4.22     | 50.28    | 3.74     | 13.27    | 11.59    | 1.02     | 79434.01  |
| 7                 | 7.49     | 2.89     | 44.52    | 2.27     | 13.87    | 11.58    | 1.02     | 78928.50  |
| 8                 | 7.91     | 2.95     | 47.07    | 2.61     | 13.22    | 11.85    | 1.03     | 77096.09  |
| 9                 | 7.93     | 3.06     | 46.75    | 2.46     | 13.47    | 11.82    | 1.03     | 77313.30  |
| 10                | 9.57     | 3.22     | 44.45    | 2.55     | 13.61    | 11.58    | 1.04     | 79560.58  |
| 11                | 10.10    | 4.80     | 44.88    | 3.24     | 12.46    | 11.93    | 1.04     | 77404.47  |
| 12                | 11.30    | 5.97     | 45.88    | 3.45     | 11.49    | 12.13    | 1.02     | 76337.15  |
| 13                | 8.52     | 3.93     | 47.77    | 2.86     | 11.92    | 12.18    | 1.00     | 75749.85  |
| 14                | 8.58     | 3.89     | 47.26    | 3.42     | 11.38    | 12.05    | 1.01     | 76799.31  |
| 15                | 9.37     | 4.45     | 46.18    | 3.90     | 11.08    | 12.15    | 1.01     | 75331.72  |
| 16                | 8.89     | 4.96     | 49.16    | 4.02     | 11.04    | 12.32    | 0.99     | 75422.07  |
| 17                | 2.32     | 2.38     | 58.62    | 2.18     | 13.28    | 12.47    | 1.00     | 72737.27  |
| 18                | 9.46     | 2.39     | 53.76    | 2.62     | 13.40    | 11.67    | 1.02     | 79196.45  |
| 19                | 14.32    | 2.89     | 52.10    | 3.55     | 13.04    | 11.61    | 1.02     | 80051.48  |
| 20                | 12.04    | 2.30     | 47.55    | 5.58     | 12.83    | 11.68    | 1.02     | 79072.11  |
| 21                | 5.45     | 2.52     | 51.10    | 4.28     | 13.44    | 11.90    | 1.02     | 76874.01  |
| 22                | 1.13     | 4.73     | 55.02    | 3.44     | 12.69    | 12.90    | 1.03     | 68797.94  |
| 23                | 8.19     | 3.68     | 30.22    | 3.67     | 14.18    | 11.39    | 1.03     | 80719.35  |
| 監測時數              | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 超限次數              | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0         |
| 有效時數              | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 平 均 值             | 8.86     | 3.87     | 47.16    | 3.16     | 13.03    | 11.87    | 1.01     | 77371.38  |
| 最 大 值             | 14.45    | 7.38     | 58.62    | 5.58     | 16.28    | 12.90    | 1.05     | 80719.35  |
| 發生時間              | 6        | 0        | 17       | 20       | 1        | 22       |          | 23        |
| 最 小 值             | 1.13     | 2.30     | 30.22    | 2.18     | 11.04    | 11.39    | 0.97     | 68797.94  |
| 發生時間              | 22       | 20       | 23       | 17       | 16       | 23       |          | 22        |
| 零點偏移(率)           | -0.02 %  | -0.08 %  | -0.20 %  | -0.00 %  |          | 0.00     |          | 0.10 %    |
| 全幅偏移(率)           | 0.02 %   | -0.66 %  | -0.08 %  | -0.24 %  |          | -0.14    |          | 0.20 %    |
| 有效比率              | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 %  |
| 備註                |          |          |          |          |          |          |          |           |

## P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年02月06日

| 項目<br>單位<br>小時\限標 | #3-HCl_C | #3-CO_C  | #3-NOx_C | #3-SO <sub>2</sub> _C | #3-H <sub>2</sub> O | #3-O <sub>2</sub> _C | #3-OPAC  | #3-FLOW_C |
|-------------------|----------|----------|----------|-----------------------|---------------------|----------------------|----------|-----------|
|                   | ppm      | ppm      | ppm      | ppm                   | %                   | %                    | %        | m3/Hour   |
|                   | 60.00    | 150.00   | 220.00   | 150.00                | 100.00              | 25.00                | 10.00    | 999999.00 |
| 0                 | 8.91     | 6.02     | 57.51    | 2.18                  | 13.89               | 11.11                | 1.04     | 79097.90  |
| 1                 | 9.12     | 5.12     | 58.48    | 1.91                  | 14.84               | 11.30                | 1.04     | 76243.68  |
| 2                 | 9.64     | 4.22     | 58.97    | 1.81                  | 14.83               | 11.02                | 1.04     | 77989.60  |
| 3                 | 9.16     | 4.48     | 56.58    | 1.44                  | 15.70               | 10.59                | 1.04     | 79018.10  |
| 4                 | 8.51     | 5.06     | 56.02    | 1.72                  | 14.57               | 10.88                | 1.06     | 77039.54  |
| 5                 | 9.58     | 5.35     | 60.73    | 1.83                  | 14.45               | 10.97                | 1.05     | 77893.71  |
| 6                 | 9.71     | 5.71     | 57.90    | 1.94                  | 14.09               | 10.91                | 1.04     | 76662.17  |
| 7                 | 10.96    | 4.34     | 60.77    | 1.46                  | 14.76               | 10.90                | 1.04     | 79559.42  |
| 8                 | 9.37     | 3.05     | 56.12    | 1.56                  | 14.31               | 11.00                | 1.05     | 77108.03  |
| 9                 | 9.68     | 3.11     | 57.55    | 1.16                  | 15.66               | 10.81                | 1.04     | 79089.71  |
| 10                | 8.83     | 4.14     | 53.75    | 1.43                  | 14.33               | 10.93                | 1.04     | 79553.89  |
| 11                | 10.29    | 5.50     | 58.75    | 2.27                  | 13.26               | 10.97                | 1.04     | 77415.00  |
| 12                | 9.85     | 3.24     | 55.26    | 2.44                  | 12.80               | 10.83                | 1.03     | 74816.90  |
| 13                | 7.11     | 3.43     | 54.53    | 2.13                  | 12.97               | 10.87                | 1.04     | 73433.68  |
| 14                | 9.97     | 5.02     | 54.81    | 1.95                  | 13.88               | 10.65                | 1.04     | 76581.96  |
| 15                | 9.91     | 4.78     | 49.61    | 2.40                  | 13.46               | 10.40                | 1.04     | 73710.96  |
| 16                | 9.42     | 2.60     | 59.83    | 2.09                  | 12.92               | 11.16                | 1.04     | 73171.90  |
| 17                | 8.29     | 4.61     | 55.26    | 1.66                  | 13.63               | 10.93                | 1.05     | 75096.97  |
| 18                | 8.92     | 3.30     | 55.79    | 1.85                  | 13.58               | 10.78                | 1.04     | 75916.10  |
| 19                | 10.52    | 2.61     | 60.48    | 2.51                  | 12.89               | 10.88                | 1.04     | 75922.21  |
| 20                | 8.26     | 2.14     | 60.18    | 1.68                  | 13.74               | 11.01                | 1.04     | 74872.78  |
| 21                | 9.87     | 4.98     | 63.28    | 1.72                  | 13.78               | 10.81                | 1.04     | 74804.63  |
| 22                | 9.12     | 6.17     | 56.60    | 1.95                  | 13.64               | 10.76                | 1.03     | 74257.96  |
| 23                | 9.37     | 2.03     | 61.19    | 1.15                  | 14.90               | 10.60                | 1.04     | 76161.64  |
| 監測時數              | 24       | 24       | 24       | 24                    | 24                  | 24                   | 24       | 24        |
| 超限次數              | 0        | 0        | 0        | 0                     | 0                   | 0                    | 0        | 0         |
| 有效時數              | 24       | 24       | 24       | 24                    | 24                  | 24                   | 24       | 24        |
| 平 均 值             | 9.35     | 4.21     | 57.50    | 1.84                  | 14.04               | 10.88                | 1.04     | 76475.77  |
| 最 大 值             | 10.96    | 6.17     | 63.28    | 2.51                  | 15.70               | 11.30                | 1.09     | 79559.42  |
| 發生時間              | 7        | 22       | 21       | 19                    | 3                   | 1                    |          | 7         |
| 最 小 值             | 7.11     | 2.03     | 49.61    | 1.15                  | 12.80               | 10.40                | 1.02     | 73171.90  |
| 發生時間              | 13       | 23       | 15       | 23                    | 12                  | 15                   |          | 16        |
| 零點偏移(率)           | -0.04 %  | 0.00 %   | -0.19 %  | -0.03 %               |                     | 0.03                 |          | -0.10 %   |
| 全幅偏移(率)           | 0.01 %   | -0.17 %  | -0.23 %  | -0.08 %               |                     | -0.15                |          | 0.00 %    |
| 有效比率              | 100.00 % | 100.00 % | 100.00 % | 100.00 %              | 100.00 %            | 100.00 %             | 100.00 % | 100.00 %  |
| 備註                |          |          |          |                       |                     |                      |          |           |