

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年05月24日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.92	2.34	54.29	2.97	16.56	11.28	1.33	71113.97
1	6.92	3.45	52.16	3.38	17.28	11.57	1.33	67353.11
2	8.26	1.53	52.66	2.71	19.23	10.50	1.31	71605.00
3	8.66	2.49	45.83	3.25	17.47	10.83	1.31	70950.56
4	9.94	2.82	58.99	3.76	16.10	11.69	1.33	65499.93
5	5.98	1.20	58.98	2.48	19.64	10.51	1.31	72322.49
6	5.75	1.62	64.38	2.50	18.89	11.02	1.33	71260.19
7	3.61	1.79	58.00	2.39	19.33	10.62	1.33	73542.94
8	2.87	2.87	52.55	3.01	16.82	11.63	1.31	68311.01
9	4.14	6.39	45.50	3.89	15.25	11.59	1.26	67341.45
10	6.16	7.92	48.20	4.77	15.01	11.66	1.28	64618.26
11	4.42	5.03	49.65	4.00	15.57	11.47	1.29	65668.23
12	5.09	3.14	54.93	3.91	16.19	11.29	1.30	67386.89
13	3.35	2.82	50.71	3.43	16.53	11.32	1.29	65944.04
14	5.21	2.85	49.39	3.65	16.72	11.35	1.27	66235.50
15	8.87	2.96	48.71	4.25	17.51	10.73	1.26	67693.26
16	8.46	3.24	53.05	3.50	18.07	10.87	1.28	68877.77
17	3.26	4.99	49.48	3.48	15.67	12.01	1.32	62040.52
18	2.41	4.53	60.57	3.05	17.08	12.17	1.28	64307.52
19	5.98	3.39	33.87	3.83	16.66	11.56	1.28	68559.17
20	9.20	10.62	50.35	4.22	15.37	11.75	1.27	65832.23
21	5.54	7.62	48.09	3.69	15.77	11.27	1.25	66533.30
22	4.53	4.26	60.06	3.30	16.62	11.52	1.27	67490.37
23	4.43	2.70	50.47	3.02	17.02	11.31	1.28	67912.47
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.87	3.86	52.12	3.43	16.93	11.31	1.30	67850.01
最大值	9.94	10.62	64.38	4.77	19.64	12.17	1.38	73542.94
發生時間	4	20	6	10	5	18		7
最小值	2.41	1.20	33.87	2.39	15.01	10.50	1.25	62040.52
發生時間	18	5	19	7	10	2		17
零點偏移(率)	-0.02 %	-0.03 %	-0.03 %	-0.00 %		-0.01	0.00	0.00 %
全幅偏移(率)	0.02 %	0.48 %	-0.00 %	0.01 %		-0.10	-0.03	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年05月24日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.12	1.58	47.42	1.96	18.18	10.09	1.46	78960.99
1	5.80	2.81	44.46	1.72	19.27	9.31	1.46	83183.49
2	7.57	5.59	42.55	2.64	20.44	8.87	1.46	84648.11
3	8.88	1.88	45.77	2.92	17.83	9.33	1.46	80958.22
4	9.72	1.42	43.88	2.55	18.04	9.33	1.49	81834.17
5	8.94	3.64	45.75	2.59	17.65	9.21	1.49	81221.27
6	0.45	1.86	61.64	1.26	19.69	10.74	1.46	77327.31
7	0.20	1.68	60.87	1.55	18.51	11.34	1.46	70757.31
8	0.19	1.57	46.09	1.23	19.77	10.50	1.41	77804.53
9	0.14	5.25	36.49	1.18	19.71	8.98	1.42	86075.43
10	0.59	2.50	48.47	1.92	17.27	9.69	1.45	81945.83
11	3.42	2.17	49.83	2.01	18.05	9.48	1.45	82552.62
12	9.53	2.98	48.90	2.66	18.08	9.34	1.42	84069.15
13	10.28	4.74	59.14	2.67	18.07	9.32	1.42	80614.26
14	8.59	2.51	45.76	2.44	18.41	9.69	1.42	79225.15
15	17.40	2.90	45.79	3.55	18.42	9.06	1.41	82089.33
16	8.94	2.27	51.16	2.11	20.69	8.44	1.40	88268.48
17	5.99	3.23	45.51	1.92	20.22	8.92	1.41	86059.86
18	8.24	1.35	52.63	1.95	20.64	9.22	1.44	87103.28
19	9.02	1.34	55.93	2.59	20.19	9.23	1.43	88318.55
20	8.74	1.78	49.09	3.06	17.01	9.93	1.42	82704.68
21	7.65	2.52	53.18	2.06	19.58	9.17	1.43	83164.62
22	3.23	6.66	64.65	1.42	21.40	8.28	1.44	87520.59
23	7.03	1.64	49.03	2.18	17.38	9.74	1.45	81277.79
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.53	2.74	49.75	2.17	18.94	9.47	1.44	82403.54
最大值	17.40	6.66	64.65	3.55	21.40	11.34	1.50	88318.55
發生時間	15	22	22	15	22	7		19
最小值	0.14	1.34	36.49	1.18	17.01	8.28	1.39	70757.31
發生時間	9	19	9	9	20	22		7
零點偏移(率)	-0.19 %	0.00 %	-0.06 %	-0.03 %		0.00	0.00	0.00 %
全幅偏移(率)	0.21 %	0.76 %	-0.12 %	0.13 %		-0.24	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年05月24日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.11	1.42	61.47	1.96	17.54	10.87	1.43	81998.59
1	5.15	2.04	47.86	1.83	17.23	10.50	1.43	82803.83
2	6.86	1.96	56.80	2.21	16.12	10.73	1.43	83239.09
3	9.78	1.33	58.09	2.49	16.07	10.91	1.43	82777.88
4	9.92	4.91	57.96	3.58	15.59	10.81	1.42	82061.16
5	8.58	1.38	61.91	2.86	14.76	11.10	1.43	81051.12
6	6.55	1.22	65.56	2.27	17.17	11.01	1.43	80404.42
7	0.30	1.29	62.25	1.78	18.34	11.38	1.43	75891.17
8	0.48	1.46	45.00	1.63	18.79	10.29	1.43	86307.83
9	1.66	2.38	53.61	1.76	17.37	10.44	1.45	85412.24
10	5.26	2.53	52.56	2.60	15.82	10.50	1.43	79083.85
11	6.64	2.10	51.28	2.51	16.48	10.30	1.43	79249.54
12	7.17	2.63	55.41	2.31	17.22	10.37	1.45	80835.82
13	11.56	1.76	59.46	2.99	16.78	10.43	1.43	79083.18
14	5.20	2.11	51.25	2.40	16.78	10.49	1.43	75859.18
15	6.82	2.01	59.06	2.52	17.30	9.89	1.43	79766.26
16	13.09	3.18	50.57	2.69	17.17	10.43	1.44	79256.89
17	5.66	3.61	52.56	2.37	18.76	10.02	1.44	83296.62
18	8.03	1.72	60.45	2.38	18.61	10.07	1.43	85836.69
19	10.35	1.97	56.59	2.84	16.34	10.47	1.43	82512.04
20	2.85	3.28	50.70	1.96	17.56	10.48	1.43	80182.08
21	9.84	2.41	53.50	2.61	18.81	9.75	1.43	87458.57
22	14.66	2.51	57.63	3.08	16.22	10.66	1.43	80585.24
23	7.67	1.98	66.98	2.40	17.49	11.02	1.44	79213.43
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.05	2.22	56.19	2.42	17.10	10.54	1.43	81423.61
最大值	14.66	4.91	66.98	3.58	18.81	11.38	1.48	87458.57
發生時間	22	4	23	4	21	7		21
最小值	0.30	1.22	45.00	1.63	14.76	9.75	1.41	75859.18
發生時間	7	6	8	8	5	21		14
零點偏移(率)	-0.17 %	0.00 %	-0.03 %	0.00 %		0.00	0.00	0.00 %
全幅偏移(率)	1.17 %	0.04 %	-0.40 %	-0.02 %		-0.16	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								