

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年03月03日

報表日期: 114年03月03日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.38	4.27	56.09	1.86	17.22	11.61	1.29	80317.12
1	7.77	4.31	55.97	2.38	17.21	11.76	1.29	78960.73
2	11.57	4.02	54.46	2.52	16.35	11.75	1.29	79729.95
3	8.83	6.40	52.84	2.03	17.44	11.56	1.29	80013.48
4	7.30	8.12	53.13	1.45	17.35	11.87	1.29	76019.88
5	8.04	1.69	56.43	2.14	16.50	11.71	1.30	81640.31
6	8.52	3.76	48.38	2.26	16.61	11.85	1.29	78595.49
7	9.08	3.76	60.08	1.93	16.93	11.90	1.29	78121.87
8	11.89	4.08	64.05	1.81	16.67	11.87	1.31	78228.27
9	10.31	3.77	53.48	2.12	16.22	11.77	1.32	78468.50
10	14.38	4.06	52.27	2.95	15.68	11.83	1.31	78239.19
11	9.28	3.65	57.14	2.12	16.25	11.76	1.29	77112.59
12	13.39	2.25	49.22	2.77	15.62	11.66	1.29	74700.21
13	12.20	3.45	57.11	1.79	16.48	11.71	1.29	75096.73
14	8.02	3.89	63.30	1.34	16.79	11.36	1.29	77741.01
15	8.80	2.42	56.73	1.43	16.33	11.68	1.29	75366.86
16	2.42	2.89	69.10	1.05	16.35	12.55	1.29	72014.85
17	0.33	3.32	65.26	0.43	18.84	11.69	1.29	76851.32
18	6.94	3.77	67.26	0.52	20.00	10.70	1.30	85473.32
19	8.27	3.31	45.99	1.46	18.28	10.97	1.31	84615.13
20	8.25	6.62	42.97	1.51	17.83	11.22	1.29	82475.42
21	8.97	4.54	53.77	1.65	17.17	11.46	1.29	80065.06
22	5.80	3.31	64.91	0.93	18.07	12.00	1.29	76689.21
23	7.12	3.43	62.52	1.05	18.07	11.10	1.29	83952.57
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.62	3.96	56.77	1.73	17.09	11.64	1.30	78770.38
最 大 值	14.38	8.12	69.10	2.95	20.00	12.55	1.33	85473.32
發生時間	10	4	16	10	18	16		18
最 小 值	0.33	1.69	42.97	0.43	15.62	10.70	1.27	72014.85
發生時間	17	5	20	17	12	18		16
零點偏移(率)	-0.96 %	0.00 %	-0.02 %	-0.00 %		-0.12		0.20 %
全幅偏移(率)	0.00 %	0.98 %	0.10 %	0.45 %		-0.40		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年03月03日

[illegible]

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年03月03日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	3.66	5.41	63.75	1.13	18.03	10.31	1.50	83353.20
1	11.68	4.14	58.93	1.83	17.30	10.88	1.50	79379.38
2	14.37	5.95	61.58	2.13	16.06	10.90	1.50	79815.01
3	14.55	7.79	58.78	3.35	15.73	10.84	1.51	80079.24
4	13.24	3.89	59.19	2.04	15.69	11.27	1.52	77085.83
5	11.14	2.56	59.84	1.77	15.78	11.10	1.52	77750.67
6	12.16	8.22	58.57	1.61	16.71	10.76	1.52	80867.80
7	10.68	7.49	60.32	2.40	14.48	11.53	1.52	74319.61
8	18.00	4.63	58.99	3.14	14.38	11.64	1.52	77101.26
9	16.20	1.88	61.28	2.20	14.99	11.40	1.52	77023.89
10	15.77	1.59	60.20	2.20	14.74	11.47	1.50	75923.10
11	12.08	2.76	56.74	1.52	15.75	10.77	1.52	75439.77
12	10.02	2.54	60.54	1.29	16.03	10.91	1.51	72742.02
13	10.42	4.18	54.02	1.30	16.32	10.59	1.50	78367.28
14	10.07	4.52	64.35	1.08	16.93	10.90	1.49	77409.67
15	15.74	7.83	60.42	1.67	16.38	10.84	1.49	76652.30
16	11.53	3.21	67.18	0.95	17.87	10.30	1.50	83902.98
17	12.77	9.88	54.96	0.92	17.64	10.20	1.51	84872.14
18	11.49	1.89	63.31	0.93	17.29	10.71	1.49	81059.44
19	10.92	3.74	54.94	1.03	18.41	10.06	1.50	84039.99
20	13.32	3.27	58.70	1.39	17.56	10.44	1.52	82263.06
21	10.89	2.40	61.96	0.97	17.61	10.50	1.52	81925.63
22	11.23	2.59	65.27	1.10	17.33	11.05	1.52	78647.95
23	9.75	3.56	54.84	1.58	16.17	11.04	1.49	79245.26
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	12.15	4.41	59.94	1.65	16.47	10.85	1.51	79136.10
最 大 值	18.00	9.88	67.18	3.35	18.41	11.64	1.53	84872.14
發生時間	8	17	16	3	19	8		17
最 小 值	3.66	1.59	54.02	0.92	14.38	10.06	1.48	72742.02
發生時間	0	10	13	17	8	19		12
零點偏移(率)	-0.08 %	-0.03 %	-0.03 %	-0.02 %		-0.12		-0.10 %
全幅偏移(率)	-1.36 %	1.14 %	0.06 %	0.36 %		-0.42		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								