

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月09日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.35	6.39	59.98	1.34	18.95	11.56	1.02	77561.92
1	7.33	6.24	57.73	1.38	19.90	11.38	1.00	77817.07
2	9.44	9.13	52.78	2.48	17.56	11.54	1.00	78595.03
3	11.09	7.79	46.85	2.87	17.50	11.65	1.01	77682.16
4	9.09	2.99	50.71	2.32	18.08	11.56	1.02	77731.05
5	10.03	14.26	62.10	1.87	18.49	11.28	1.01	82634.60
6	7.42	11.51	56.05	2.40	16.56	11.69	1.01	78071.47
7	10.65	6.38	53.40	2.16	17.71	11.24	1.02	80495.34
8	9.15	7.03	54.08	2.18	17.51	11.76	1.01	76052.81
9	8.48	5.60	56.62	1.30	19.03	11.36	1.02	77488.80
10	9.52	11.67	48.17	1.81	17.90	11.60	1.02	74985.70
11	8.72	8.99	46.81	2.30	17.17	11.46	0.99	76760.62
12	12.81	10.51	50.82	2.32	17.26	11.47	1.01	76192.05
13	16.21	15.40	48.28	4.18	15.57	11.75	1.03	74489.11
14	8.35	9.22	58.35	1.67	18.19	11.37	1.00	75389.47
15	8.97	8.70	51.43	1.59	17.98	11.31	1.01	76088.76
16	6.22	7.47	58.58	1.05	18.44	11.26	1.01	76200.82
17	8.99	9.16	43.48	2.09	16.55	11.33	0.99	76743.58
18	9.51	8.81	43.51	2.10	17.06	11.19	0.99	77561.10
19	8.80	9.10	45.76	2.72	15.63	11.73	1.01	75204.74
20	7.56	13.23	62.94	1.46	18.19	11.63	1.05	75151.35
21	5.29	13.01	68.54	0.80	19.46	11.22	1.05	79169.00
22	1.99	14.09	56.05	0.63	19.76	11.02	1.05	79470.94
23	0.55	8.74	56.76	0.62	19.66	10.79	1.02	80798.29
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.52	9.39	53.74	1.90	17.92	11.42	1.01	77430.66
最大值	16.21	15.40	68.54	4.18	19.90	11.76	1.14	82634.60
發生時間	13	13	21	13	1	8		5
最小值	0.55	2.99	43.48	0.62	15.57	10.79	0.99	74489.11
發生時間	23	4	17	23	13	23		13
零點偏移(率)	-0.02 %	0.00 %	-0.03 %	-0.01 %		0.00		0.00 %
全幅偏移(率)	0.93 %	0.57 %	0.26 %	0.19 %		0.18		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月09日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.08	4.13	50.94	2.26	16.96	10.66	0.97	84055.30
1	6.87	4.43	55.39	2.61	17.49	10.84	0.97	81935.82
2	9.14	4.87	53.17	3.32	15.19	11.06	0.97	82771.37
3	5.12	3.47	44.32	2.27	17.04	10.54	0.96	85197.42
4	5.57	5.41	54.17	3.06	16.61	10.78	0.96	83309.92
5	7.16	4.63	50.12	2.89	17.32	10.55	0.97	84179.42
6	5.44	6.97	60.28	2.54	18.26	10.29	0.97	78428.97
7	8.19	3.77	34.34	2.04	18.69	9.61	0.98	90131.49
8	8.71	5.09	48.48	1.95	19.60	9.64	0.98	88969.35
9	7.88	4.22	56.36	1.85	19.12	9.96	0.99	87506.39
10	5.17	4.02	44.11	2.35	17.55	10.20	0.99	86711.13
11	4.24	5.22	49.69	2.91	16.68	10.50	0.98	85301.12
12	7.86	4.35	47.97	2.87	16.37	10.61	0.97	84646.13
13	9.17	3.94	49.75	2.55	16.56	10.57	0.97	84737.52
14	9.33	3.45	58.44	2.02	17.46	10.25	0.97	86170.43
15	10.31	11.19	52.42	3.51	15.27	10.79	0.97	84482.53
16	8.49	4.22	51.42	3.04	15.56	10.82	0.97	84578.06
17	9.42	6.83	59.56	2.63	16.17	10.79	0.97	83851.77
18	10.03	4.07	55.22	2.65	15.95	10.80	0.97	84396.26
19	5.30	3.38	58.04	2.16	16.73	10.76	0.99	83709.91
20	6.34	6.55	54.00	2.52	16.68	10.59	0.97	85292.35
21	6.86	6.72	55.75	2.23	17.40	10.35	0.97	86178.06
22	1.28	8.35	54.08	2.00	16.89	10.57	0.97	84864.25
23	1.53	7.27	50.67	1.42	18.09	10.17	0.97	86352.47
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.90	5.27	52.03	2.49	17.07	10.49	0.97	84906.56
最大值	10.31	11.19	60.28	3.51	19.60	11.06	1.00	90131.49
發生時間	15	15	6	15	8	2		7
最小值	1.28	3.38	34.34	1.42	15.19	9.61	0.94	78428.97
發生時間	22	19	7	23	2	7		6
零點偏移(率)	-0.10 %	0.00 %	-0.06 %	-0.01 %		0.01		-0.20 %
全幅偏移(率)	0.22 %	-0.77 %	-0.30 %	0.16 %		-0.22		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月09日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.89	6.85	55.07	1.25	16.27	11.34	1.01	76321.70
1	2.36	7.37	56.60	1.27	16.72	11.64	1.02	74177.08
2	5.85	6.10	48.72	1.73	16.00	11.03	1.00	77330.21
3	6.39	5.56	48.37	2.32	15.46	11.04	1.02	77106.71
4	9.38	5.36	47.78	3.20	14.39	11.21	1.00	74446.05
5	7.46	4.18	41.76	2.56	14.82	10.88	0.99	73824.41
6	3.44	3.62	47.77	1.49	16.36	11.02	0.99	70635.73
7	0.45	8.18	40.66	1.10	15.35	11.15	1.03	69276.63
8	2.10	9.36	42.36	1.04	17.43	10.43	1.03	81336.58
9	5.16	5.11	52.85	1.35	17.21	10.58	1.05	83157.00
10	6.45	4.94	48.77	1.47	16.40	10.80	1.05	81773.69
11	6.13	6.58	52.77	2.03	15.00	11.22	1.05	78911.31
12	7.07	12.02	53.71	2.23	14.60	11.38	1.08	77621.56
13	3.54	13.41	50.02	2.50	13.74	11.31	1.06	76012.97
14	8.68	8.74	50.19	2.38	14.80	11.23	1.02	78453.23
15	3.70	11.45	52.04	1.90	14.63	11.37	1.03	74963.95
16	6.85	9.61	53.04	1.47	16.17	10.77	1.05	75740.65
17	7.48	7.31	45.88	2.34	14.04	10.95	1.00	74818.02
18	4.72	12.32	50.09	1.54	15.14	11.43	1.01	72578.09
19	6.94	6.31	59.26	1.99	15.11	11.19	1.03	77131.51
20	5.78	7.90	52.30	1.67	15.42	11.10	1.05	77926.90
21	5.92	8.06	45.05	2.09	14.51	10.90	1.04	76256.29
22	3.59	2.82	51.30	1.98	14.71	11.02	1.03	75050.93
23	0.55	6.26	50.02	1.69	14.75	11.00	1.01	75141.39
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.16	7.48	49.85	1.86	15.38	11.08	1.03	76249.69
最大值	9.38	13.41	59.26	3.20	17.43	11.64	1.10	83157.00
發生時間	4	13	19	4	8	1		9
最小值	0.45	2.82	40.66	1.04	13.74	10.43	0.99	69276.63
發生時間	7	22	7	8	13	8		7
零點偏移(率)	-0.17 %	0.00 %	-0.08 %	0.00 %		0.00		0.00 %
全幅偏移(率)	0.04 %	0.55 %	-0.76 %	-0.02 %		0.17		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								