

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 111年12月18日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.00	6.91	62.94	1.33	18.42	12.24	1.47	71048.69
1	4.75	0.95	54.54	0.60	20.86	10.94	1.41	78875.42
2	10.06	1.12	52.83	0.87	20.27	10.92	1.41	79466.75
3	11.01	9.21	53.06	1.61	17.27	11.71	1.41	76089.78
4	8.55	1.97	62.52	1.48	17.91	12.14	1.41	73752.16
5	8.14	2.11	57.82	0.91	19.97	11.35	1.44	76517.67
6	6.13	0.99	55.86	0.48	20.07	11.12	1.45	79227.20
7	12.13	3.28	48.10	0.99	19.06	11.11	1.46	80192.36
8	9.04	3.62	57.04	0.65	19.44	11.03	1.46	79618.16
9	9.32	7.61	43.89	1.05	16.89	11.75	1.46	76446.44
10	3.94	6.73	64.30	0.76	18.25	12.46	1.51	69717.53
11	3.44	6.78	54.30	0.65	19.47	11.88	1.57	73350.46
12	0.81	1.80	64.28	0.72	18.38	12.76	1.52	67440.92
13	1.24	1.55	48.38	0.58	19.54	11.79	1.47	74584.11
14	3.15	1.92	61.53	0.29	20.78	11.16	1.46	78132.89
15	7.21	1.14	50.16	0.17	21.92	10.64	1.46	80867.94
16	4.79	5.33	63.34	0.78	18.07	12.19	1.50	72708.79
17	6.19	7.55	69.94	1.03	17.77	12.69	1.57	68142.29
18	1.06	46.76	62.07	1.99	15.65	12.82	2.34	69351.35
19	1.15	1.64	36.58	2.00	15.58	11.65	1.81	78839.21
20	0.21	0.79	51.02	0.45	19.50	9.24	1.48	95344.44
21	2.28	1.79	48.76	0.61	19.71	11.57	1.49	76193.29
22	3.05	1.47	58.69	0.14	22.20	10.82	1.44	79836.03
23	8.65	1.14	56.59	0.29	21.70	10.17	1.42	85082.11
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.39	5.17	55.77	0.85	19.11	11.51	1.52	76701.08
最大值	12.13	46.76	69.94	2.00	22.20	12.82	2.88	95344.44
發生時間	7	18	17	19	22	18		20
最小值	0.21	0.79	36.58	0.14	15.58	9.24	1.40	67440.92
發生時間	20	20	19	22	19	20		12
零點偏移(率)	-0.05 %	-0.01 %	-0.06 %	0.00 %		0.04	0.00	0.00 %
全幅偏移(率)	-0.83 %	-0.20 %	-0.19 %	-0.07 %		0.63	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 111年12月18日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.03	4.82	53.28	1.39	18.29	10.24	1.41	67697.28
1	6.02	0.98	53.94	1.15	19.52	10.42	1.41	66807.19
2	8.69	1.11	55.63	1.41	19.25	10.10	1.41	67994.20
3	9.71	0.86	61.02	1.46	18.75	10.37	1.42	67732.43
4	7.76	1.41	62.78	1.25	19.15	10.33	1.40	67517.11
5	7.35	3.26	61.39	1.26	19.08	10.24	1.39	68174.84
6	8.07	1.10	46.95	1.33	18.10	10.19	1.40	69713.36
7	12.25	1.95	55.22	1.41	19.46	9.96	1.38	68593.11
8	8.27	1.64	49.84	1.20	19.75	9.68	1.39	69339.28
9	10.93	3.25	55.31	1.16	19.71	9.99	1.39	68878.71
10	8.95	6.68	61.75	0.99	19.58	10.36	1.39	67285.10
11	10.24	5.57	56.33	1.38	19.05	10.08	1.41	69499.62
12	6.04	10.25	45.23	1.79	18.76	10.10	1.43	69721.11
13	7.27	1.00	49.91	1.17	18.45	10.44	1.45	68315.27
14	5.12	4.40	64.19	1.20	18.01	11.70	1.50	59980.27
15	8.14	1.14	45.02	1.11	18.97	10.27	1.44	68400.56
16	7.53	5.05	49.71	1.32	17.63	10.85	1.45	65593.89
17	8.18	3.24	52.41	1.34	17.74	10.95	1.44	64548.15
18	3.89	10.02	54.34	3.50	14.88	13.16	1.66	52128.69
19	3.44	3.27	40.01	4.83	9.74	14.38	1.42	45317.75
20	0.32	0.65	45.50	0.65	16.28	9.63	1.43	74733.42
21	2.26	1.40	50.34	0.81	19.18	9.65	1.46	73029.79
22	6.11	1.20	48.89	0.84	19.99	9.87	1.46	70837.76
23	8.56	3.40	54.05	1.18	18.48	10.40	1.46	68574.01
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.21	3.24	53.04	1.46	18.24	10.56	1.43	66683.87
最大值	12.25	10.25	64.19	4.83	19.99	14.38	2.49	74733.42
發生時間	7	12	14	19	22	19		20
最小值	0.32	0.65	40.01	0.65	9.74	9.63	1.38	45317.75
發生時間	20	20	19	20	19	20		19
零點偏移(率)	-0.01 %	-0.11 %	-0.24 %	-0.02 %		-0.08	0.00	0.00 %
全幅偏移(率)	-0.62 %	-0.09 %	0.30 %	-0.15 %		0.58	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 111年12月18日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.17	4.63	64.24	2.39	14.54	11.51	1.33	85312.05
1	9.43	1.20	61.49	2.07	16.79	10.94	1.31	87717.11
2	8.39	1.29	59.69	2.08	17.06	10.28	1.30	94220.09
3	7.12	1.50	58.01	1.91	16.50	10.56	1.30	91122.23
4	6.08	1.96	60.31	1.79	17.09	10.80	1.29	89743.17
5	5.21	8.73	54.59	1.90	16.27	10.64	1.27	89097.92
6	4.71	2.01	62.01	1.98	16.27	11.10	1.26	85923.75
7	5.77	4.64	67.03	1.30	15.86	11.40	1.30	92926.24
8	5.41	5.99	55.65	1.23	16.91	10.86	1.32	87752.25
9	8.22	2.70	61.74	1.10	17.16	10.87	1.33	87092.06
10	7.85	3.97	59.87	1.10	18.28	10.46	1.32	90214.87
11	6.77	5.52	52.79	0.94	17.65	10.22	1.31	93117.92
12	7.25	3.74	54.48	1.12	16.66	10.61	1.31	90613.48
13	5.87	1.58	52.76	1.13	16.42	10.85	1.30	87829.23
14	7.76	5.08	50.43	1.15	17.88	10.21	1.30	92180.65
15	9.57	3.58	52.48	1.37	16.46	10.49	1.33	92206.32
16	6.69	4.07	60.86	1.58	15.37	11.45	1.32	83232.94
17	6.58	3.89	65.03	1.54	15.79	11.72	1.33	81559.48
18	4.24	4.32	65.09	1.05	16.83	11.88	1.34	80252.45
19	0.50	8.86	57.61	2.21	14.09	13.34	1.93	69077.68
20	1.29	2.47	46.42	1.14	16.60	10.55	1.43	91263.28
21	5.97	3.69	52.53	1.17	17.79	9.61	1.31	93044.22
22	9.04	2.25	58.65	1.23	16.08	11.07	1.28	86134.98
23	7.64	2.71	55.79	0.90	17.22	11.02	1.28	87189.97
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.40	3.77	57.90	1.47	16.57	10.94	1.34	87867.68
最大值	9.57	8.86	67.03	2.39	18.28	13.34	2.48	94220.09
發生時間	15	19	7	0	10	19		2
最小值	0.50	1.20	46.42	0.90	14.09	9.61	1.25	69077.68
發生時間	19	1	20	23	19	21		19
零點偏移(率)	-0.05 %	-0.00 %	-0.21 %	-0.01 %		0.06	0.00	0.00 %
全幅偏移(率)	-4.32 %	-0.92 %	0.08 %	-0.01 %		0.78	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								