

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月01日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.45	13.46	44.94	2.36	15.45	11.66	1.23	77623.02
1	8.76	11.56	47.48	2.05	16.67	11.47	1.24	80934.31
2	12.19	13.06	54.96	2.44	16.65	11.05	1.25	84258.09
3	7.91	11.88	56.87	3.33	14.61	11.43	1.25	81080.06
4	8.48	11.62	55.74	2.62	15.88	11.57	1.25	79898.38
5	8.01	11.77	49.33	2.51	14.20	11.83	1.24	77021.47
6	6.76	12.38	58.36	1.84	16.11	11.90	1.24	78476.83
7	13.53	12.78	46.05	2.93	15.88	11.32	1.24	83371.38
8	11.15	11.90	57.27	2.63	14.83	11.72	1.24	80293.07
9	13.14	11.80	57.55	2.66	14.90	11.70	1.24	80454.24
10	7.25	11.81	55.24	2.69	15.23	11.66	1.22	80346.60
11	7.16	11.91	70.34	2.07	15.16	11.73	1.23	79698.23
12	6.15	12.39	46.87	2.35	14.65	11.96	1.26	78202.43
13	9.79	11.57	64.91	1.96	17.36	11.16	1.24	81905.91
14	10.20	11.49	56.86	1.74	17.55	11.04	1.23	82982.32
15	8.95	11.60	46.91	2.70	15.74	11.25	1.22	82579.96
16	10.58	12.12	55.37	2.57	15.69	11.38	1.22	81864.55
17	6.46	11.55	67.51	1.76	16.72	11.20	1.22	82098.30
18	9.55	12.54	43.27	2.39	15.48	11.37	1.20	81999.02
19	10.97	12.15	55.96	3.02	14.50	11.72	1.20	80062.15
20	5.99	11.62	56.73	2.05	16.46	11.35	1.23	81064.42
21	11.00	11.29	49.35	2.41	16.68	11.00	1.23	84077.61
22	8.20	12.17	60.10	1.69	16.65	11.45	1.24	80191.52
23	10.42	11.42	48.29	1.52	17.48	10.94	1.23	83826.01
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.25	11.99	54.43	2.35	15.86	11.45	1.23	81012.91
最大值	13.53	13.46	70.34	3.33	17.55	11.96	1.29	84258.09
發生時間	7	0	11	3	14	12		2
最小值	5.99	11.29	43.27	1.52	14.20	10.94	1.20	77021.47
發生時間	20	21	18	23	5	23		5
零點偏移(率)	-0.13 %	-0.03 %	-0.02 %	-0.00 %		-0.01	-0.01	0.20 %
全幅偏移(率)	-1.19 %	-0.74 %	0.59 %	-0.34 %		0.16	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月01日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.58	12.12	49.81	1.81	18.07	10.40	0.94	76338.39
1	8.79	11.85	51.03	2.00	17.53	10.08	0.94	80009.20
2	10.28	12.06	50.70	2.84	15.90	10.49	0.94	79681.79
3	7.54	12.21	61.50	1.48	17.23	10.82	0.94	76729.18
4	9.83	11.36	56.29	1.56	18.02	10.01	0.94	78580.97
5	8.11	11.58	49.25	2.01	15.77	10.48	0.93	79687.39
6	7.89	11.82	42.43	2.35	17.24	9.90	0.95	79099.49
7	7.13	11.57	50.16	1.26	15.98	10.45	0.94	76976.04
8	5.02	11.48	65.59	0.68	16.84	10.37	0.98	77855.82
9	12.51	11.88	51.08	1.41	16.51	10.55	1.00	79313.83
10	13.28	11.86	59.21	1.87	17.01	10.68	0.99	81251.92
11	2.59	12.01	59.43	0.65	17.05	10.78	0.99	76557.54
12	6.11	11.74	61.40	0.67	17.25	10.55	1.01	76418.41
13	1.03	11.96	50.11	0.84	17.12	10.73	1.01	80145.25
14	4.15	11.81	55.23	0.63	18.16	10.49	0.99	79545.18
15	7.93	11.90	48.50	1.57	16.65	10.72	0.99	77174.39
16	4.96	11.68	50.50	0.82	17.93	10.24	0.99	79887.19
17	9.44	11.44	44.27	0.94	17.46	10.23	1.00	80072.05
18	1.53	12.50	50.66	0.45	18.56	9.95	0.99	78149.26
19	6.99	13.40	42.73	1.33	17.59	9.94	0.99	78457.08
20	9.04	14.61	54.58	1.21	17.98	10.51	1.00	78304.99
21	7.93	13.60	53.73	1.16	16.71	10.62	1.02	81691.12
22	10.07	13.80	61.41	1.09	16.32	11.11	1.00	73160.71
23	1.21	13.42	42.48	0.47	18.82	10.39	0.98	75530.92
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.29	12.24	52.59	1.30	17.24	10.44	0.98	78359.09
最大值	13.28	14.61	65.59	2.84	18.82	11.11	1.02	81691.12
發生時間	10	20	8	2	23	22		21
最小值	1.03	11.36	42.43	0.45	15.77	9.90	0.93	73160.71
發生時間	13	4	6	18	5	6		22
零點偏移(率)	-0.06 %	0.00 %	-0.03 %	0.00 %		0.00	-0.01	0.10 %
全幅偏移(率)	-0.23 %	-0.03 %	1.82 %	-0.83 %		0.11	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月01日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.23	10.66	63.92	3.30	18.14	8.35	1.36	67675.35
1	11.68	11.37	57.18	3.05	18.57	7.81	1.37	71164.89
2	6.50	12.43	47.89	2.41	18.21	8.01	1.36	72343.86
3	10.34	11.85	52.84	2.65	19.48	7.72	1.36	77373.33
4	10.48	10.99	53.06	2.77	19.12	7.55	1.36	76832.87
5	7.70	10.23	58.64	1.63	19.04	7.61	1.36	74915.44
6	11.69	10.71	46.50	2.73	19.01	7.62	1.37	75414.16
7	8.51	10.25	34.98	1.62	18.59	7.65	1.36	73962.92
8	14.14	8.38	45.83	1.76	17.82	8.37	1.36	80002.11
9	8.65	10.15	56.03	1.63	17.99	8.29	1.32	78483.41
10	14.85	10.01	61.73	1.93	17.83	8.75	1.36	79971.75
11	14.57	11.37	39.90	1.80	18.48	8.10	1.36	79434.98
12	8.73	10.86	53.53	1.63	16.65	8.98	1.34	76286.70
13	5.89	11.42	61.32	1.54	15.51	10.54	1.32	73328.66
14	6.92	11.11	55.59	1.34	18.10	9.84	1.31	72592.46
15	9.32	10.70	54.46	1.41	17.39	9.59	1.32	75191.75
16	8.98	10.98	50.85	1.36	15.80	10.10	1.36	73572.39
17	7.18	10.83	51.12	1.30	17.05	9.78	1.36	71718.07
18	6.77	11.96	47.61	1.23	16.97	9.67	1.36	73349.23
19	9.11	12.94	44.99	1.24	17.08	9.71	1.35	72548.93
20	9.31	13.24	50.21	1.36	17.36	9.89	1.32	73095.12
21	9.57	12.60	49.39	2.06	18.29	9.60	1.31	78221.27
22	8.89	12.34	54.68	3.02	19.49	9.65	1.34	73553.08
23	7.86	11.98	64.57	3.22	18.50	9.38	1.36	78075.61
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.37	11.22	52.37	2.00	17.94	8.86	1.35	74962.85
最大值	14.85	13.24	64.57	3.30	19.49	10.54	1.38	80002.11
發生時間	10	20	23	0	22	13		8
最小值	5.89	8.38	34.98	1.23	15.51	7.55	1.31	67675.35
發生時間	13	8	7	18	13	4		0
零點偏移(率)	-0.06 %	0.00 %	-0.02 %	-0.01 %		-0.03	-0.01	0.20 %
全幅偏移(率)	0.02 %	1.43 %	0.87 %	0.12 %		0.25	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								