

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年06月16日

報表日期: 114年06月16日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.34	3.92	61.12	2.31	17.29	11.77	1.26	77864.15
1	8.79	5.17	54.06	3.44	16.81	11.39	1.25	80348.53
2	7.28	3.61	60.07	2.63	18.12	11.42	1.26	79292.30
3	9.67	4.85	57.19	2.69	18.08	10.86	1.27	84450.04
4	5.32	3.14	56.98	4.27	14.76	11.96	1.28	78148.05
5	5.98	2.73	52.09	3.07	16.40	11.83	1.27	80868.49
6	6.02	1.93	55.32	2.87	16.98	11.40	1.29	79904.56
7	3.75	1.69	58.80	2.40	16.50	11.67	1.28	78031.80
8	8.35	1.82	55.23	3.56	16.22	11.56	1.28	77955.69
9	3.22	2.00	60.41	2.74	15.80	12.76	1.27	69169.66
10	2.73	2.61	30.49	1.70	17.84	11.00	1.28	84057.69
11	3.93	3.61	38.81	2.90	15.60	11.82	1.29	78833.16
12	1.25	2.16	60.66	2.42	15.64	11.97	1.26	77568.21
13	4.92	2.08	65.91	1.87	16.19	12.21	1.25	75200.60
14	8.92	5.91	52.30	3.34	15.37	11.79	1.25	78838.35
15	2.93	3.73	51.27	3.21	14.65	11.92	1.25	76045.68
16	6.86	2.43	54.01	3.00	15.43	11.83	1.25	76628.87
17	1.37	3.70	53.66	2.11	15.70	11.59	1.26	76416.83
18	3.26	3.93	61.56	2.15	15.72	11.74	1.27	76980.72
19	1.63	4.27	60.24	1.88	16.23	11.96	1.28	77142.56
20	1.62	4.11	52.52	1.66	17.19	11.26	1.27	82341.64
21	0.97	4.35	55.57	2.52	15.64	11.62	1.25	80600.30
22	2.58	4.30	63.35	2.04	16.36	11.70	1.25	79404.46
23	4.50	5.51	55.92	2.83	15.24	12.01	1.25	77425.36
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	4.63	3.48	55.31	2.65	16.24	11.71	1.27	78479.90
最 大 值	9.67	5.91	65.91	4.27	18.12	12.76	1.29	84450.04
發生時間	3	14	13	4	2	9		3
最 小 值	0.97	1.69	30.49	1.66	14.65	10.86	1.25	69169.66
發生時間	21	7	10	20	15	3		9
零點偏移(率)	-0.10 %	0.01 %	-0.01 %	-0.01 %		-0.32		0.00 %
全幅偏移(率)	0.00 %	0.91 %	-0.15 %	0.85 %		-0.11		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年06月16日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.90	4.91	55.45	1.19	19.07	10.42	1.09	83395.66
1	2.98	4.94	51.13	1.56	18.40	10.40	1.09	84427.30
2	2.99	6.20	56.14	2.17	18.08	10.71	1.06	81660.41
3	3.30	4.87	59.70	2.07	16.91	11.08	1.06	79253.78
4	3.90	6.59	61.24	3.05	16.46	11.06	1.06	79011.07
5	3.59	1.19	51.92	1.53	18.48	10.22	1.06	79764.70
6	0.11	3.47	63.04	3.46	15.43	10.85	1.05	94888.38
7	1.70	5.72	50.70	1.58	18.87	10.08	1.04	82971.03
8	3.18	0.64	52.96	2.04	16.42	10.67	1.06	82168.83
9	1.45	0.57	44.49	1.60	17.56	10.42	1.05	81080.76
10	3.20	1.35	49.93	1.85	16.88	11.06	1.07	77969.58
11	1.17	2.02	59.69	1.32	17.61	11.03	1.05	81400.55
12	1.27	2.84	61.27	2.95	15.65	11.49	1.04	78721.11
13	1.12	2.40	58.02	2.24	16.28	11.22	1.04	80126.38
14	1.31	1.86	61.68	1.81	17.54	10.72	1.04	81397.51
15	1.66	1.94	54.04	1.77	16.73	10.87	1.04	79189.67
16	2.07	2.09	53.60	2.50	15.87	10.89	1.04	79762.01
17	3.00	1.96	57.08	2.40	16.53	10.91	1.05	82226.03
18	2.32	7.72	56.87	2.04	17.08	10.72	1.04	80945.52
19	5.38	2.22	59.55	2.10	17.22	10.70	1.04	79863.56
20	5.04	3.17	52.28	2.61	16.67	10.60	1.05	80761.97
21	8.98	2.48	53.14	2.71	16.11	10.58	1.05	79529.07
22	9.09	2.04	58.96	2.16	17.43	10.83	1.05	77537.29
23	5.45	2.16	52.46	1.04	19.38	10.23	1.05	82784.47
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	3.22	3.14	55.64	2.07	17.19	10.74	1.05	81284.86
最 大 值	9.09	7.72	63.04	3.46	19.38	11.49	1.11	94888.38
發生時間	22	18	6	6	23	12		6
最 小 值	0.11	0.57	44.49	1.04	15.43	10.08	1.04	77537.29
發生時間	6	9	9	23	6	7		22
零點偏移(率)	-0.11 %	-0.08 %	-0.03 %	0.01 %		-0.10		-0.20 %
全幅偏移(率)	0.14 %	0.24 %	-0.17 %	0.25 %		-0.10		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 114年06月16日

報表日期: 114年06月16日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	1.35	3.78	48.53	2.74	19.84	9.31	1.36	82712.93
1	1.45	3.37	59.93	2.81	19.16	9.43	1.39	79195.71
2	2.53	2.19	58.03	2.82	18.22	10.00	1.38	77367.47
3	3.16	2.86	59.64	3.04	16.68	10.19	1.39	83326.47
4	4.15	2.91	57.68	3.06	16.78	10.03	1.38	81650.99
5	9.01	4.94	57.36	4.03	15.28	10.54	1.38	77593.32
6	5.80	5.36	52.76	3.38	15.86	10.26	1.36	72399.51
7	2.73	1.08	65.89	3.22	15.61	9.73	1.39	76993.59
8	4.39	2.50	60.59	2.92	17.27	9.13	1.39	76752.55
9	3.10	2.41	59.26	2.71	16.56	9.29	1.35	73465.76
10	4.39	4.76	61.79	2.91	16.42	9.36	1.37	73601.47
11	0.58	2.75	54.23	2.56	15.71	9.46	1.34	70106.99
12	0.54	2.49	61.92	2.62	16.09	9.98	1.35	74906.25
13	1.51	4.44	63.65	3.31	14.52	10.50	1.36	74164.51
14	2.24	1.26	63.19	2.63	15.77	10.36	1.36	71798.00
15	2.18	1.53	58.78	2.36	16.80	9.82	1.35	75854.11
16	2.17	3.23	60.89	2.58	15.80	9.91	1.33	75903.08
17	2.27	5.19	63.57	2.60	15.94	10.27	1.33	77327.16
18	2.15	5.26	56.46	2.42	17.45	9.68	1.35	77525.91
19	2.47	2.01	62.05	2.59	17.35	9.65	1.38	78978.09
20	2.25	4.46	58.44	2.46	16.90	9.67	1.36	79509.55
21	2.50	6.75	60.87	2.85	15.23	10.23	1.34	77157.11
22	2.54	2.07	63.54	2.60	16.60	10.25	1.34	74315.22
23	2.06	2.44	54.17	2.62	18.37	9.90	1.33	78747.70
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	2.81	3.33	59.30	2.83	16.68	9.87	1.36	76723.06
最 大 值	9.01	6.75	65.89	4.03	19.84	10.54	1.41	83326.47
發生時間	5	21	7	5	0	5		3
最 小 值	0.54	1.08	48.53	2.36	14.52	9.13	1.31	70106.99
發生時間	12	7	0	15	13	8		11
零點偏移(率)	-0.06 %	-0.00 %	-0.15 %	-0.08 %		-0.02		-0.10 %
全幅偏移(率)	0.02 %	-0.19 %	-0.05 %	-0.01 %		0.16		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								