

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 114年04月19日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.74	2.72	58.38	0.53	19.50	10.08	1.29	80546.40
1	8.61	9.33	47.25	1.39	18.06	10.57	1.30	78771.16
2	8.93	4.68	43.21	1.44	17.42	10.61	1.29	78429.81
3	5.53	2.35	47.26	1.10	17.70	10.71	1.29	78099.60
4	8.01	2.31	59.37	0.73	18.33	10.55	1.29	79884.95
5	7.90	1.53	55.88	0.89	18.12	10.61	1.32	80037.32
6	10.59	2.62	54.50	1.29	17.48	10.81	1.33	81058.83
7	8.38	2.73	59.08	1.04	17.65	10.96	1.34	78861.25
8	13.47	4.80	54.87	1.16	17.81	10.50	1.34	81054.27
9	0.08	6.45	61.58	0.30	19.11	9.85	1.31	80155.49
10	13.82	4.86	61.07	1.11	18.88	9.66	1.33	87012.07
11	13.79	3.15	44.06	1.99	16.66	10.84	1.34	82596.48
12	11.39	2.97	54.40	1.83	16.99	10.77	1.33	80429.13
13	4.22	3.20	51.32	1.39	16.75	10.81	1.32	78911.69
14	1.70	4.73	60.33	0.96	17.16	11.05	1.32	76070.06
15	5.21	1.95	52.92	0.81	18.62	10.24	1.31	80814.27
16	4.85	4.98	47.00	1.63	16.82	10.93	1.31	78746.83
17	7.93	1.92	51.65	1.01	17.94	10.95	1.32	78735.81
18	3.39	1.61	59.56	0.91	17.84	10.92	1.31	79394.81
19	3.05	1.56	49.74	0.83	18.12	10.69	1.32	79734.34
20	4.74	1.48	56.34	0.67	18.73	10.54	1.34	81735.78
21	6.44	1.72	45.87	0.99	18.56	10.49	1.34	81374.33
22	8.63	1.97	49.67	1.26	17.59	10.61	1.31	80879.87
23	4.89	7.34	58.75	0.47	18.70	10.69	1.32	79287.49
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.18	3.46	53.50	1.07	17.94	10.60	1.32	80109.25
最 大 值	13.82	9.33	61.58	1.99	19.50	11.05	1.35	87012.07
發生時間	10	1	9	11	0	14		10
最 小 值	0.08	1.48	43.21	0.30	16.66	9.66	1.29	76070.06
發生時間	9	20	2	9	11	10		14
零點偏移(率)	-0.12 %	-0.10 %	-0.02 %	-0.00 %		-0.29		0.20 %
全幅偏移(率)	0.00 %	0.38 %	-0.97 %	0.72 %		0.09		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年04月19日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.89	9.10	56.04	1.68	17.52	10.85	1.06	78757.54
1	9.72	6.24	50.74	2.96	14.88	10.92	1.06	79348.71
2	10.09	2.67	53.96	2.33	16.16	10.40	1.06	82429.18
3	8.52	2.90	55.80	2.47	17.39	10.25	1.06	83947.34
4	9.05	4.66	59.27	1.97	17.42	10.60	1.07	82383.30
5	9.76	2.90	54.20	2.53	17.11	10.44	1.06	85262.03
6	9.08	1.66	49.52	2.06	15.89	10.60	1.09	80550.73
7	7.83	3.10	62.30	1.77	16.92	10.67	1.09	80193.94
8	9.19	2.64	64.48	2.21	17.26	10.35	1.10	83238.65
9	6.78	3.27	62.65	2.06	16.38	10.51	1.10	82631.40
10	7.22	5.51	55.19	2.29	16.65	10.33	1.09	82589.44
11	8.04	1.07	64.64	1.97	17.06	10.37	1.10	83787.74
12	8.67	1.17	63.08	2.63	15.73	10.48	1.10	80704.72
13	8.64	1.42	64.40	2.70	15.64	10.56	1.10	78988.94
14	9.04	1.63	63.77	2.51	16.25	10.05	1.10	83232.34
15	8.77	3.47	65.02	2.54	17.15	9.72	1.10	84646.25
16	9.31	3.31	67.59	2.69	15.69	10.50	1.10	83320.64
17	9.02	5.27	63.80	2.67	15.34	10.92	1.10	81972.83
18	8.83	2.22	52.87	2.54	15.54	10.52	1.08	78963.59
19	8.73	2.49	45.98	2.02	16.12	10.52	1.09	78030.76
20	9.16	8.92	39.99	2.06	17.65	9.74	1.07	78440.05
21	9.89	3.92	59.04	2.63	16.31	10.14	1.06	82703.94
22	9.73	1.50	61.61	1.76	17.58	10.22	1.07	83153.63
23	8.27	2.28	53.03	2.03	17.66	10.30	1.07	84270.85
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.84	3.47	57.87	2.29	16.55	10.42	1.08	81814.52
最 大 值	10.09	9.10	67.59	2.96	17.66	10.92	1.12	85262.03
發生時間	2	0	16	1	23	1		5
最 小 值	6.78	1.07	39.99	1.68	14.88	9.72	1.06	78030.76
發生時間	9	11	20	0	1	15		19
零點偏移(率)	-0.07 %	-0.00 %	-0.02 %	-0.01 %		-0.01		0.00 %
全幅偏移(率)	0.00 %	0.06 %	-0.56 %	0.37 %		0.08		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 114年04月19日

報表日期: 114年04月19日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.44	5.14	48.68	1.83	18.36	8.74	1.52	84736.73
1	4.67	8.32	56.31	1.92	16.53	9.90	1.52	78474.63
2	12.17	8.75	55.87	2.46	16.92	9.70	1.53	81259.25
3	8.75	6.36	51.01	2.36	17.61	9.30	1.53	80036.39
4	9.80	1.81	52.59	2.02	17.52	9.66	1.53	81672.46
5	8.22	3.19	56.37	2.02	18.62	9.47	1.53	81360.06
6	9.08	5.55	55.92	2.36	18.21	9.06	1.54	83274.70
7	4.66	4.96	44.25	1.83	17.77	9.03	1.55	79819.00
8	6.57	7.92	49.74	1.73	16.88	9.72	1.57	78484.43
9	5.69	8.66	53.28	1.79	17.01	9.56	1.57	80160.76
10	8.42	2.39	67.24	2.32	18.16	9.50	1.54	81449.94
11	11.34	11.01	52.68	2.45	16.90	9.38	1.59	81473.01
12	5.53	1.34	63.44	1.87	16.91	9.78	1.55	77170.11
13	8.84	5.41	58.05	2.70	17.06	9.19	1.52	84631.29
14	8.09	5.33	57.78	2.10	16.27	9.94	1.52	79594.29
15	5.69	4.50	63.28	1.98	16.68	9.89	1.52	80727.00
16	5.62	4.51	62.81	1.77	17.36	9.69	1.52	82428.00
17	7.59	1.45	62.05	2.06	17.38	9.81	1.52	80807.89
18	4.26	5.25	58.76	1.67	18.41	9.46	1.54	81928.24
19	4.53	8.31	60.38	1.66	17.14	9.93	1.58	84522.77
20	4.29	4.62	61.70	1.71	17.34	9.84	1.53	82254.45
21	4.32	2.63	61.72	1.74	17.21	9.82	1.52	83518.61
22	6.49	1.16	61.68	1.69	17.69	9.83	1.55	81495.65
23	6.71	2.10	67.70	1.76	17.51	10.22	1.53	81100.92
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.78	5.03	57.64	1.99	17.39	9.60	1.54	81349.19
最 大 值	12.17	11.01	67.70	2.70	18.62	10.22	1.61	84736.73
發生時間	2	11	23	13	5	23		0
最 小 值	1.44	1.16	44.25	1.66	16.27	8.74	1.50	77170.11
發生時間	0	22	7	19	14	0		12
零點偏移(率)	-0.07 %	0.00 %	-0.06 %	0.00 %		0.01		-0.20 %
全幅偏移(率)	0.02 %	0.62 %	-0.48 %	0.07 %		0.37		-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								