

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 114年01月18日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.25	2.46	43.82	1.73	15.88	11.62	1.23	83018.30
1	10.13	2.56	41.90	1.67	16.93	11.49	1.23	82852.78
2	9.35	2.43	40.61	2.18	15.97	11.55	1.23	83418.46
3	9.18	2.50	41.19	2.80	14.31	12.03	1.23	82411.20
4	8.73	2.95	39.52	3.07	14.29	12.06	1.21	82037.80
5	9.84	3.39	45.65	1.68	16.35	11.49	1.23	81268.08
6	9.72	2.41	45.42	1.71	16.52	11.37	1.23	84525.77
7	9.66	2.48	42.93	1.53	16.47	11.43	1.21	83674.01
8	8.56	2.61	37.91	2.01	16.11	11.37	1.20	84228.90
9	8.27	2.65	36.83	1.82	15.97	11.49	1.24	83173.51
10	9.14	2.65	36.81	1.97	15.18	11.50	1.23	83821.24
11	10.29	3.00	37.99	2.15	14.59	11.97	1.21	80395.62
12	9.90	2.69	40.03	1.83	14.97	11.79	1.23	81774.59
13	6.76	2.84	42.66	1.79	15.27	12.05	1.23	78695.90
14	6.90	2.73	42.48	1.35	15.56	11.99	1.24	78901.97
15	9.68	4.02	43.31	1.50	16.75	11.38	1.24	83301.83
16	7.37	2.72	46.04	1.22	16.55	11.61	1.23	81710.13
17	9.28	2.86	48.78	1.05	17.32	11.23	1.22	83879.56
18	8.66	2.62	39.80	1.33	16.33	11.59	1.21	81454.97
19	8.47	2.56	39.12	1.31	16.36	11.54	1.20	81709.60
20	7.81	2.58	42.85	1.81	15.36	11.77	1.21	80709.96
21	10.09	2.92	53.01	2.33	14.94	11.90	1.20	80311.16
22	10.52	3.29	51.22	2.17	14.77	11.96	1.24	80006.55
23	13.67	2.91	49.43	2.44	14.50	12.07	1.24	79323.74
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.26	2.78	42.89	1.85	15.72	11.68	1.22	81941.90
最 大 值	13.67	4.02	53.01	3.07	17.32	12.07	1.26	84525.77
發生時間	23	15	21	4	17	23		6
最 小 值	6.76	2.41	36.81	1.05	14.29	11.23	1.19	78695.90
發生時間	13	6	10	17	4	17		13
零點偏移(率)	-0.05 %	-0.00 %	0.00 %	-0.00 %		-0.01		0.30 %
全幅偏移(率)	0.00 %	0.55 %	0.39 %	-0.00 %		-0.08		0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年01月18日

項目 單位 小時\限標	#2-HCl_C ppm	#2-CO_C ppm	#2-NOx_C ppm	#2-SO2_C ppm	#2-H2O %	#2-O2_C %	#2-OPAC %	#2-FLOW_C m3/Hour
0	11.68	1.62	50.02	4.88	13.68	11.15	1.14	82225.01
1	9.17	1.80	47.37	3.68	14.32	11.27	1.15	81239.37
2	9.64	1.57	55.33	2.10	14.02	11.31	1.18	81036.23
3	13.12	2.18	50.61	2.98	12.70	11.16	1.17	82373.68
4	11.41	1.59	57.27	1.98	13.34	11.44	1.16	81620.49
5	11.40	1.56	52.26	1.78	14.63	11.18	1.16	83285.85
6	17.30	2.98	46.66	4.10	13.64	11.14	1.14	85405.67
7	14.85	1.65	50.92	2.04	13.96	11.20	1.13	83923.04
8	13.01	1.71	54.16	1.54	13.44	11.43	1.11	83614.50
9	12.24	1.61	54.94	1.77	13.60	11.32	1.11	84445.79
10	12.10	1.58	53.26	1.82	13.55	11.38	1.13	84120.39
11	11.27	5.77	58.21	1.72	12.57	11.73	1.10	80443.22
12	12.72	2.56	39.08	1.39	14.62	11.14	1.10	79311.33
13	15.53	2.88	41.01	1.54	14.58	11.17	1.10	81772.38
14	17.70	1.68	35.57	1.61	15.55	10.74	1.12	84987.76
15	13.78	1.72	55.48	1.53	14.41	11.58	1.11	78615.86
16	11.45	2.02	57.98	0.99	15.73	11.41	1.10	80981.89
17	9.71	2.99	47.29	1.00	15.25	12.11	1.10	72914.16
18	11.77	3.19	39.47	1.21	16.48	10.53	1.10	83282.16
19	13.79	10.29	43.24	1.61	15.83	10.65	1.10	82695.87
20	14.13	5.11	48.64	1.67	14.49	11.16	1.10	81840.91
21	11.91	2.23	49.36	1.60	14.42	11.34	1.10	81462.30
22	15.69	4.27	51.69	1.75	13.97	11.28	1.10	80846.14
23	11.69	3.34	54.96	3.15	13.96	11.41	1.10	82870.38
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	12.79	2.83	49.78	2.06	14.28	11.26	1.12	81888.10
最 大 值	17.70	10.29	58.21	4.88	16.48	12.11	1.18	85405.67
發生時間	14	19	11	0	18	17		6
最 小 值	9.17	1.56	35.57	0.99	12.57	10.53	1.09	72914.16
發生時間	1	5	14	16	11	18		17
零點偏移(率)	-0.26 %	-0.00 %	-0.14 %	-0.02 %		0.01		0.00 %
全幅偏移(率)	0.14 %	0.08 %	0.29 %	0.32 %		-0.05		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 114年01月18日

報表日期: 114年01月18日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.78	4.77	46.61	2.71	16.15	10.49	1.50	83936.15
1	10.91	4.35	45.20	2.74	17.43	10.50	1.49	82825.38
2	9.97	4.78	43.51	3.62	16.51	10.52	1.48	83020.93
3	10.44	3.19	60.79	2.49	15.36	10.84	1.48	82442.97
4	10.48	5.31	60.85	2.66	14.24	11.19	1.48	79786.57
5	8.23	2.12	64.97	4.03	14.97	10.90	1.49	82137.21
6	9.24	3.76	60.19	4.56	14.90	11.00	1.50	81121.26
7	8.82	4.80	50.02	1.85	14.45	11.06	1.48	79803.30
8	10.47	2.59	44.39	3.06	14.26	11.15	1.48	80230.79
9	8.53	4.08	45.32	3.93	14.51	11.03	1.48	81544.76
10	8.71	5.39	42.69	1.44	14.32	11.05	1.49	80273.39
11	7.58	5.44	38.33	1.64	13.33	11.09	1.48	73861.73
12	8.06	6.31	39.91	1.37	15.77	10.57	1.48	78451.23
13	9.47	4.13	39.04	1.12	16.58	10.12	1.49	78623.20
14	8.11	2.67	44.03	1.04	18.06	9.73	1.50	84004.56
15	9.81	1.98	45.25	1.09	16.26	10.41	1.49	78283.18
16	8.89	2.13	48.10	0.97	16.19	10.82	1.48	81010.22
17	9.08	5.61	41.95	1.56	17.30	10.59	1.48	82535.75
18	10.33	3.71	44.04	1.40	17.45	10.37	1.48	83688.67
19	8.87	3.16	39.86	1.26	15.04	10.80	1.49	82092.76
20	11.19	5.53	53.17	1.32	13.94	11.33	1.50	79476.84
21	8.71	3.08	61.48	1.19	14.53	11.09	1.50	80794.53
22	12.52	2.68	53.29	1.60	14.63	11.01	1.50	81938.25
23	12.11	2.44	57.26	1.86	14.98	11.18	1.50	79803.10
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.64	3.92	48.76	2.10	15.47	10.78	1.49	80903.61
最 大 值	12.52	6.31	64.97	4.56	18.06	11.33	1.51	84004.56
發生時間	22	12	5	6	14	20		14
最 小 值	7.58	1.98	38.33	0.97	13.33	9.73	1.48	73861.73
發生時間	11	15	11	16	11	14		11
零點偏移(率)	-0.05 %	0.00 %	-0.03 %	-0.02 %		0.01		0.00 %
全幅偏移(率)	1.67 %	0.17 %	-0.12 %	0.04 %		-0.02		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								