

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月12日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.41	11.49	47.77	1.48	17.19	11.12	1.25	83658.04
1	9.36	11.63	52.38	1.29	18.49	11.09	1.25	82859.53
2	10.04	11.85	51.70	1.44	18.79	10.92	1.24	83825.81
3	6.82	12.44	68.42	1.38	18.10	11.69	1.24	78104.39
4	9.17	12.25	55.29	1.53	19.09	11.24	1.23	80599.11
5	8.54	13.36	62.84	2.06	17.57	11.62	1.19	83332.46
6	9.42	13.14	55.85	1.92	16.77	11.56	1.18	80196.56
7	9.84	13.14	60.52	1.61	18.14	11.36	1.18	80428.20
8	9.19	12.01	49.63	1.40	19.37	10.37	1.19	87396.95
9	11.12	12.24	49.81	1.70	18.20	10.75	1.20	85479.70
10	7.36	12.31	49.32	1.62	18.05	10.81	1.22	85159.68
11	11.88	12.75	54.72	1.72	17.34	11.07	1.22	83520.58
12	7.57	12.45	54.61	1.48	17.32	11.03	1.20	83309.10
13	8.84	12.38	59.35	1.30	18.44	10.83	1.21	84295.91
14	10.32	12.58	54.00	1.67	18.53	10.99	1.18	83257.79
15	6.87	12.60	53.10	1.19	18.27	11.04	1.19	83015.90
16	13.96	12.17	46.44	1.83	19.51	10.11	1.22	89346.28
17	8.68	12.71	47.81	1.98	17.28	10.96	1.23	84824.63
18	8.49	13.75	45.86	2.35	16.18	11.19	1.23	83871.50
19	5.65	12.94	57.73	2.86	17.12	11.42	1.21	81529.51
20	11.82	12.26	51.41	3.91	17.85	10.68	1.22	86774.11
21	14.14	13.16	47.58	5.55	16.44	10.99	1.20	85060.86
22	8.29	12.74	45.40	3.09	16.78	11.29	1.20	81369.62
23	5.69	13.09	46.69	2.77	16.93	11.57	1.20	79172.27
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.19	12.56	52.84	2.05	17.82	11.07	1.21	83349.52
最大值	14.14	13.75	68.42	5.55	19.51	11.69	1.25	89346.28
發生時間	21	18	3	21	16	3		16
最小值	5.65	11.49	45.40	1.19	16.18	10.11	1.18	78104.39
發生時間	19	0	22	15	18	16		3
零點偏移(率)	-0.06 %	-0.01 %	-0.07 %	0.00 %		0.00	-0.01	0.20 %
全幅偏移(率)	-0.81 %	-1.85 %	0.09 %	-0.16 %		0.00	0.10	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月12日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.42	13.13	55.98	0.66	17.81	11.50	0.99	78219.52
1	5.08	13.04	57.69	1.14	18.52	11.30	1.02	80333.97
2	1.61	14.23	56.65	1.19	17.59	12.15	1.02	74074.40
3	10.71	12.88	57.37	0.78	19.76	10.60	1.02	84982.35
4	2.51	13.41	47.48	0.92	19.99	10.46	1.02	85365.72
5	2.28	12.34	55.23	1.42	18.31	10.83	1.02	84276.43
6	2.27	11.53	65.18	1.15	18.89	10.74	1.02	90347.90
7	5.62	12.06	55.06	1.66	19.67	10.21	1.02	86888.23
8	7.91	11.91	55.42	1.04	19.73	10.33	1.01	86547.69
9	1.60	11.95	55.06	1.05	19.32	10.43	0.99	85735.30
10	5.99	12.62	59.92	1.44	16.52	11.37	0.98	79979.83
11	2.35	12.85	57.84	1.27	17.49	11.43	1.00	80069.75
12	1.81	12.24	51.42	0.63	19.61	10.64	0.99	83946.37
13	4.34	12.46	53.45	1.10	19.35	10.36	0.99	86248.04
14	7.93	12.25	58.63	1.47	18.22	10.77	1.00	83678.97
15	5.10	12.98	57.90	1.16	18.02	11.35	0.99	79458.05
16	1.41	12.47	55.18	0.93	18.61	10.94	0.97	82827.02
17	6.84	12.62	50.78	1.53	18.50	10.70	0.97	84841.67
18	1.40	11.82	62.95	1.52	18.41	10.42	0.99	86986.34
19	7.61	12.23	57.52	1.28	18.16	10.55	0.98	85892.20
20	7.92	12.64	58.84	2.14	15.97	11.32	0.97	81799.77
21	10.41	13.61	65.24	2.84	16.04	11.39	0.96	81299.82
22	7.51	12.39	54.48	1.71	17.74	10.71	0.97	85405.78
23	10.96	12.88	57.12	1.26	18.12	11.18	0.97	80785.06
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.48	12.61	56.77	1.30	18.35	10.90	0.99	83332.92
最大值	10.96	14.23	65.24	2.84	19.99	12.15	1.02	90347.90
發生時間	23	2	21	21	4	2		6
最小值	1.40	11.53	47.48	0.63	15.97	10.21	0.94	74074.40
發生時間	18	6	4	12	20	7		2
零點偏移(率)	-0.01 %	-0.08 %	-0.05 %	-0.00 %		0.01	-0.01	-0.20 %
全幅偏移(率)	0.14 %	0.14 %	0.14 %	0.14 %		0.09	0.00	-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月12日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.78	12.30	52.03	2.82	19.39	9.26	1.34	74731.84
1	7.42	12.27	54.28	2.74	21.22	8.94	1.34	76199.81
2	9.46	11.86	55.57	3.42	20.40	8.92	1.34	74985.11
3	7.86	12.07	52.53	2.78	20.51	8.46	1.31	74881.00
4	9.76	12.60	45.44	2.97	20.07	9.09	1.31	75773.18
5	3.00	11.85	51.03	2.48	19.79	9.08	1.33	75662.76
6	3.08	12.67	58.33	2.52	20.30	9.31	1.36	73149.29
7	3.54	11.51	43.82	2.42	19.63	9.17	1.36	76065.17
8	3.03	10.92	53.92	1.36	19.21	9.39	1.37	75917.33
9	2.91	10.75	52.26	1.26	19.06	9.17	1.38	75115.53
10	3.28	10.62	43.98	1.17	19.83	8.81	1.36	75539.58
11	2.91	11.35	51.54	1.24	18.44	9.06	1.32	74754.53
12	6.94	11.69	51.22	1.29	18.00	9.23	1.31	73722.40
13	3.99	13.20	58.56	1.80	20.22	9.29	1.35	73759.79
14	8.95	11.72	49.20	1.46	19.78	9.12	1.34	76067.07
15	5.88	11.64	46.71	1.48	20.54	8.88	1.31	75396.44
16	6.59	11.98	43.45	1.47	19.03	8.78	1.33	76317.13
17	10.65	11.84	56.94	1.68	16.61	9.66	1.35	75624.00
18	7.98	11.86	56.04	1.45	16.96	9.59	1.36	76663.49
19	14.64	11.62	57.42	3.76	18.81	9.71	1.35	77469.42
20	2.71	11.02	50.85	2.28	17.79	9.30	1.32	76374.60
21	11.62	10.99	59.73	2.85	17.71	9.36	1.31	75237.02
22	11.06	10.89	56.69	3.12	19.67	8.99	1.32	76747.57
23	3.92	14.24	36.39	2.74	21.18	8.04	1.32	72586.62
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.62	11.81	51.58	2.19	19.34	9.11	1.34	75364.20
最大值	14.64	14.24	59.73	3.76	21.22	9.71	1.39	77469.42
發生時間	19	23	21	19	1	19		19
最小值	2.71	10.62	36.39	1.17	16.61	8.04	1.31	72586.62
發生時間	20	10	23	10	17	23		23
零點偏移(率)	-0.05 %	0.00 %	-0.02 %	-0.00 %		-0.02	-0.01	0.00 %
全幅偏移(率)	1.52 %	-0.52 %	1.72 %	0.40 %		0.37	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								