

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 113年05月08日

| 項目<br>單位<br>小時\限標 | #1-HCl_C | #1-CO_C  | #1-NOx_C | #1-SO2_C | #1-H2O   | #1-O2_C  | #1-OPAC  | #1-FLOW_C |
|-------------------|----------|----------|----------|----------|----------|----------|----------|-----------|
|                   | ppm      | ppm      | ppm      | ppm      | %        | %        | %        | m3/Hour   |
|                   | 60.00    | 150.00   | 220.00   | 150.00   | 100.00   | 25.00    | 10.00    | 999999.00 |
| 0                 | 6.21     | 7.42     | 50.41    | 0.23     | 19.02    | 11.14    | 1.01     | 84407.37  |
| 1                 | 7.19     | 6.21     | 38.33    | 1.29     | 17.47    | 11.61    | 1.02     | 81759.94  |
| 2                 | 8.47     | 0.78     | 47.23    | 1.10     | 18.54    | 11.21    | 1.02     | 84674.93  |
| 3                 | 8.97     | 4.16     | 46.49    | 0.59     | 18.19    | 11.31    | 1.02     | 84193.72  |
| 4                 | 10.95    | 9.46     | 45.18    | 1.16     | 17.86    | 11.02    | 1.01     | 86818.17  |
| 5                 | 8.76     | 5.88     | 51.75    | 0.54     | 17.37    | 11.89    | 1.02     | 83134.77  |
| 6                 | 9.69     | 4.94     | 48.13    | 1.16     | 15.93    | 11.55    | 1.02     | 84386.31  |
| 7                 | 9.98     | 4.64     | 49.65    | 0.95     | 17.93    | 11.27    | 1.02     | 84812.22  |
| 8                 | 8.53     | 4.37     | 49.33    | 1.05     | 16.90    | 11.57    | 1.02     | 83434.57  |
| 9                 | 5.95     | 5.21     | 57.04    | 0.53     | 17.43    | 11.72    | 1.02     | 81182.71  |
| 10                | 5.47     | 5.70     | 62.79    | 0.50     | 17.65    | 12.26    | 1.02     | 76361.74  |
| 11                | 6.68     | 4.80     | 51.16    | 0.75     | 16.80    | 11.95    | 0.99     | 79794.69  |
| 12                | 11.16    | 5.05     | 46.36    | 1.30     | 16.23    | 11.82    | 0.98     | 82463.43  |
| 13                | 10.17    | 5.23     | 51.65    | 1.09     | 16.00    | 12.04    | 1.00     | 80193.32  |
| 14                | 12.93    | 8.22     | 43.89    | 2.31     | 14.37    | 12.26    | 0.99     | 80264.77  |
| 15                | 9.60     | 6.07     | 62.16    | 1.22     | 15.45    | 12.58    | 1.01     | 75586.07  |
| 16                | 8.26     | 5.07     | 62.16    | 0.40     | 16.82    | 11.46    | 1.05     | 84605.89  |
| 17                | 6.65     | 5.17     | 47.35    | 0.87     | 16.81    | 11.25    | 1.04     | 86205.38  |
| 18                | 9.02     | 4.63     | 40.67    | 1.09     | 16.04    | 11.46    | 1.02     | 85040.92  |
| 19                | 8.87     | 5.70     | 43.54    | 1.58     | 14.56    | 11.63    | 1.03     | 85252.65  |
| 20                | 7.58     | 4.89     | 56.35    | 0.86     | 16.38    | 11.32    | 1.04     | 86140.17  |
| 21                | 4.82     | 5.14     | 59.02    | 0.40     | 17.52    | 11.04    | 1.04     | 87531.97  |
| 22                | 8.85     | 7.90     | 45.80    | 0.64     | 16.72    | 11.00    | 1.02     | 88178.60  |
| 23                | 6.67     | 6.95     | 61.59    | 1.31     | 15.61    | 11.93    | 1.02     | 81381.79  |
| 監測時數              | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 超限次數              | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0         |
| 有效時數              | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 平 均 值             | 8.39     | 5.57     | 50.75    | 0.95     | 16.82    | 11.60    | 1.02     | 83241.92  |
| 最 大 值             | 12.93    | 9.46     | 62.79    | 2.31     | 19.02    | 12.58    | 1.09     | 88178.60  |
| 發生時間              | 14       | 4        | 10       | 14       | 0        | 15       |          | 22        |
| 最 小 值             | 4.82     | 0.78     | 38.33    | 0.23     | 14.37    | 11.00    | 0.97     | 75586.07  |
| 發生時間              | 21       | 2        | 1        | 0        | 14       | 22       |          | 15        |
| 零點偏移(率)           | -0.05 %  | -0.04 %  | -0.05 %  | -0.00 %  |          | -0.10    |          | 0.10 %    |
| 全幅偏移(率)           | 0.00 %   | 1.20 %   | -0.02 %  | 0.14 %   |          | 0.24     |          | 0.10 %    |
| 有效比率              | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 %  |
| 備註                |          |          |          |          |          |          |          |           |

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 113年05月08日

| 項目<br>單位<br>小時\限標 | #2-HCl_C | #2-CO_C  | #2-NOx_C | #2-SO2_C | #2-H2O   | #2-O2_C  | #2-OPAC  | #2-FLOW_C |
|-------------------|----------|----------|----------|----------|----------|----------|----------|-----------|
|                   | ppm      | ppm      | ppm      | ppm      | %        | %        | %        | m3/Hour   |
|                   | 60.00    | 150.00   | 220.00   | 150.00   | 100.00   | 25.00    | 10.00    | 999999.00 |
| 0                 | 9.43     | 6.37     | 56.75    | 2.33     | 16.26    | 11.13    | 1.02     | 80866.44  |
| 1                 | 10.05    | 5.71     | 61.23    | 2.45     | 17.04    | 11.52    | 1.02     | 77591.28  |
| 2                 | 6.02     | 3.56     | 50.02    | 3.57     | 15.44    | 11.66    | 1.02     | 77600.49  |
| 3                 | 3.17     | 2.31     | 49.91    | 1.63     | 17.51    | 11.34    | 1.02     | 78578.52  |
| 4                 | 7.52     | 3.98     | 39.04    | 2.51     | 16.87    | 10.96    | 1.02     | 82354.12  |
| 5                 | 5.91     | 10.26    | 51.03    | 3.25     | 14.44    | 11.56    | 1.02     | 79102.30  |
| 6                 | 7.75     | 14.93    | 48.80    | 2.93     | 18.13    | 10.21    | 1.04     | 79610.93  |
| 7                 | 8.68     | 4.10     | 47.54    | 2.92     | 15.41    | 11.24    | 1.04     | 80655.35  |
| 8                 | 9.41     | 2.33     | 51.32    | 1.96     | 17.79    | 10.66    | 1.05     | 83372.69  |
| 9                 | 8.90     | 3.27     | 52.41    | 2.02     | 16.47    | 11.34    | 1.06     | 78783.64  |
| 10                | 6.58     | 2.67     | 44.22    | 1.66     | 16.99    | 10.85    | 1.07     | 80177.97  |
| 11                | 6.89     | 3.48     | 46.60    | 2.79     | 15.34    | 11.22    | 1.09     | 78483.61  |
| 12                | 9.03     | 3.47     | 62.93    | 2.22     | 15.89    | 11.60    | 1.08     | 76189.28  |
| 13                | 4.19     | 3.46     | 54.48    | 1.79     | 16.09    | 12.34    | 1.09     | 71359.85  |
| 14                | 3.60     | 5.31     | 54.58    | 1.41     | 17.33    | 11.25    | 1.08     | 78060.00  |
| 15                | 10.14    | 6.35     | 44.90    | 2.58     | 15.96    | 11.07    | 1.07     | 81951.37  |
| 16                | 5.84     | 4.55     | 52.41    | 2.41     | 14.72    | 11.49    | 1.06     | 79419.77  |
| 17                | 5.95     | 6.85     | 52.22    | 2.55     | 13.99    | 11.18    | 1.07     | 82383.28  |
| 18                | 10.15    | 3.71     | 52.07    | 2.17     | 15.95    | 10.95    | 1.05     | 83363.37  |
| 19                | 5.76     | 4.90     | 64.29    | 1.18     | 17.82    | 11.38    | 1.04     | 77577.25  |
| 20                | 7.35     | 2.65     | 52.97    | 1.07     | 19.96    | 9.94     | 1.05     | 87239.89  |
| 21                | 6.03     | 4.44     | 60.86    | 0.61     | 20.15    | 10.44    | 1.05     | 82813.90  |
| 22                | 5.87     | 5.94     | 46.08    | 1.51     | 18.79    | 9.99     | 1.06     | 87780.16  |
| 23                | 5.21     | 6.07     | 53.48    | 2.91     | 14.39    | 11.69    | 1.06     | 79177.19  |
| 監測時數              | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 超限次數              | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0         |
| 有效時數              | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 平 均 值             | 7.06     | 5.03     | 52.09    | 2.18     | 16.61    | 11.13    | 1.05     | 80187.19  |
| 最 大 值             | 10.15    | 14.93    | 64.29    | 3.57     | 20.15    | 12.34    | 1.10     | 87780.16  |
| 發生時間              | 18       | 6        | 19       | 2        | 21       | 13       |          | 22        |
| 最 小 值             | 3.17     | 2.31     | 39.04    | 0.61     | 13.99    | 9.94     | 1.02     | 71359.85  |
| 發生時間              | 3        | 3        | 4        | 21       | 17       | 20       |          | 13        |
| 零點偏移(率)           | -0.01 %  | -0.04 %  | -0.02 %  | -0.02 %  |          | -0.05    |          | -0.10 %   |
| 全幅偏移(率)           | 0.14 %   | 0.09 %   | 0.29 %   | 0.13 %   |          | 0.19     |          | 0.00 %    |
| 有效比率              | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 %  |
| 備註                |          |          |          |          |          |          |          |           |

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年05月08日

| 項目<br>單位<br>小時\限標 | #3-HCl_C<br>ppm | #3-CO_C<br>ppm | #3-NOx_C<br>ppm | #3-SO2_C<br>ppm | #3-H2O<br>% | #3-O2_C<br>% | #3-OPAC<br>% | #3-FLOW_C<br>m3/Hour |
|-------------------|-----------------|----------------|-----------------|-----------------|-------------|--------------|--------------|----------------------|
| 0                 | 1.46            | 6.22           | 65.01           | 0.65            | 17.56       | 10.65        | 1.01         | 80904.96             |
| 1                 | 1.92            | 7.43           | 57.39           | 0.94            | 17.33       | 10.47        | 1.01         | 82236.99             |
| 2                 | 0.80            | 1.93           | 60.53           | 1.55            | 14.72       | 11.37        | 0.99         | 75549.64             |
| 3                 | 1.40            | 1.72           | 60.60           | 1.25            | 15.46       | 10.94        | 0.99         | 76785.57             |
| 4                 | 2.50            | 3.33           | 54.98           | 0.97            | 16.21       | 10.70        | 0.99         | 77347.76             |
| 5                 | 4.70            | 2.06           | 58.07           | 1.50            | 16.06       | 10.41        | 0.99         | 81315.49             |
| 6                 | 4.95            | 5.36           | 52.73           | 1.19            | 17.17       | 9.81         | 0.99         | 82530.33             |
| 7                 | 3.50            | 4.45           | 47.71           | 0.88            | 18.65       | 9.44         | 1.01         | 80324.78             |
| 8                 | 2.74            | 4.07           | 49.71           | 0.76            | 17.06       | 10.23        | 1.01         | 81057.14             |
| 9                 | 2.99            | 4.16           | 51.43           | 0.77            | 18.51       | 9.72         | 1.03         | 82000.34             |
| 10                | 0.76            | 1.66           | 49.34           | 0.55            | 18.29       | 9.80         | 1.01         | 81908.35             |
| 11                | 2.31            | 3.21           | 53.49           | 0.82            | 16.68       | 10.69        | 1.00         | 76503.24             |
| 12                | 1.29            | 3.24           | 57.84           | 0.55            | 18.68       | 10.00        | 0.99         | 80491.66             |
| 13                | 1.41            | 3.20           | 50.88           | 0.73            | 18.84       | 10.38        | 0.99         | 78498.85             |
| 14                | 3.50            | 3.25           | 49.36           | 0.94            | 18.20       | 10.26        | 1.00         | 81836.21             |
| 15                | 7.16            | 3.94           | 52.83           | 1.37            | 16.51       | 10.33        | 1.01         | 81960.75             |
| 16                | 7.02            | 4.11           | 59.92           | 1.09            | 18.23       | 9.94         | 1.03         | 83770.66             |
| 17                | 5.71            | 4.52           | 48.81           | 1.00            | 16.61       | 10.12        | 0.99         | 81559.25             |
| 18                | 4.35            | 7.14           | 62.07           | 0.82            | 17.98       | 10.22        | 1.02         | 81676.57             |
| 19                | 1.20            | 5.83           | 62.25           | 0.64            | 18.25       | 10.10        | 1.01         | 84349.88             |
| 20                | 0.93            | 3.78           | 58.01           | 0.64            | 18.63       | 9.83         | 1.01         | 86178.40             |
| 21                | 1.11            | 4.06           | 56.81           | 0.68            | 19.07       | 9.70         | 1.03         | 86270.46             |
| 22                | 1.69            | 4.19           | 38.40           | 0.81            | 17.67       | 8.90         | 0.99         | 82759.89             |
| 23                | 0.62            | 2.48           | 63.47           | 1.33            | 14.87       | 10.66        | 0.99         | 75651.62             |
| 監測時數              | 24              | 24             | 24              | 24              | 24          | 24           | 24           | 24                   |
| 超限次數              | 0               | 0              | 0               | 0               | 0           | 0            | 0            | 0                    |
| 有效時數              | 24              | 24             | 24              | 24              | 24          | 24           | 24           | 24                   |
| 平 均 值             | 2.75            | 3.97           | 55.07           | 0.93            | 17.39       | 10.19        | 1.00         | 80977.87             |
| 最 大 值             | 7.16            | 7.43           | 65.01           | 1.55            | 19.07       | 11.37        | 1.04         | 86270.46             |
| 發生時間              | 15              | 1              | 0               | 2               | 21          | 2            |              | 21                   |
| 最 小 值             | 0.62            | 1.66           | 38.40           | 0.55            | 14.72       | 8.90         | 0.97         | 75549.64             |
| 發生時間              | 23              | 10             | 22              | 10              | 2           | 22           |              | 2                    |
| 零點偏移(率)           | -0.03 %         | -0.03 %        | -0.06 %         | -0.01 %         |             | -0.04        |              | 0.20 %               |
| 全幅偏移(率)           | 0.02 %          | 0.54 %         | -0.34 %         | 0.00 %          |             | 0.63         |              | 0.20 %               |
| 有效比率              | 100.00 %        | 100.00 %       | 100.00 %        | 100.00 %        | 100.00 %    | 100.00 %     | 100.00 %     | 100.00 %             |
| 備註                |                 |                |                 |                 |             |              |              |                      |