

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年04月10日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.46	3.54	47.64	3.45	14.39	12.27	1.48	69484.81
1	6.43	4.09	45.10	3.90	14.16	12.53	1.47	68054.58
2	7.07	3.84	51.33	4.63	12.88	12.57	1.48	68381.44
3	8.63	3.17	50.96	3.99	14.19	12.28	1.47	70400.18
4	8.06	4.22	43.19	5.04	12.29	12.84	1.46	67315.59
5	0.19	4.15	67.63	4.00	13.47	13.28	1.44	67033.72
6	0.13	3.39	55.12	3.61	13.79	12.74	1.43	67704.96
7	4.13	3.21	47.19	3.98	13.78	12.40	1.41	69492.16
8	7.12	2.98	64.79	3.18	15.59	11.85	1.45	72241.99
9	9.60	4.24	49.78	4.58	13.19	12.35	1.42	70420.62
10	9.27	4.65	56.28	4.47	14.03	12.55	1.42	67864.04
11	5.21	3.14	61.39	3.60	14.32	12.40	1.43	68736.16
12	2.53	3.38	50.79	3.69	14.03	12.53	1.41	68015.72
13	1.24	3.96	53.12	3.94	13.86	12.97	1.42	64668.75
14	1.76	4.61	58.84	3.34	14.74	12.51	1.41	67376.18
15	1.14	3.37	52.92	3.30	14.44	12.31	1.41	69531.10
16	6.73	3.73	49.28	4.12	13.82	12.42	1.40	68886.40
17	9.98	4.30	63.15	3.31	16.13	12.12	1.40	69693.44
18	5.71	3.81	51.00	2.73	16.62	12.25	1.40	67956.84
19	5.75	5.12	56.93	2.67	16.68	12.08	1.40	69565.78
20	1.54	3.54	60.62	2.19	17.00	11.70	1.43	71740.15
21	4.33	6.18	44.52	3.01	15.46	12.07	1.44	69968.52
22	7.84	6.42	52.01	3.40	15.00	12.08	1.43	70886.92
23	3.05	3.56	61.38	2.61	16.06	12.06	1.41	69979.39
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.20	4.03	53.96	3.61	14.58	12.38	1.43	68974.98
最大值	9.98	6.42	67.63	5.04	17.00	13.28	1.49	72241.99
發生時間	17	22	5	4	20	5		8
最小值	0.13	2.98	43.19	2.19	12.29	11.70	1.38	64668.75
發生時間	6	8	4	20	4	20		13
零點偏移(率)	-0.01 %	-0.03 %	-0.01 %	-0.00 %		0.00	0.00	0.00 %
全幅偏移(率)	1.54 %	0.06 %	-0.51 %	0.08 %		0.24	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年04月10日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.14	4.04	32.39	3.33	18.45	9.64	1.39	81350.72
1	8.49	5.84	29.07	3.29	19.06	9.80	1.38	79374.36
2	10.38	4.63	29.62	4.68	17.15	9.61	1.40	82212.74
3	12.65	7.69	40.05	7.45	14.36	9.98	1.42	81518.62
4	13.31	6.58	55.03	8.08	14.96	10.43	1.44	78365.46
5	10.38	4.14	34.41	3.70	18.53	9.62	1.44	82621.36
6	8.16	6.62	43.54	3.17	16.39	10.15	1.43	83387.62
7	11.06	7.11	41.45	3.51	17.07	10.03	1.43	82245.37
8	7.18	2.02	34.83	2.72	18.37	9.82	1.40	79790.99
9	9.21	1.80	47.96	2.52	18.91	10.04	1.39	83886.27
10	9.01	1.89	46.28	2.41	18.94	10.05	1.40	86030.53
11	6.36	1.38	57.03	2.33	17.45	11.12	1.37	78590.09
12	7.59	1.27	42.15	2.64	18.03	10.65	1.39	80149.14
13	5.17	1.41	46.40	1.99	18.17	10.51	1.41	78247.83
14	0.10	1.52	36.76	1.30	18.86	10.08	1.39	81728.82
15	2.74	1.45	44.26	2.22	17.21	10.78	1.38	82293.73
16	10.04	2.62	45.03	3.84	17.21	10.49	1.38	77687.17
17	8.03	1.20	48.94	2.65	18.32	10.57	1.37	76481.69
18	2.44	1.30	42.41	1.78	17.55	10.63	1.36	78211.54
19	0.85	2.00	42.66	1.77	17.53	10.18	1.37	82562.18
20	2.11	1.23	44.98	1.65	18.27	10.25	1.38	83701.75
21	7.66	1.37	44.84	2.42	17.56	10.45	1.41	83434.54
22	8.74	1.30	53.65	2.36	17.33	10.80	1.41	81475.48
23	9.17	2.00	45.29	2.10	17.85	10.33	1.39	81983.28
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.50	3.02	42.88	3.08	17.65	10.25	1.40	81138.80
最大值	13.31	7.69	57.03	8.08	19.06	11.12	1.45	86030.53
發生時間	4	3	11	4	1	11		10
最小值	0.10	1.20	29.07	1.30	14.36	9.61	1.36	76481.69
發生時間	14	17	1	14	3	2		17
零點偏移(率)	-0.02 %	-0.07 %	0.00 %	0.00 %		0.00	0.00	0.00 %
全幅偏移(率)	0.03 %	-0.09 %	-0.44 %	0.00 %		0.07	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年04月10日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.38	1.89	53.32	2.00	17.43	10.64	1.43	85012.75
1	8.39	3.31	55.75	2.18	16.42	11.07	1.43	81821.99
2	8.59	4.92	53.86	3.04	14.64	11.25	1.43	80197.32
3	9.49	3.04	52.91	3.20	14.62	11.12	1.42	80775.85
4	10.18	4.73	47.96	3.58	14.75	10.62	1.41	82709.76
5	8.96	2.08	52.11	2.54	15.80	10.84	1.42	81193.60
6	7.05	2.46	50.76	1.84	16.03	10.81	1.41	81312.80
7	9.05	4.44	51.32	3.09	14.24	11.29	1.42	85198.64
8	10.74	5.40	54.42	2.68	15.91	10.68	1.45	84780.88
9	9.61	6.37	49.48	2.24	17.16	10.32	1.45	85230.60
10	10.29	10.69	50.74	2.83	16.39	10.91	1.44	81769.57
11	5.51	14.84	42.43	1.98	15.68	11.35	1.44	76967.28
12	3.30	18.11	43.20	1.60	17.30	11.01	1.44	77414.14
13	1.94	19.38	36.16	1.44	17.16	11.04	1.43	75646.64
14	0.81	14.79	37.56	3.28	16.31	11.14	1.44	79336.65
15	2.64	19.00	51.69	1.92	15.60	11.44	1.44	77622.93
16	1.52	3.69	48.47	1.48	16.38	10.44	1.43	81544.52
17	1.51	4.12	49.51	1.36	16.95	10.27	1.43	82360.28
18	0.81	3.48	54.07	1.38	16.15	10.65	1.43	82634.70
19	3.20	5.33	57.25	1.44	17.27	10.57	1.44	85716.69
20	3.75	7.50	52.79	1.68	16.32	10.63	1.45	84828.45
21	5.53	10.17	59.00	2.10	15.61	10.92	1.44	82148.17
22	9.16	2.28	58.59	1.88	16.12	11.06	1.44	83956.81
23	4.47	1.88	56.86	1.55	15.97	11.05	1.43	83633.78
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.04	7.25	50.84	2.18	16.09	10.88	1.43	81825.62
最大值	10.74	19.38	59.00	3.58	17.43	11.44	1.49	85716.69
發生時間	8	13	21	4	0	15		19
最小值	0.81	1.88	36.16	1.36	14.24	10.27	1.40	75646.64
發生時間	14	23	13	17	7	17		13
零點偏移(率)	-0.01 %	-0.04 %	-0.02 %	-0.02 %		0.00	0.00	0.00 %
全幅偏移(率)	1.92 %	0.47 %	-0.47 %	0.24 %		0.30	-0.03	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								