

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 115年07月25日

[illegible]

P002 樹林焚化廠CEMS系統日報表-A 報表日期: 115年07月25日

報表日期: 115年07月25日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.52	12.54	52.17	1.77	17.73	10.90	0.94	82615.95
1	9.64	12.16	58.85	1.29	19.02	10.65	0.94	84762.88
2	12.23	12.24	51.50	2.07	18.74	10.73	0.94	84115.82
3	11.66	12.31	57.98	2.40	17.88	10.91	0.94	83690.10
4	9.71	13.22	45.83	3.08	16.00	11.28	0.94	81887.49
5	8.01	12.03	61.29	1.64	16.41	11.39	0.94	80143.09
6	10.75	12.72	47.17	3.09	17.12	11.38	0.93	80638.35
7	3.22	13.58	46.57	1.99	18.62	11.04	0.92	80868.27
8	4.92	12.41	47.50	1.53	20.74	10.22	0.93	85608.52
9	8.18	11.67	58.62	1.79	19.78	10.23	0.94	85695.45
10	5.45	12.12	47.73	1.29	20.50	10.14	0.94	85939.27
11	5.08	12.08	35.80	1.24	18.65	10.74	0.94	82344.39
12	10.00	12.75	54.79	1.61	17.85	11.29	0.92	79094.82
13	10.20	12.20	51.42	1.72	18.79	10.73	0.92	82912.63
14	11.69	12.14	52.85	2.58	18.05	10.70	0.92	83552.04
15	8.71	12.66	58.06	1.58	19.16	10.43	0.94	85305.19
16	11.18	12.78	39.23	2.35	17.51	10.82	0.92	83646.98
17	9.59	13.70	60.04	1.72	18.57	10.94	0.92	81276.18
18	9.85	13.50	49.67	1.10	19.03	10.62	0.92	83700.33
19	8.56	13.58	43.23	1.44	17.62	10.80	0.93	83334.41
20	11.26	12.35	57.96	0.93	19.00	10.76	0.92	82140.75
21	8.59	12.34	42.64	1.21	18.47	10.72	0.92	83160.59
22	9.21	13.33	53.61	1.02	18.51	11.26	0.94	79164.73
23	11.38	13.51	55.51	1.01	19.27	10.72	0.93	82752.51
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.19	12.66	51.25	1.73	18.46	10.81	0.93	82847.95
最 大 值	12.23	13.70	61.29	3.09	20.74	11.39	0.95	85939.27
發生時間	2	17	5	6	8	5		10
最 小 值	3.22	11.67	35.80	0.93	16.00	10.14	0.90	79094.82
發生時間	7	9	11	20	4	10		12
零點偏移(率)	-0.08 %	-0.02 %	-0.01 %	-0.02 %		-0.07	-0.01	-0.10 %
全幅偏移(率)	1.34 %	-0.19 %	1.44 %	0.65 %		-0.18	-0.06	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 115年07月25日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	6.59	11.59	54.47	2.29	18.93	10.08	1.30	78810.87
1	8.11	11.75	59.10	2.31	18.38	10.36	1.30	78309.43
2	2.49	11.87	57.78	2.06	19.75	10.19	1.30	79233.99
3	3.57	11.51	57.26	2.31	19.22	9.96	1.31	79748.76
4	3.73	11.53	55.11	2.34	17.27	10.08	1.28	79352.80
5	6.70	12.10	62.20	2.70	16.86	10.60	1.27	77017.76
6	2.49	11.58	62.79	2.22	18.99	10.14	1.27	78064.67
7	1.54	11.59	48.73	2.29	17.41	10.26	1.27	78408.39
8	6.13	11.68	53.12	2.42	19.26	10.25	1.31	80622.58
9	7.43	11.69	51.39	2.37	20.31	10.10	1.30	82929.25
10	7.27	12.07	53.25	2.49	19.51	10.58	1.27	80115.88
11	7.69	11.85	48.53	2.31	17.89	10.57	1.27	80179.07
12	8.22	11.89	52.79	2.28	17.88	10.63	1.29	79472.96
13	10.45	11.85	52.70	2.49	18.70	10.49	1.31	78751.59
14	7.74	11.78	49.75	2.29	17.73	10.53	1.29	78005.65
15	10.75	12.11	48.35	3.03	16.70	10.77	1.27	77004.32
16	2.96	12.66	52.88	2.17	18.47	11.09	1.28	74196.06
17	8.28	12.86	57.43	2.42	17.51	10.69	1.27	78918.35
18	8.21	13.51	56.95	2.15	17.71	10.42	1.27	80529.50
19	7.66	12.88	59.66	2.18	18.84	10.16	1.30	78912.90
20	3.52	11.97	63.19	2.24	19.54	10.28	1.30	79230.55
21	5.94	12.05	56.09	2.40	20.32	10.31	1.27	78216.47
22	3.23	12.35	56.56	2.39	19.99	10.25	1.26	79336.40
23	6.66	13.20	60.75	2.35	19.35	10.41	1.28	79723.65
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.14	12.08	55.45	2.35	18.61	10.38	1.28	78962.16
最 大 值	10.75	13.51	63.19	3.03	20.32	11.09	1.33	82929.25
發生時間	15	18	20	15	21	16		9
最 小 值	1.54	11.51	48.35	2.06	16.70	9.96	1.25	74196.06
發生時間	7	3	15	2	15	3		16
零點偏移(率)	-0.13 %	0.01 %	-0.03 %	0.00 %		-0.04	-0.01	0.10 %
全幅偏移(率)	0.66 %	-0.25 %	0.08 %	-0.60 %		0.17	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								