

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年04月06日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.77	4.02	62.69	2.85	16.75	12.42	1.47	67322.53
1	2.26	5.37	57.46	2.66	17.02	12.87	1.50	63279.19
2	1.19	4.50	59.15	2.15	17.84	11.92	1.51	70927.61
3	9.47	4.98	44.92	3.00	17.34	11.35	1.50	74935.42
4	10.56	6.41	48.32	3.55	15.93	11.92	1.51	71802.83
5	7.84	4.39	63.00	3.12	16.32	12.44	1.48	68711.10
6	6.36	3.60	64.01	2.31	17.65	11.96	1.48	70283.50
7	1.39	5.29	59.61	2.57	16.73	12.85	1.50	64759.49
8	0.12	15.45	84.37	3.28	15.74	13.71	1.66	58060.43
9	0.21	7.18	56.73	3.13	15.89	13.45	1.53	60086.56
10	0.21	9.91	63.46	2.82	17.08	13.24	1.56	60771.95
11	0.16	16.34	67.42	1.58	19.13	11.66	1.47	71759.98
12	3.74	15.33	50.62	1.74	18.44	10.87	1.49	77793.42
13	10.91	16.50	46.15	3.37	15.93	11.85	1.48	72678.22
14	9.48	29.08	64.92	0.80	16.10	12.37	1.47	68320.66
15	8.46	16.09	65.75	1.09	16.61	12.34	1.46	68140.50
16	10.23	15.06	48.69	1.67	16.05	12.30	1.44	68866.53
17	8.84	9.02	58.46	2.72	16.89	12.04	1.43	70471.67
18	10.05	3.37	53.18	3.05	16.99	11.66	1.43	72665.66
19	7.40	3.71	55.04	2.98	16.45	12.32	1.43	68080.02
20	2.38	3.86	65.36	2.34	17.38	12.33	1.45	67253.17
21	5.07	3.52	54.65	2.51	17.05	12.04	1.44	70392.46
22	6.09	3.44	58.40	2.42	17.45	11.79	1.43	71720.32
23	5.52	3.41	54.82	2.25	17.92	11.71	1.43	71804.36
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.57	8.74	58.63	2.50	16.94	12.23	1.48	68786.98
最大值	10.91	29.08	84.37	3.55	19.13	13.71	2.09	77793.42
發生時間	13	14	8	4	11	8		12
最小值	0.12	3.37	44.92	0.80	15.74	10.87	1.42	58060.43
發生時間	8	18	3	14	8	12		8
零點偏移(率)	0.00 %	-0.00 %	-0.00 %	0.00 %		-0.05	0.00	0.00 %
全幅偏移(率)	-0.23 %	0.27 %	-0.88 %	0.36 %		-0.05	-0.03	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年04月06日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.75	7.71	34.72	2.71	18.65	9.43	1.45	79520.05
1	5.72	7.12	35.23	2.06	19.71	10.11	1.46	81570.91
2	8.87	9.04	33.35	3.55	17.45	10.02	1.47	79911.79
3	9.96	6.25	32.79	4.38	19.18	9.06	1.49	84257.63
4	11.05	2.91	39.36	4.67	18.52	9.04	1.49	84402.77
5	8.41	2.78	27.95	3.21	17.70	9.52	1.49	78141.75
6	4.54	3.06	31.33	1.85	19.45	9.71	1.45	76891.33
7	4.21	2.83	42.02	1.23	21.46	9.59	1.44	81495.68
8	0.78	2.54	78.56	0.42	21.81	10.17	1.44	77048.28
9	0.10	1.92	55.32	0.48	20.89	10.47	1.43	77289.50
10	0.97	2.33	50.44	0.74	21.48	10.05	1.45	79938.96
11	4.01	2.61	41.30	1.61	19.88	9.59	1.48	83492.83
12	8.92	1.73	54.01	2.82	17.59	10.32	1.46	81591.51
13	9.68	2.45	49.84	2.65	16.60	10.94	1.44	80025.92
14	6.18	1.99	54.09	1.96	17.39	11.09	1.44	80567.60
15	6.72	2.03	63.67	1.77	18.37	10.92	1.47	81034.50
16	8.70	2.28	47.91	2.28	18.10	10.43	1.48	84757.28
17	6.37	2.89	52.84	2.02	17.90	10.61	1.46	82574.64
18	6.77	4.29	48.06	1.78	19.14	10.38	1.46	83291.30
19	3.43	7.47	50.09	0.86	21.77	9.25	1.46	89749.71
20	4.42	4.29	52.57	1.53	18.74	10.12	1.46	85898.99
21	5.12	4.37	53.53	1.65	18.68	10.31	1.46	84056.20
22	9.44	4.57	53.85	2.79	18.52	10.29	1.46	84579.21
23	6.45	4.29	52.81	1.45	20.33	10.00	1.46	85202.41
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.15	3.91	47.32	2.10	19.14	10.06	1.46	81970.45
最大值	11.05	9.04	78.56	4.67	21.81	11.09	1.50	89749.71
發生時間	4	2	8	4	8	14		19
最小值	0.10	1.73	27.95	0.42	16.60	9.04	1.43	76891.33
發生時間	9	12	5	8	13	4		6
零點偏移(率)	0.00 %	0.00 %	-0.07 %	-0.01 %		-0.14	0.00	0.00 %
全幅偏移(率)	-0.23 %	-0.00 %	-0.10 %	0.17 %		-0.10	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年04月06日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.88	5.39	54.35	1.99	16.12	11.02	1.38	79908.18
1	5.89	3.76	60.39	1.98	16.78	11.20	1.39	80103.71
2	9.67	8.60	49.24	3.13	15.62	10.42	1.39	79641.48
3	10.59	8.58	53.84	2.80	16.69	10.20	1.38	80633.98
4	9.48	5.79	45.15	2.73	16.99	9.98	1.38	78894.95
5	7.27	3.04	50.16	2.10	18.10	9.93	1.38	79300.29
6	8.34	5.15	48.25	2.15	18.14	9.92	1.38	80812.69
7	5.22	5.54	46.27	1.73	18.81	10.02	1.38	77977.32
8	5.53	1.30	73.16	1.96	18.87	10.37	1.38	85520.90
9	1.43	1.21	71.25	1.87	19.74	9.94	1.39	87390.35
10	3.96	4.43	47.85	1.75	19.58	9.22	1.39	90250.21
11	7.41	3.67	52.71	1.85	16.86	10.59	1.40	85000.07
12	4.97	1.78	57.78	1.83	16.59	10.82	1.41	84838.72
13	6.17	1.37	65.80	2.22	15.91	11.05	1.42	82969.62
14	2.87	1.35	61.90	2.02	15.93	10.92	1.40	80756.63
15	5.40	3.32	63.27	2.27	16.97	10.71	1.39	82060.16
16	5.39	1.56	56.69	1.98	16.97	10.57	1.39	83083.30
17	3.66	2.81	51.21	1.94	16.55	10.50	1.38	83904.70
18	10.15	9.57	60.65	2.24	17.04	10.70	1.39	83975.19
19	5.67	3.83	64.39	1.78	17.99	10.71	1.39	84956.18
20	2.87	4.10	53.90	1.61	18.19	10.31	1.39	87049.86
21	2.94	4.98	53.61	1.64	17.26	10.57	1.38	84698.46
22	4.37	5.02	51.72	1.89	17.51	10.24	1.38	86264.53
23	4.01	3.94	61.43	1.82	18.06	10.74	1.38	82141.84
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.84	4.17	56.46	2.05	17.39	10.44	1.39	83005.56
最大值	10.59	9.57	73.16	3.13	19.74	11.20	1.43	90250.21
發生時間	3	18	8	2	9	1		10
最小值	1.43	1.21	45.15	1.61	15.62	9.22	1.37	77977.32
發生時間	9	9	4	20	2	10		7
零點偏移(率)	-0.01 %	0.00 %	-0.00 %	-0.00 %		-0.29	0.00	0.00 %
全幅偏移(率)	-0.95 %	0.48 %	-1.13 %	1.01 %		0.04	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								