

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月04日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.16	11.89	64.85	1.11	17.46	12.11	1.10	74821.88
1	9.92	10.51	65.98	1.20	18.03	11.34	1.10	80882.25
2	8.93	12.30	53.13	1.85	15.96	11.77	1.08	79243.85
3	8.46	13.26	58.15	2.28	16.13	11.83	1.09	77983.31
4	9.21	11.10	55.44	1.37	17.44	11.63	1.09	79248.97
5	10.63	13.77	66.55	1.49	16.28	11.69	1.12	74097.84
6	8.81	10.12	52.37	1.28	16.16	11.98	1.12	76446.39
7	8.98	10.51	62.99	0.95	17.31	11.76	1.08	77967.20
8	8.01	14.22	52.86	1.22	16.87	11.81	1.17	77295.02
9	3.83	15.18	71.07	0.78	17.51	12.48	1.21	71037.59
10	6.01	8.38	55.27	0.63	18.87	10.87	1.12	80876.49
11	7.01	9.02	69.10	1.31	16.17	12.14	1.11	75611.59
12	8.53	4.90	52.73	1.15	18.14	11.40	1.11	80197.47
13	2.01	8.91	59.31	0.89	17.67	11.89	1.11	74958.63
14	0.68	11.51	42.64	1.43	20.75	9.10	1.07	78743.96
15	9.92	4.24	66.09	1.13	17.24	10.78	1.07	78342.53
16	9.18	15.41	45.45	2.08	15.54	11.93	1.07	73216.74
17	9.38	8.10	53.81	0.99	18.90	11.14	1.09	78893.83
18	8.06	8.96	50.22	0.63	19.57	10.61	1.10	79629.89
19	7.78	9.94	55.82	0.94	18.16	11.01	1.10	79136.77
20	7.49	9.85	56.04	0.90	18.85	11.07	1.10	79349.02
21	8.81	9.86	62.80	0.81	19.07	11.21	1.09	80607.82
22	8.60	9.98	52.35	0.63	19.08	11.13	1.07	81427.37
23	7.02	12.23	55.45	1.35	18.06	11.42	1.08	80317.78
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.73	10.59	57.52	1.18	17.72	11.42	1.10	77930.59
最大值	10.63	15.41	71.07	2.28	20.75	12.48	1.55	81427.37
發生時間	5	16	9	3	14	9		22
最小值	0.68	4.24	42.64	0.63	15.54	9.10	1.05	71037.59
發生時間	14	15	14	10	16	14		9
零點偏移(率)	-0.06 %	-0.05 %	-0.01 %	-0.00 %		-0.01		0.00 %
全幅偏移(率)	0.02 %	0.56 %	0.01 %	0.43 %		-0.30		0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月04日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.36	9.46	39.36	1.22	20.33	9.32	1.15	84657.63
1	9.66	7.76	38.51	1.66	20.67	9.26	1.15	85599.38
2	9.79	10.45	47.08	1.33	18.93	9.33	1.15	84964.28
3	10.18	8.46	49.70	2.29	16.76	9.80	1.15	81692.31
4	8.63	8.54	54.28	1.86	16.87	9.81	1.15	82385.78
5	9.10	7.41	57.33	1.89	17.07	9.88	1.15	81301.00
6	11.79	7.78	55.23	1.74	17.34	9.23	1.15	80504.35
7	9.37	8.55	62.02	1.61	16.54	9.60	1.15	83397.49
8	8.73	7.92	48.00	1.56	17.32	9.82	1.15	83341.71
9	11.30	7.72	52.68	1.14	18.50	9.29	1.16	88597.56
10	9.16	8.97	51.53	1.21	17.71	9.89	1.18	85822.54
11	9.06	7.37	49.78	1.59	16.43	10.51	1.16	82446.45
12	6.63	6.49	67.82	1.47	16.25	11.51	1.17	74208.34
13	9.61	9.51	57.06	0.95	17.80	10.65	1.18	80352.50
14	9.62	4.62	55.37	1.44	17.12	10.48	1.18	82556.91
15	8.42	5.52	50.51	1.05	17.45	10.58	1.18	80055.20
16	7.15	4.95	66.87	0.90	17.95	10.63	1.18	80544.50
17	9.04	9.64	54.47	0.73	19.12	9.95	1.17	84403.55
18	8.54	6.60	63.36	1.14	17.80	10.12	1.16	84785.26
19	8.39	5.98	57.99	1.04	18.05	10.24	1.16	83572.28
20	1.71	6.32	69.70	0.65	17.92	11.01	1.18	77711.16
21	1.76	9.81	44.34	1.08	18.64	10.03	1.17	84305.05
22	6.31	6.45	50.71	1.49	18.03	10.49	1.16	81502.15
23	7.84	10.20	51.05	1.35	18.56	10.21	1.17	83267.95
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.34	7.77	53.95	1.35	17.88	10.07	1.16	82582.31
最大值	11.79	10.45	69.70	2.29	20.67	11.51	1.18	88597.56
發生時間	6	2	20	3	1	12		9
最小值	1.71	4.62	38.51	0.65	16.25	9.23	1.15	74208.34
發生時間	20	14	1	20	12	6		12
零點偏移(率)	-0.04 %	-0.01 %	-0.02 %	-0.01 %		0.00		0.00 %
全幅偏移(率)	0.04 %	0.12 %	0.32 %	0.41 %		-0.41		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月04日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.89	11.27	64.15	1.45	15.30	10.82	1.01	72503.13
1	4.80	11.05	63.25	1.11	17.04	10.74	1.02	76267.69
2	10.54	12.23	45.29	1.30	16.00	10.56	1.02	81193.69
3	12.86	9.36	49.40	2.02	14.94	10.85	1.02	82879.09
4	7.10	13.42	52.04	2.21	14.32	11.00	1.02	76286.39
5	10.72	6.85	57.44	4.36	13.99	11.56	1.05	75740.64
6	3.44	9.94	61.09	1.67	14.72	11.15	1.04	75217.02
7	0.30	10.21	58.45	0.66	16.67	9.91	1.05	73307.37
8	3.81	4.99	59.77	1.24	15.22	10.33	1.05	80463.82
9	9.05	10.16	52.66	1.43	15.21	10.74	1.05	77102.93
10	1.37	6.22	62.32	0.77	16.00	10.67	1.03	79142.54
11	0.51	7.97	66.77	1.90	13.64	11.57	1.02	78037.94
12	1.67	13.71	62.66	1.83	13.66	12.42	1.03	68584.67
13	15.24	5.48	49.97	1.99	14.45	11.94	1.05	80499.42
14	0.75	3.19	58.62	0.92	15.49	12.13	1.05	77614.46
15	0.87	9.03	59.62	0.66	16.05	11.17	1.06	81386.17
16	0.48	3.15	56.30	0.59	17.00	11.05	1.05	83137.73
17	0.62	5.01	57.07	0.85	15.81	11.32	1.04	83202.48
18	1.04	12.33	61.31	1.17	15.22	11.40	1.02	80862.93
19	1.27	1.22	57.61	0.49	17.49	10.74	1.02	85304.86
20	0.82	1.88	54.54	0.58	17.07	11.00	1.01	84248.91
21	0.62	9.22	51.79	0.75	16.24	11.09	1.03	81705.20
22	0.66	8.24	54.58	0.65	17.25	10.88	1.05	83205.06
23	0.71	11.41	54.15	0.71	16.84	10.79	1.05	82280.88
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	3.84	8.23	57.12	1.30	15.65	11.08	1.03	79173.96
最大值	15.24	13.71	66.77	4.36	17.49	12.42	1.08	85304.86
發生時間	13	12	11	5	19	12		19
最小值	0.30	1.22	45.29	0.49	13.64	9.91	0.99	68584.67
發生時間	7	19	2	19	11	7		12
零點偏移(率)	-0.12 %	-0.04 %	-0.06 %	-0.02 %		0.00		0.00 %
全幅偏移(率)	0.00 %	0.69 %	-0.69 %	0.51 %		0.00		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								