

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 113年08月17日

[illegible]

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 113年08月17日

項目 單位 小時\限標	#2-HCl_C ppm	#2-CO_C ppm	#2-NOx_C ppm	#2-SO2_C ppm	#2-H2O %	#2-O2_C %	#2-OPAC %	#2-FLOW_C m3/Hour
0	8.53	3.78	40.07	1.54	19.22	10.30	1.06	84567.68
1	9.96	5.32	44.17	3.14	16.66	11.16	1.06	80339.61
2	11.13	1.51	45.55	2.29	17.28	11.10	1.08	81327.64
3	10.04	1.53	40.42	1.35	18.94	10.84	1.08	82175.51
4	5.71	1.56	39.47	1.49	18.34	10.86	1.09	81709.14
5	8.21	5.38	50.34	1.85	18.59	10.67	1.09	82614.91
6	9.18	2.94	41.58	0.50	20.27	10.46	1.07	80801.11
7	8.58	2.09	41.64	1.23	18.98	10.25	1.07	85659.60
8	8.64	2.44	41.08	1.99	17.89	10.67	1.06	83535.35
9	7.64	2.49	44.66	1.60	18.46	10.85	1.06	81591.14
10	8.43	3.93	40.91	1.41	19.08	10.33	1.06	84779.07
11	9.71	8.22	40.47	1.55	18.84	10.42	1.06	84076.55
12	6.66	4.57	40.90	1.49	17.99	10.59	1.07	83666.31
13	6.92	3.95	46.16	1.95	16.86	10.85	1.06	82943.95
14	8.26	2.81	55.20	1.25	18.11	10.54	1.07	83910.81
15	9.88	3.54	51.19	1.31	18.26	10.73	1.06	82273.68
16	8.38	2.54	40.22	0.75	20.18	10.17	1.06	84919.05
17	6.20	4.14	38.13	1.30	18.56	10.50	1.06	83934.86
18	3.35	3.96	45.61	1.55	18.17	10.73	1.06	82401.92
19	2.81	2.61	54.39	1.73	17.64	10.71	1.06	82887.14
20	0.10	2.79	46.99	1.73	16.38	11.15	1.06	80517.32
21	0.11	2.65	51.21	1.62	17.03	10.90	1.06	81922.14
22	0.11	2.62	58.52	1.70	17.47	11.49	1.06	76915.48
23	2.35	3.51	47.66	1.25	17.74	10.94	1.06	81349.75
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.70	3.37	45.27	1.57	18.21	10.72	1.07	82534.15
最 大 值	11.13	8.22	58.52	3.14	20.27	11.49	1.10	85659.60
發生時間	2	11	22	1	6	22		7
最 小 值	0.10	1.51	38.13	0.50	16.38	10.17	1.05	76915.48
發生時間	20	2	17	6	20	16		22
零點偏移(率)	0.00 %	-0.01 %	-0.02 %	-0.10 %		-0.15		-0.10 %
全幅偏移(率)	0.13 %	0.49 %	-1.12 %	0.15 %		-0.12		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

