

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年05月30日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.73	13.52	57.12	1.99	16.18	11.37	1.23	81988.46
1	6.58	12.40	55.44	2.24	15.19	12.03	1.23	77151.00
2	11.34	12.06	55.68	2.94	15.39	11.87	1.23	78855.22
3	7.76	11.47	67.02	2.11	16.28	11.37	1.23	82211.56
4	11.08	11.59	48.69	3.05	14.48	11.67	1.23	81255.01
5	2.31	12.00	56.25	1.79	13.72	12.03	1.22	87577.71
6	12.87	13.40	57.75	2.42	14.65	11.71	1.23	80845.25
7	7.59	12.94	57.62	2.38	14.93	11.53	1.22	81652.08
8	11.22	12.97	62.70	2.67	14.86	11.61	1.21	81251.06
9	7.26	12.85	55.85	3.38	14.64	11.53	1.24	82057.81
10	14.18	12.14	55.89	4.28	13.88	11.48	1.23	82728.36
11	8.90	13.09	55.98	2.49	14.23	11.83	1.20	79286.26
12	8.87	12.92	65.95	1.72	15.96	11.49	1.22	80846.83
13	4.11	12.67	60.66	1.77	15.93	11.36	1.23	81823.33
14	13.27	12.60	66.58	2.26	16.77	11.17	1.21	82845.97
15	8.14	12.68	63.90	3.32	15.81	11.70	1.20	79403.32
16	7.98	13.48	53.73	3.99	16.43	11.27	1.21	82284.77
17	9.80	12.73	57.09	5.26	14.27	11.71	1.22	80479.18
18	3.57	12.47	59.83	4.02	15.12	11.44	1.23	82143.97
19	10.55	12.62	55.03	4.76	14.89	11.44	1.21	82916.46
20	4.33	12.42	61.49	4.01	15.82	11.31	1.21	83328.03
21	3.84	12.54	57.71	3.88	15.59	11.43	1.22	82178.91
22	11.75	12.42	52.87	4.38	15.64	11.30	1.22	83209.63
23	6.67	12.40	60.36	3.84	16.15	11.25	1.22	83014.23
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.49	12.60	58.38	3.12	15.28	11.54	1.22	81722.27
最大值	14.18	13.52	67.02	5.26	16.77	12.03	1.25	87577.71
發生時間	10	0	3	17	14	1		5
最小值	2.31	11.47	48.69	1.72	13.72	11.17	1.20	77151.00
發生時間	5	3	4	12	5	14		1
零點偏移(率)	-0.02 %	-0.11 %	-0.07 %	-0.01 %		-0.02	-0.01	0.10 %
全幅偏移(率)	0.00 %	-0.29 %	0.95 %	0.05 %		0.12	-0.06	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年05月30日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.95	13.94	56.56	1.42	18.27	10.31	0.94	78945.25
1	6.20	13.84	56.05	1.71	18.28	10.21	0.94	78849.00
2	12.26	13.02	57.25	1.68	17.71	10.26	0.94	79028.26
3	11.00	12.09	56.49	2.28	16.39	11.00	0.94	79478.34
4	9.56	11.75	58.06	1.53	17.28	10.61	0.94	81137.89
5	8.97	12.62	57.29	2.19	16.91	10.62	0.94	82172.88
6	9.37	12.19	53.60	1.98	17.08	10.87	0.94	81410.58
7	8.86	12.18	58.02	2.52	16.66	10.64	0.94	80650.65
8	11.61	11.73	51.34	1.92	16.78	10.67	0.94	80757.55
9	7.07	12.00	55.47	2.33	16.35	10.90	0.95	82255.88
10	13.25	11.91	55.07	1.72	17.21	10.78	0.95	81464.91
11	6.78	11.52	45.64	1.35	17.77	10.24	0.95	78131.83
12	8.26	11.38	48.88	0.87	18.89	10.04	0.94	81176.83
13	5.00	11.46	46.36	1.37	17.97	10.25	0.94	80064.97
14	4.83	11.65	58.33	0.86	18.90	9.87	0.94	83016.54
15	9.69	12.58	56.44	1.70	17.50	10.49	0.94	81302.45
16	6.76	15.46	63.26	1.56	17.50	10.55	0.94	82160.70
17	12.73	12.05	59.28	3.00	14.76	11.14	0.94	79458.95
18	8.54	11.99	64.52	1.54	16.52	10.93	0.95	82393.21
19	8.46	12.21	63.25	1.60	16.45	11.13	0.94	80093.31
20	7.74	12.10	52.44	1.70	15.74	11.11	0.94	81292.02
21	10.93	12.14	60.95	1.63	16.30	11.09	0.94	82405.31
22	9.90	12.13	62.49	1.30	16.96	10.98	0.94	80445.18
23	6.23	11.96	59.59	0.42	19.46	10.47	0.94	80874.42
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.91	12.33	56.53	1.67	17.23	10.63	0.94	80790.29
最大值	13.25	15.46	64.52	3.00	19.46	11.14	0.97	83016.54
發生時間	10	16	18	17	23	17		14
最小值	4.83	11.38	45.64	0.42	14.76	9.87	0.94	78131.83
發生時間	14	12	11	23	17	14		11
零點偏移(率)	-0.05 %	-0.13 %	-0.04 %	-0.01 %		0.01	-0.01	-0.20 %
全幅偏移(率)	1.99 %	-0.67 %	1.15 %	-0.99 %		0.13	0.00	-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年05月30日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.75	11.09	45.43	1.91	16.84	9.19	1.28	71355.03
1	7.43	10.86	48.77	2.89	18.99	9.29	1.31	72913.88
2	9.51	10.83	46.50	3.06	17.99	9.40	1.31	72537.25
3	9.58	11.13	45.23	3.00	17.23	9.44	1.31	72184.56
4	6.14	10.54	51.58	2.98	19.23	9.02	1.32	73109.58
5	7.38	12.44	55.75	2.80	16.73	9.37	1.33	71773.43
6	10.67	12.85	56.19	3.04	18.82	8.76	1.31	71196.28
7	5.59	10.46	35.48	2.73	17.81	8.70	1.32	68412.39
8	9.63	10.39	37.41	3.19	18.16	8.65	1.36	69968.05
9	11.76	10.74	41.47	3.50	17.47	9.07	1.38	74028.79
10	7.17	11.24	52.37	2.97	17.19	10.13	1.36	74507.94
11	10.06	11.27	52.49	2.97	17.51	10.04	1.36	72880.41
12	8.84	11.14	51.77	2.87	17.21	10.01	1.38	72078.79
13	8.55	11.01	51.97	3.06	17.91	9.78	1.39	73563.08
14	7.96	10.94	51.27	2.95	18.44	9.64	1.40	74422.56
15	11.28	12.05	51.07	3.25	19.15	9.24	1.36	75935.74
16	5.79	11.49	48.89	2.96	18.75	9.47	1.34	75126.31
17	5.85	10.80	51.32	2.81	18.10	9.55	1.34	74334.66
18	6.21	11.09	51.07	2.88	18.31	9.74	1.38	74043.58
19	7.07	10.93	47.30	2.92	17.54	9.55	1.34	75088.14
20	9.18	10.85	49.98	2.89	17.46	9.67	1.36	73568.96
21	10.64	10.68	51.85	3.06	17.97	9.42	1.36	75581.64
22	5.97	10.78	50.01	2.91	16.79	9.70	1.36	74050.60
23	7.57	10.80	52.57	2.91	17.24	9.66	1.36	74079.05
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.27	11.10	49.07	2.94	17.87	9.44	1.35	73197.53
最大值	11.76	12.85	56.19	3.50	19.23	10.13	1.41	75935.74
發生時間	9	6	6	9	4	10		15
最小值	5.59	10.39	35.48	1.91	16.73	8.65	1.27	68412.39
發生時間	7	8	7	0	5	8		7
零點偏移(率)	-0.06 %	-0.00 %	-0.03 %	-0.00 %		-0.03	-0.01	0.00 %
全幅偏移(率)	2.51 %	-0.83 %	1.81 %	-0.01 %		0.34	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								