

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年01月31日

報表日期: 114年01月31日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.66	5.96	39.66	2.36	14.60	11.76	1.26	79988.41
1	9.63	6.61	40.53	2.46	14.99	11.49	1.26	80616.18
2	11.56	7.78	39.75	2.58	14.39	11.67	1.25	78536.83
3	4.40	6.80	53.16	1.89	14.06	12.07	1.26	75006.22
4	8.97	12.59	51.79	2.61	13.08	12.23	1.25	77190.25
5	4.42	5.35	52.35	1.32	14.42	12.08	1.27	76843.24
6	8.04	2.76	49.68	1.48	14.62	11.88	1.28	80268.25
7	10.65	2.37	50.99	1.39	14.45	11.76	1.27	81866.84
8	9.49	2.47	47.82	1.52	14.47	11.89	1.26	80644.58
9	12.29	2.77	49.12	2.04	13.71	11.83	1.27	81775.19
10	9.01	2.71	49.59	1.47	14.26	12.02	1.26	79767.21
11	10.74	2.72	45.37	1.93	14.01	11.99	1.27	80090.50
12	2.57	3.12	63.26	2.12	13.36	12.97	1.32	70778.52
13	5.86	2.36	46.81	1.65	14.57	11.72	1.29	81316.45
14	4.30	2.50	52.94	1.06	15.36	12.04	1.28	78225.12
15	3.19	2.62	65.46	0.82	15.78	11.42	1.26	82122.52
16	9.07	3.08	35.88	1.57	14.76	11.67	1.27	81705.70
17	7.80	2.84	41.39	1.17	15.82	11.59	1.29	81838.73
18	3.76	2.26	39.08	0.76	16.58	11.25	1.29	84703.10
19	7.36	2.31	40.45	0.84	16.85	11.06	1.28	84897.28
20	10.62	2.25	41.48	0.75	16.74	11.01	1.27	85350.30
21	14.08	4.45	43.37	1.09	16.32	10.93	1.28	86180.25
22	12.72	4.30	50.01	1.30	15.35	11.21	1.28	84529.83
23	3.75	5.36	37.74	1.48	15.08	11.41	1.28	83282.15
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.16	4.10	46.99	1.57	14.90	11.71	1.27	80730.15
最 大 值	14.08	12.59	65.46	2.61	16.85	12.97	1.34	86180.25
發生時間	21	4	15	4	19	12		21
最 小 值	2.57	2.25	35.88	0.75	13.08	10.93	1.25	70778.52
發生時間	12	20	16	20	4	21		12
零點偏移(率)	-0.01 %	-0.01 %	-0.02 %	-0.02 %		-0.04		0.30 %
全幅偏移(率)	-0.56 %	1.03 %	-0.02 %	0.33 %		-0.14		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年01月31日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	8.78	6.99	56.79	2.23	12.85	11.51	1.52	78974.16
1	15.42	4.97	58.80	1.74	14.21	11.39	1.52	78610.72
2	9.84	1.42	57.86	1.84	13.40	11.43	1.52	79152.80
3	12.80	4.81	51.18	1.17	14.76	10.91	1.52	80833.13
4	10.36	2.70	49.14	0.97	14.80	10.98	1.52	80982.95
5	13.22	2.63	53.93	1.83	14.01	11.05	1.52	81069.90
6	8.53	3.36	52.47	1.83	14.10	11.10	1.52	80948.03
7	10.39	3.98	55.20	2.35	13.83	11.04	1.55	78276.40
8	8.90	3.30	53.57	1.84	14.53	10.85	1.54	81939.21
9	10.91	3.18	56.14	1.76	14.72	10.84	1.55	82435.55
10	10.56	3.10	55.41	2.40	13.95	11.07	1.54	80460.54
11	11.37	2.15	63.05	1.80	14.61	10.97	1.55	80528.36
12	8.69	2.18	58.25	1.89	14.19	10.98	1.55	81207.84
13	9.72	3.74	60.75	1.78	14.01	11.12	1.55	79967.52
14	9.25	2.43	66.04	2.07	14.13	11.17	1.52	79941.69
15	10.75	2.58	57.91	1.71	14.14	11.00	1.52	80264.68
16	9.77	3.76	53.39	1.29	15.23	10.64	1.52	82447.72
17	16.18	3.06	48.96	1.78	14.74	10.98	1.53	80836.60
18	10.18	4.27	49.45	0.94	15.70	10.47	1.53	83939.09
19	9.45	4.83	46.05	1.58	14.11	11.06	1.52	80226.82
20	7.77	2.69	45.58	1.33	14.58	10.94	1.55	80775.17
21	9.54	2.16	52.91	1.55	14.80	10.94	1.54	79602.96
22	8.64	1.28	54.66	1.66	15.24	10.77	1.54	80350.78
23	9.01	1.37	47.31	1.60	14.75	10.86	1.53	80634.53
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	10.42	3.21	54.37	1.71	14.39	11.00	1.53	80600.30
最 大 值	16.18	6.99	66.04	2.40	15.70	11.51	1.57	83939.09
發生時間	17	0	14	10	18	0		18
最 小 值	7.77	1.28	45.58	0.94	12.85	10.47	1.51	78276.40
發生時間	20	22	20	18	0	18		7
零點偏移(率)	-0.09 %	-0.01 %	-0.04 %	0.00 %		-0.05		0.00 %
全幅偏移(率)	-1.40 %	0.01 %	0.04 %	0.16 %		-0.08		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								