

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月26日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.35	2.55	56.34	2.49	17.31	11.84	1.35	71263.82
1	9.08	3.68	53.19	2.64	17.21	11.99	1.38	69836.88
2	10.99	3.36	57.08	2.53	17.52	11.71	1.37	72831.40
3	10.31	3.23	63.23	2.40	17.97	11.58	1.36	73333.50
4	9.96	6.68	54.87	2.93	16.65	11.81	1.34	72483.79
5	9.67	5.69	67.55	2.50	16.53	12.23	1.33	68482.69
6	9.68	3.74	62.81	2.51	16.61	12.49	1.33	67526.15
7	9.07	3.86	42.72	2.95	15.66	12.06	1.33	71704.87
8	4.92	4.02	60.16	2.40	16.37	12.22	1.34	69500.68
9	6.57	3.39	59.38	2.07	17.87	11.48	1.36	74564.58
10	7.30	3.84	52.40	1.95	17.96	11.52	1.38	74098.23
11	8.05	3.52	60.09	2.33	17.89	11.54	1.39	73865.67
12	8.49	3.19	64.06	1.76	19.23	11.05	1.39	75927.02
13	4.46	3.50	58.49	1.71	18.78	11.53	1.40	73732.13
14	8.37	3.56	46.67	2.20	18.34	11.52	1.40	75402.58
15	10.33	5.62	49.44	2.70	16.72	11.57	1.40	74894.27
16	9.57	3.95	61.35	2.10	18.34	11.72	1.40	72424.55
17	9.88	3.32	60.72	2.06	18.33	11.28	1.39	75629.82
18	10.09	4.42	46.58	2.94	16.73	11.74	1.39	73511.43
19	10.04	3.57	52.42	3.27	15.49	12.64	1.40	68997.39
20	7.74	3.57	61.11	2.47	16.75	12.42	1.39	69665.53
21	7.61	3.66	56.32	2.04	17.83	11.89	1.38	71938.74
22	10.56	3.51	60.19	2.21	17.36	11.88	1.39	71999.20
23	8.87	3.66	57.97	2.29	16.97	11.93	1.39	71660.74
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.83	3.88	56.88	2.39	17.35	11.82	1.37	72303.15
最大值	10.99	6.68	67.55	3.27	19.23	12.64	1.44	75927.02
發生時間	2	4	5	19	12	19		12
最小值	4.46	2.55	42.72	1.71	15.49	11.05	1.33	67526.15
發生時間	13	0	7	13	19	12		6
零點偏移(率)	-0.16 %	0.00 %	-0.06 %	-0.00 %		-0.01	0.00	0.00 %
全幅偏移(率)	-3.31 %	0.47 %	-0.28 %	0.06 %		0.05	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月26日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.36	2.64	50.87	2.34	19.60	9.76	1.51	85854.41
1	9.02	3.68	60.57	1.26	20.69	10.01	1.51	86911.67
2	9.76	4.48	54.58	2.37	19.27	10.36	1.50	84756.65
3	9.27	3.72	55.50	2.18	19.47	10.14	1.51	86717.08
4	9.50	3.81	53.85	2.11	19.07	10.30	1.51	86743.60
5	9.59	6.49	56.57	2.51	17.04	10.72	1.50	83359.27
6	11.23	6.81	61.86	3.28	17.47	10.91	1.50	93335.61
7	8.93	4.25	56.46	2.62	17.66	10.59	1.46	84829.55
8	8.77	3.97	63.80	2.57	16.84	10.87	1.46	85314.03
9	9.33	5.13	44.65	2.52	17.68	10.39	1.46	82613.80
10	10.74	5.36	54.67	2.16	19.60	9.84	1.46	89210.04
11	9.10	4.27	47.42	2.48	17.59	10.44	1.46	83086.80
12	8.55	6.91	50.41	3.18	15.97	10.43	1.46	81223.97
13	9.41	6.53	52.73	4.33	15.21	10.77	1.47	78863.34
14	10.67	5.55	41.95	3.33	18.37	9.92	1.46	84732.00
15	8.75	5.07	46.71	2.73	16.42	10.97	1.46	76555.94
16	9.53	4.85	45.19	2.48	17.78	10.26	1.46	82328.84
17	9.77	3.76	51.15	2.40	18.23	10.21	1.46	83818.16
18	10.54	4.90	42.37	3.07	18.14	10.19	1.46	84442.76
19	9.85	4.00	43.21	3.64	17.74	10.44	1.46	82462.82
20	9.84	4.38	51.11	2.85	18.68	9.97	1.48	83596.18
21	11.26	5.27	41.99	3.13	17.73	10.21	1.51	82932.47
22	10.36	3.69	40.45	2.84	18.14	10.08	1.51	82448.56
23	10.93	5.16	50.47	2.70	18.07	10.12	1.51	82648.20
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.79	4.78	50.77	2.71	18.02	10.33	1.48	84116.07
最大值	11.26	6.91	63.80	4.33	20.69	10.97	1.51	93335.61
發生時間	21	12	8	13	1	15		6
最小值	8.55	2.64	40.45	1.26	15.21	9.76	1.45	76555.94
發生時間	12	0	22	1	13	0		15
零點偏移(率)	-0.26 %	0.00 %	-0.29 %	-0.03 %		-0.01	0.00	0.00 %
全幅偏移(率)	1.48 %	0.84 %	0.20 %	0.26 %		0.03	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月26日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.82	5.56	45.75	1.99	17.18	10.23	1.37	84080.88
1	7.72	6.31	51.20	2.23	17.09	10.67	1.38	80737.30
2	8.69	4.76	57.27	2.34	18.24	10.25	1.38	86914.86
3	7.69	6.18	57.79	2.53	16.92	10.57	1.37	83449.00
4	7.53	6.62	52.46	2.51	17.25	10.40	1.37	85980.45
5	9.66	7.18	54.61	2.67	16.10	10.88	1.38	84257.80
6	9.35	7.63	64.43	2.89	16.46	11.12	1.38	83272.84
7	4.28	7.86	65.27	2.50	14.23	12.05	1.38	79651.01
8	1.98	5.81	53.64	1.87	16.70	11.29	1.37	83782.01
9	2.06	19.76	44.60	3.85	15.44	10.76	1.37	84704.22
10	4.69	5.06	58.22	2.00	16.31	11.07	1.38	83649.75
11	10.68	5.42	57.80	2.37	16.65	10.91	1.38	84108.30
12	10.64	6.92	54.21	2.11	16.98	10.66	1.38	88196.68
13	9.95	14.71	49.18	3.03	15.06	10.81	1.38	82023.44
14	10.10	2.02	54.75	2.62	16.05	10.79	1.39	84028.62
15	7.88	3.05	56.14	1.94	17.03	10.70	1.40	83691.31
16	10.53	4.88	50.41	2.30	16.82	10.25	1.40	85651.60
17	10.65	4.07	47.59	2.63	15.22	10.71	1.38	81909.18
18	9.98	2.91	57.68	2.51	16.06	10.83	1.38	81050.64
19	7.41	2.74	60.09	2.17	16.36	11.11	1.40	80185.59
20	7.63	3.09	50.45	1.99	17.04	10.51	1.41	86977.66
21	11.70	3.26	50.10	2.64	17.71	10.17	1.41	88976.23
22	10.70	2.06	51.84	2.70	16.75	10.55	1.41	86726.21
23	10.42	3.05	51.79	2.72	16.62	10.63	1.42	86746.26
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.28	5.87	54.05	2.46	16.51	10.75	1.39	84197.99
最大值	11.70	19.76	65.27	3.85	18.24	12.05	1.43	88976.23
發生時間	21	9	7	9	2	7		21
最小值	1.98	2.02	44.60	1.87	14.23	10.17	1.36	79651.01
發生時間	8	14	9	8	7	21		7
零點偏移(率)	-0.14 %	-0.00 %	-0.27 %	-0.08 %		0.04	0.00	0.00 %
全幅偏移(率)	1.40 %	0.23 %	-0.12 %	0.09 %		0.27	0.02	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								