

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月29日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.08	12.66	49.71	0.48	20.94	10.78	1.05	75923.43
1	6.05	9.68	46.98	0.86	19.60	11.49	1.02	71924.95
2	4.76	9.11	57.75	0.70	19.08	11.29	1.02	74217.73
3	7.93	9.40	40.93	1.65	16.78	11.67	1.02	72898.44
4	6.23	7.74	44.50	1.23	17.90	11.38	1.02	73982.18
5	6.26	7.09	41.79	2.34	15.72	11.94	0.99	69152.73
6	1.98	6.39	57.63	1.06	17.31	12.21	0.99	68344.78
7	0.61	6.95	46.59	0.62	18.97	10.89	1.00	77517.57
8	5.78	8.64	44.86	1.48	17.94	11.30	1.00	74621.91
9	8.18	10.19	42.47	1.47	17.36	11.53	1.04	73682.29
10	9.06	8.56	41.94	1.84	16.66	11.60	1.03	73270.97
11	5.36	8.96	55.01	0.92	18.45	11.70	1.01	71231.33
12	4.51	9.27	49.74	0.53	19.63	11.09	1.00	74938.78
13	7.13	12.29	43.49	1.43	17.18	11.57	1.01	73362.50
14	2.11	8.08	60.08	0.99	18.23	11.85	1.02	70291.78
15	0.55	11.70	65.71	0.36	20.02	11.24	1.01	73456.23
16	2.93	12.17	50.60	0.86	18.33	11.27	0.99	74686.39
17	5.66	13.76	44.93	1.47	18.00	11.47	1.00	73541.07
18	6.00	9.95	42.04	1.89	16.73	11.69	1.02	73309.14
19	6.27	7.02	48.91	1.10	18.15	11.38	1.03	74546.96
20	7.49	9.46	48.09	1.02	18.82	11.11	1.02	75083.29
21	8.07	11.99	41.47	1.54	17.60	11.37	1.02	74103.87
22	7.56	7.64	45.28	1.61	17.68	11.53	1.02	72698.10
23	5.79	9.80	51.83	0.85	18.80	11.37	1.02	73605.63
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.56	9.52	48.43	1.18	18.16	11.45	1.02	73349.67
最大值	9.06	13.76	65.71	2.34	20.94	12.21	1.05	77517.57
發生時間	10	17	15	5	0	6		7
最小值	0.55	6.39	40.93	0.36	15.72	10.78	0.99	68344.78
發生時間	15	6	3	15	5	0		6
零點偏移(率)	-0.01 %	-0.14 %	-0.02 %	-0.00 %		-0.05		0.00 %
全幅偏移(率)	0.02 %	0.04 %	-0.04 %	0.05 %		0.07		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月29日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.24	7.34	43.38	1.68	19.16	10.01	0.99	86608.68
1	0.62	8.05	49.44	1.72	20.19	9.64	0.99	89195.51
2	4.28	4.02	47.54	2.74	16.83	10.58	0.99	85289.99
3	7.30	9.91	47.63	1.40	19.14	9.88	0.99	88693.10
4	9.99	4.56	48.32	2.56	17.28	10.21	1.07	87406.51
5	7.90	4.40	57.81	2.07	17.03	10.57	1.01	85258.80
6	9.63	6.96	40.08	1.78	18.23	10.22	1.01	84750.22
7	7.75	7.95	45.18	2.08	17.44	10.42	1.01	85644.84
8	9.71	4.72	46.03	2.06	17.28	10.36	1.01	86272.46
9	8.99	4.98	50.96	1.29	18.49	10.12	1.01	86795.77
10	8.77	10.41	41.81	1.90	17.69	10.15	1.01	87188.25
11	8.92	2.45	42.91	1.60	17.88	10.12	1.01	87145.94
12	7.04	6.26	46.16	1.87	17.88	10.08	1.01	87626.90
13	4.70	3.96	50.50	0.87	20.09	9.58	1.02	89271.38
14	5.71	5.23	56.87	1.03	19.37	9.93	1.02	87177.26
15	7.85	3.29	44.98	1.53	18.70	10.09	1.02	87151.77
16	8.57	9.16	47.84	1.86	18.02	10.14	1.00	86848.62
17	6.07	4.39	50.29	1.28	17.78	10.31	1.00	85626.68
18	7.92	6.42	48.17	1.59	17.15	10.33	1.01	86052.71
19	5.72	6.20	52.58	1.22	18.49	10.30	0.99	84972.60
20	7.05	8.52	55.83	1.01	19.68	9.66	0.99	88428.51
21	9.49	9.30	42.70	1.49	18.64	9.73	0.99	88400.46
22	7.74	4.60	43.71	0.76	18.92	10.19	0.99	85076.47
23	3.80	5.41	48.37	0.65	19.43	10.26	0.99	84353.00
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.95	6.19	47.88	1.59	18.37	10.12	1.01	86718.18
最大值	9.99	10.41	57.81	2.74	20.19	10.58	1.19	89271.38
發生時間	4	10	5	2	1	2		13
最小值	0.62	2.45	40.08	0.65	16.83	9.58	0.99	84353.00
發生時間	1	11	6	23	2	13		23
零點偏移(率)	-0.04 %	-0.19 %	-0.02 %	0.00 %		0.01		-0.20 %
全幅偏移(率)	0.10 %	0.00 %	-0.42 %	-0.15 %		0.09		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月29日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.98	7.59	39.64	0.72	17.48	10.12	0.95	81563.18
1	2.29	2.44	47.83	0.96	18.34	10.59	0.93	79182.82
2	7.04	9.09	40.33	1.18	18.10	10.07	0.91	80982.33
3	8.68	5.90	34.52	1.33	16.75	10.07	0.90	79606.87
4	6.95	8.84	35.06	1.20	18.20	9.88	0.91	82603.19
5	5.02	4.81	35.83	1.21	16.03	10.39	0.91	75778.48
6	4.91	4.61	34.81	1.09	18.74	9.80	0.92	79502.20
7	6.64	9.03	36.80	1.17	17.11	10.20	0.94	84494.36
8	8.80	8.78	34.65	1.05	17.28	10.08	0.94	80095.13
9	7.44	8.27	30.63	1.01	17.63	9.89	0.98	79506.25
10	6.55	4.30	46.06	1.06	18.20	10.01	0.98	83037.02
11	7.46	4.92	45.28	0.87	19.02	10.19	0.95	86109.34
12	5.96	6.62	45.50	1.13	16.85	10.77	0.94	81951.53
13	8.23	6.91	52.29	1.10	17.35	10.83	0.96	81729.05
14	6.90	4.52	46.77	1.32	17.05	10.69	0.97	79848.74
15	2.96	3.41	44.41	0.78	18.14	10.40	0.95	77163.12
16	2.88	4.99	43.48	0.77	18.49	10.09	0.93	78698.09
17	5.07	7.24	34.58	1.10	17.63	9.74	0.93	78916.63
18	6.37	6.67	40.15	1.15	16.23	10.47	0.96	73722.43
19	5.53	5.99	39.78	1.28	17.46	10.10	0.97	77274.68
20	4.17	7.63	43.67	1.00	18.57	10.09	0.97	80297.88
21	2.87	9.54	34.03	0.63	18.74	9.77	0.96	80527.65
22	6.77	6.38	38.59	1.20	16.90	10.05	0.95	79675.66
23	5.93	3.55	55.57	0.88	18.30	10.74	0.96	77154.61
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.77	6.33	40.84	1.05	17.69	10.21	0.94	79975.88
最大值	8.80	9.54	55.57	1.33	19.02	10.83	0.99	86109.34
發生時間	8	21	23	3	11	13		11
最小值	2.29	2.44	30.63	0.63	16.03	9.74	0.89	73722.43
發生時間	1	1	9	21	5	17		18
零點偏移(率)	-0.01 %	-0.05 %	-0.02 %	-0.01 %		0.00		0.00 %
全幅偏移(率)	-0.01 %	-0.05 %	-0.81 %	0.15 %		0.37		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								