

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 114年09月02日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.76	13.10	67.16	1.71	16.02	12.08	1.25	68426.15
1	9.47	12.16	55.39	2.13	15.46	11.95	1.25	69408.92
2	10.36	12.43	63.95	1.65	16.28	12.14	1.25	67856.43
3	9.60	11.90	44.99	2.28	14.41	11.94	1.24	70462.53
4	9.99	11.90	56.59	1.95	15.60	11.79	1.24	70950.95
5	9.77	12.04	57.24	1.94	16.38	11.78	1.21	71032.34
6	7.15	12.01	50.50	1.80	15.56	11.83	1.21	70567.72
7	9.11	13.02	56.44	2.68	15.87	11.76	1.21	70416.80
8	9.05	13.28	60.92	3.04	16.90	11.64	1.21	70892.20
9	12.03	13.23	59.45	3.37	16.84	11.19	1.21	73923.84
10	7.15	13.45	50.56	3.82	14.82	11.94	1.24	69394.52
11	9.43	13.34	57.01	3.76	15.36	11.65	1.21	71516.91
12	9.07	13.02	59.26	3.28	16.03	11.57	1.23	71708.03
13	5.94	13.48	53.05	3.22	14.71	12.03	1.21	68934.69
14	7.32	13.25	60.36	3.36	15.18	11.84	1.23	70378.22
15	9.02	13.36	59.01	3.36	14.18	11.99	1.23	69389.87
16	14.82	13.91	62.83	3.95	13.88	12.27	1.22	69004.11
17	10.25	14.70	61.84	1.90	13.44	12.72	1.20	66942.25
18	8.85	13.24	61.73	1.55	14.10	11.96	1.20	70926.82
19	10.52	13.39	63.09	1.66	13.95	12.02	1.21	69744.42
20	9.51	13.49	61.21	2.35	14.09	11.98	1.23	69632.09
21	6.05	14.49	46.84	3.77	13.92	11.87	1.24	69947.67
22	9.85	12.95	49.78	2.27	13.72	11.98	1.24	68830.49
23	8.10	13.06	51.15	1.89	13.18	12.08	1.25	68859.91
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.13	13.09	57.10	2.61	15.00	11.92	1.23	69964.50
最 大 值	14.82	14.70	67.16	3.95	16.90	12.72	1.25	73923.84
發生時間	16	17	0	16	8	17		9
最 小 值	5.94	11.90	44.99	1.55	13.18	11.19	1.18	66942.25
發生時間	13	3	3	18	23	9		17
零點偏移(率)	-0.02 %	-0.00 %	-0.09 %	-0.03 %		-0.02		0.00 %
全幅偏移(率)	0.00 %	-0.17 %	0.20 %	0.23 %		-0.16		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年09月02日

[illegible]