

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月09日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.35	3.21	61.17	3.39	14.28	12.03	1.44	71900.96
1	5.43	5.81	49.42	3.78	13.60	12.53	1.44	68360.76
2	4.89	4.17	59.75	3.27	14.54	12.30	1.44	70189.86
3	7.48	6.10	50.46	4.25	13.17	12.55	1.47	68745.42
4	5.87	3.60	61.44	3.91	13.90	12.59	1.50	68566.30
5	1.12	7.48	61.09	2.74	14.41	12.84	1.45	67354.62
6	0.55	4.22	48.72	2.98	13.60	12.60	1.41	68684.96
7	0.93	4.04	62.99	2.66	14.47	12.74	1.39	66250.76
8	0.34	3.60	52.28	2.23	14.96	12.57	1.38	67202.06
9	0.11	3.48	44.94	2.09	15.58	12.23	1.40	69371.09
10	1.09	3.00	55.40	1.74	16.29	11.60	1.45	73171.62
11	1.83	3.98	59.34	3.63	12.46	12.78	1.42	66817.47
12	5.63	7.91	48.32	4.07	12.54	12.81	1.43	66802.99
13	9.04	4.51	58.82	4.39	12.35	12.73	1.43	66653.74
14	10.69	6.65	45.09	5.24	11.09	12.89	1.39	65568.66
15	11.52	7.26	58.53	5.87	12.58	12.80	1.40	66534.25
16	7.61	4.25	50.88	5.91	12.82	12.71	1.40	67794.12
17	7.62	3.69	53.33	4.25	12.96	12.69	1.43	67582.61
18	7.29	3.93	55.88	4.28	12.43	12.94	1.43	66020.16
19	2.21	3.35	59.53	2.96	13.68	12.51	1.40	68865.73
20	6.26	3.36	57.82	3.31	13.35	12.57	1.41	68200.56
21	6.46	3.32	58.83	3.13	13.68	12.37	1.45	70064.56
22	3.70	5.67	50.29	3.68	12.50	12.79	1.44	67933.39
23	2.88	5.63	58.38	3.56	12.84	12.86	1.41	66894.65
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.95	4.68	55.11	3.64	13.50	12.58	1.43	68147.14
最大值	11.52	7.91	62.99	5.91	16.29	12.94	1.51	73171.62
發生時間	15	12	7	16	10	18		10
最小值	0.11	3.00	44.94	1.74	11.09	11.60	1.38	65568.66
發生時間	9	10	9	10	14	10		14
零點偏移(率)	-0.01 %	-0.00 %	-0.14 %	-0.00 %		0.00	0.00	0.00 %
全幅偏移(率)	-0.43 %	-0.36 %	0.12 %	-0.17 %		0.12	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月09日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.21	3.47	44.04	2.54	15.39	10.65	1.48	80224.93
1	9.62	3.79	47.08	2.50	15.22	10.71	1.45	83356.00
2	9.19	5.30	63.29	2.63	13.85	11.25	1.44	82431.84
3	8.91	4.77	48.33	2.51	15.29	10.59	1.44	80405.56
4	9.14	3.44	44.05	2.84	16.52	10.36	1.44	81987.65
5	7.80	3.23	45.18	2.33	16.94	10.23	1.44	84251.84
6	5.94	3.67	61.53	1.83	17.05	10.97	1.45	79325.95
7	3.57	3.48	57.38	1.10	19.57	10.30	1.46	84797.73
8	3.39	6.21	39.76	1.45	18.12	10.12	1.47	82760.45
9	4.32	4.36	42.69	1.65	18.61	9.95	1.49	84567.45
10	3.17	8.52	40.66	1.99	15.43	10.63	1.49	82151.67
11	1.72	4.30	43.30	1.88	15.75	10.22	1.45	77125.97
12	8.41	4.88	42.55	3.31	15.47	10.19	1.48	77453.37
13	10.51	3.74	46.55	3.86	14.76	10.62	1.43	78607.25
14	10.38	3.67	50.07	3.45	15.41	10.63	1.44	82283.72
15	10.16	3.50	52.40	3.19	15.65	10.86	1.46	83738.45
16	10.01	3.53	51.23	2.56	15.53	10.94	1.43	83317.88
17	6.83	3.44	54.35	2.25	15.55	10.87	1.44	81986.90
18	8.19	3.27	56.16	2.29	16.52	10.67	1.48	83729.21
19	8.10	3.52	53.73	2.04	16.39	10.68	1.47	84796.61
20	10.67	5.16	51.45	2.90	14.36	11.17	1.43	82255.50
21	6.41	6.90	56.71	2.17	15.08	11.05	1.45	82844.80
22	9.41	5.16	53.93	2.28	15.55	10.95	1.49	82940.51
23	8.33	3.48	51.38	2.05	16.56	10.78	1.49	84255.16
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.60	4.37	49.91	2.40	16.02	10.64	1.46	82149.85
最大值	10.67	8.52	63.29	3.86	19.57	11.25	1.51	84797.73
發生時間	20	10	2	13	7	2		7
最小值	1.72	3.23	39.76	1.10	13.85	9.95	1.43	77125.97
發生時間	11	5	8	7	2	9		11
零點偏移(率)	-0.01 %	-0.00 %	-0.11 %	0.00 %		-0.05	0.00	0.00 %
全幅偏移(率)	2.47 %	0.00 %	-0.15 %	0.13 %		0.02	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月09日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.16	4.79	48.21	2.03	14.89	10.92	1.38	81054.59
1	4.03	3.33	55.73	2.05	15.19	11.07	1.38	83928.27
2	7.49	9.09	53.82	3.22	14.12	11.19	1.37	82867.68
3	6.69	3.74	55.66	3.06	13.70	11.34	1.39	82660.89
4	8.08	2.35	57.73	2.24	15.31	11.16	1.38	82728.01
5	6.70	3.32	55.20	2.05	15.28	11.13	1.38	83831.64
6	1.74	3.33	63.81	1.60	16.29	11.21	1.38	82291.01
7	2.51	4.92	48.66	1.37	15.29	11.16	1.39	83698.58
8	2.93	3.60	55.38	1.06	16.90	11.00	1.41	82962.84
9	1.84	3.72	57.85	1.51	15.46	11.39	1.42	80032.84
10	3.43	9.86	53.88	2.31	14.07	11.00	1.43	82148.44
11	1.84	3.36	57.24	1.97	14.18	11.30	1.43	81215.08
12	1.36	3.48	60.53	1.68	14.62	11.33	1.43	82196.24
13	5.25	4.44	57.89	2.53	13.60	11.54	1.43	79517.52
14	1.65	4.21	56.50	1.90	14.11	11.39	1.41	79106.76
15	1.76	4.45	51.04	1.68	14.61	11.10	1.41	80297.10
16	2.61	3.19	56.09	2.23	13.70	11.27	1.41	79937.84
17	2.23	4.11	57.32	1.70	14.91	11.23	1.42	80876.74
18	1.96	4.94	55.30	1.63	14.75	11.08	1.41	83134.65
19	2.01	5.50	55.60	2.02	13.97	11.16	1.40	78502.22
20	1.88	3.83	54.90	1.58	14.77	11.06	1.39	80627.63
21	3.78	5.48	57.80	2.11	14.16	11.42	1.39	81357.66
22	7.55	4.07	55.75	2.12	14.50	11.24	1.41	82369.84
23	3.44	3.60	60.10	1.47	16.35	11.11	1.39	80828.53
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	3.62	4.45	55.92	1.96	14.78	11.20	1.40	81590.52
最大值	8.08	9.86	63.81	3.22	16.90	11.54	1.46	83928.27
發生時間	4	10	6	2	8	13		1
最小值	1.36	2.35	48.21	1.06	13.60	10.92	1.36	78502.22
發生時間	12	4	0	8	13	0		19
零點偏移(率)	-0.03 %	-0.00 %	-0.13 %	-0.01 %		0.00	0.00	0.00 %
全幅偏移(率)	0.00 %	-0.60 %	-0.42 %	-0.03 %		0.04	0.02	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								