

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月13日

| 項目 | #1-HCl_C | #1-CO_C | #1-NOx_C | #1-SO2_C | #1-H2O | #1-O2_C | #1-OPAC | #1-FLOW_C |
|---------|----------|----------|----------|----------|----------|----------|----------|-----------|
| 單位 | ppm | ppm | ppm | ppm | % | % | % | m3/Hour |
| 小時\限標 | 60.00 | 150.00 | 220.00 | 150.00 | 100.00 | 25.00 | 10.00 | 999999.00 |
| 0 | 9.54 | 7.33 | 49.28 | 0.98 | 18.22 | 11.05 | 1.06 | 76437.93 |
| 1 | 9.99 | 7.61 | 50.36 | 1.12 | 18.16 | 11.44 | 1.07 | 74869.04 |
| 2 | 8.51 | 7.73 | 52.73 | 1.62 | 16.98 | 11.67 | 1.07 | 73875.07 |
| 3 | 9.44 | 7.69 | 63.35 | 0.62 | 17.97 | 11.30 | 1.07 | 76363.36 |
| 4 | 8.02 | 7.91 | 53.88 | 1.03 | 17.01 | 11.43 | 1.07 | 75723.34 |
| 5 | 11.20 | 5.86 | 54.67 | 1.11 | 17.48 | 11.27 | 1.05 | 73859.98 |
| 6 | 8.09 | 10.70 | 52.54 | 0.91 | 16.98 | 11.31 | 1.05 | 76408.28 |
| 7 | 9.19 | 11.79 | 53.65 | 0.62 | 18.21 | 11.04 | 1.05 | 77130.34 |
| 8 | 8.24 | 11.74 | 53.58 | 0.62 | 17.15 | 11.37 | 1.03 | 75769.34 |
| 9 | 9.03 | 8.96 | 52.13 | 1.04 | 15.86 | 11.82 | 1.04 | 73094.49 |
| 10 | 9.18 | 5.39 | 49.86 | 1.30 | 15.79 | 11.64 | 1.03 | 75282.13 |
| 11 | 3.01 | 6.44 | 53.72 | 0.87 | 16.65 | 11.78 | 1.02 | 73551.78 |
| 12 | 0.54 | 6.26 | 61.44 | 0.69 | 16.91 | 11.78 | 1.02 | 73397.46 |
| 13 | 4.65 | 5.40 | 50.75 | 0.55 | 17.44 | 11.15 | 1.01 | 77238.11 |
| 14 | 5.88 | 7.66 | 36.16 | 1.48 | 15.74 | 12.06 | 1.00 | 71525.29 |
| 15 | 3.47 | 5.90 | 38.30 | 1.15 | 16.97 | 11.70 | 1.01 | 73990.19 |
| 16 | 4.36 | 5.51 | 42.35 | 0.62 | 17.99 | 11.21 | 1.03 | 76887.31 |
| 17 | 8.75 | 6.47 | 47.11 | 0.92 | 17.97 | 11.11 | 1.02 | 77639.01 |
| 18 | 7.70 | 7.35 | 53.36 | 0.62 | 18.11 | 10.99 | 1.02 | 78648.29 |
| 19 | 4.54 | 7.48 | 45.20 | 0.89 | 17.50 | 11.19 | 1.02 | 76873.67 |
| 20 | 4.81 | 7.49 | 60.64 | 0.45 | 18.32 | 11.17 | 1.03 | 76809.61 |
| 21 | 9.07 | 7.44 | 41.86 | 1.26 | 17.07 | 11.13 | 1.03 | 77946.54 |
| 22 | 8.30 | 7.71 | 49.30 | 1.22 | 16.74 | 11.48 | 1.02 | 75560.72 |
| 23 | 7.07 | 7.52 | 59.59 | 0.70 | 18.01 | 11.35 | 1.04 | 75284.22 |
| 監測時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 超限次數 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 有效時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 平均值 | 7.19 | 7.56 | 51.08 | 0.93 | 17.30 | 11.39 | 1.04 | 75590.23 |
| 最大值 | 11.20 | 11.79 | 63.35 | 1.62 | 18.32 | 12.06 | 1.09 | 78648.29 |
| 發生時間 | 5 | 7 | 3 | 2 | 20 | 14 | | 18 |
| 最小值 | 0.54 | 5.39 | 36.16 | 0.45 | 15.74 | 10.99 | 0.99 | 71525.29 |
| 發生時間 | 12 | 10 | 14 | 20 | 14 | 18 | | 14 |
| 零點偏移(率) | -0.15 % | -0.05 % | -0.04 % | -0.01 % | | -0.47 | | 0.00 % |
| 全幅偏移(率) | 0.00 % | 0.01 % | -0.03 % | -0.01 % | | 0.10 | | 0.20 % |
| 有效比率 | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % |
| 備註 | | | | | | | | |

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月13日

| 項目 | #2-HCl_C | #2-CO_C | #2-NOx_C | #2-SO2_C | #2-H2O | #2-O2_C | #2-OPAC | #2-FLOW_C |
|---------|----------|----------|----------|----------|----------|----------|----------|-----------|
| 單位 | ppm | ppm | ppm | ppm | % | % | % | m3/Hour |
| 小時\限標 | 60.00 | 150.00 | 220.00 | 150.00 | 100.00 | 25.00 | 10.00 | 999999.00 |
| 0 | 8.44 | 2.26 | 53.16 | 2.56 | 16.47 | 10.47 | 0.97 | 84423.46 |
| 1 | 8.66 | 4.42 | 59.06 | 3.14 | 15.69 | 10.67 | 0.97 | 83774.36 |
| 2 | 6.75 | 2.89 | 59.04 | 2.76 | 15.65 | 10.75 | 0.97 | 83689.70 |
| 3 | 4.34 | 2.96 | 58.03 | 2.25 | 16.39 | 10.56 | 0.99 | 84661.99 |
| 4 | 5.21 | 4.68 | 58.17 | 2.22 | 16.79 | 10.48 | 0.99 | 84866.64 |
| 5 | 8.75 | 7.61 | 51.37 | 2.73 | 16.13 | 10.54 | 0.99 | 85280.97 |
| 6 | 6.01 | 6.86 | 64.09 | 2.65 | 15.43 | 10.63 | 0.99 | 87638.62 |
| 7 | 5.69 | 6.47 | 59.00 | 1.82 | 16.32 | 10.47 | 0.99 | 84949.98 |
| 8 | 9.75 | 6.96 | 60.12 | 2.33 | 16.20 | 10.30 | 0.99 | 86088.32 |
| 9 | 9.26 | 7.92 | 44.52 | 2.89 | 15.21 | 10.63 | 0.99 | 84413.75 |
| 10 | 8.93 | 2.90 | 56.72 | 1.56 | 16.95 | 10.10 | 0.99 | 87959.55 |
| 11 | 7.13 | 4.19 | 51.66 | 2.27 | 15.40 | 10.66 | 0.99 | 84561.30 |
| 12 | 4.72 | 2.05 | 46.08 | 1.80 | 16.44 | 10.42 | 0.98 | 85201.86 |
| 13 | 6.39 | 2.46 | 52.01 | 1.63 | 16.79 | 10.23 | 0.98 | 86144.21 |
| 14 | 4.54 | 5.96 | 47.58 | 2.05 | 15.88 | 10.81 | 0.97 | 82332.74 |
| 15 | 0.73 | 3.52 | 50.31 | 1.82 | 15.51 | 11.26 | 0.98 | 79421.05 |
| 16 | 1.34 | 2.95 | 51.40 | 1.43 | 16.22 | 10.61 | 0.99 | 83815.96 |
| 17 | 4.01 | 3.85 | 56.81 | 1.43 | 16.44 | 10.54 | 0.99 | 84288.82 |
| 18 | 3.57 | 5.27 | 46.89 | 1.48 | 16.84 | 10.24 | 0.99 | 86537.92 |
| 19 | 1.44 | 5.18 | 52.41 | 1.54 | 16.40 | 10.51 | 0.99 | 84204.73 |
| 20 | 8.43 | 5.31 | 47.54 | 2.39 | 15.88 | 10.51 | 0.99 | 84859.63 |
| 21 | 4.28 | 9.30 | 50.56 | 2.50 | 15.37 | 10.52 | 0.99 | 85214.24 |
| 22 | 0.74 | 4.37 | 59.70 | 1.48 | 16.99 | 10.46 | 0.99 | 84184.62 |
| 23 | 0.80 | 5.48 | 56.91 | 1.50 | 18.04 | 9.98 | 0.98 | 86920.55 |
| 監測時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 超限次數 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 有效時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 平均值 | 5.41 | 4.83 | 53.88 | 2.09 | 16.23 | 10.51 | 0.99 | 84809.79 |
| 最大值 | 9.75 | 9.30 | 64.09 | 3.14 | 18.04 | 11.26 | 1.01 | 87959.55 |
| 發生時間 | 8 | 21 | 6 | 1 | 23 | 15 | | 10 |
| 最小值 | 0.73 | 2.05 | 44.52 | 1.43 | 15.21 | 9.98 | 0.97 | 79421.05 |
| 發生時間 | 15 | 12 | 9 | 16 | 9 | 23 | | 15 |
| 零點偏移(率) | -0.01 % | -0.07 % | -0.27 % | 0.00 % | | 0.06 | | -0.10 % |
| 全幅偏移(率) | 0.02 % | 0.56 % | 0.21 % | -0.03 % | | -0.08 | | 0.00 % |
| 有效比率 | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % |
| 備註 | | | | | | | | |

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月13日

| 項目 | #3-HCl_C | #3-CO_C | #3-NOx_C | #3-SO2_C | #3-H2O | #3-O2_C | #3-OPAC | #3-FLOW_C |
|---------|----------|----------|----------|----------|----------|----------|----------|-----------|
| 單位 | ppm | ppm | ppm | ppm | % | % | % | m3/Hour |
| 小時\限標 | 60.00 | 150.00 | 220.00 | 150.00 | 100.00 | 25.00 | 10.00 | 999999.00 |
| 0 | 5.84 | 7.69 | 40.37 | 1.68 | 16.20 | 10.35 | 0.93 | 77210.58 |
| 1 | 4.98 | 5.99 | 44.66 | 1.63 | 15.46 | 10.70 | 0.93 | 76158.26 |
| 2 | 9.46 | 2.36 | 49.86 | 3.28 | 13.78 | 10.41 | 0.94 | 77103.94 |
| 3 | 7.86 | 2.30 | 54.85 | 3.03 | 13.20 | 10.96 | 0.94 | 75700.10 |
| 4 | 8.97 | 6.02 | 53.56 | 2.00 | 15.74 | 10.61 | 0.94 | 79832.80 |
| 5 | 8.80 | 7.22 | 49.55 | 2.46 | 14.97 | 10.53 | 0.94 | 80202.85 |
| 6 | 7.56 | 5.31 | 62.49 | 3.79 | 15.57 | 10.14 | 0.93 | 81549.23 |
| 7 | 3.99 | 6.80 | 47.51 | 1.93 | 13.89 | 11.45 | 0.89 | 70075.43 |
| 8 | 6.64 | 4.30 | 54.60 | 1.19 | 16.61 | 10.30 | 0.90 | 81543.25 |
| 9 | 8.56 | 3.58 | 56.94 | 2.60 | 13.53 | 11.22 | 0.91 | 78162.26 |
| 10 | 8.39 | 5.81 | 49.05 | 2.11 | 14.64 | 10.59 | 0.91 | 81544.54 |
| 11 | 2.42 | 4.04 | 57.59 | 2.41 | 12.23 | 11.73 | 0.91 | 70420.88 |
| 12 | 4.61 | 7.95 | 43.25 | 1.58 | 13.87 | 10.90 | 0.90 | 73865.10 |
| 13 | 4.82 | 3.27 | 50.36 | 1.75 | 13.63 | 11.14 | 0.90 | 73544.18 |
| 14 | 2.76 | 3.57 | 56.43 | 1.14 | 15.41 | 10.83 | 0.91 | 73584.82 |
| 15 | 4.67 | 4.53 | 46.89 | 1.70 | 14.42 | 10.92 | 0.91 | 73203.13 |
| 16 | 2.55 | 4.17 | 53.80 | 1.27 | 14.82 | 11.12 | 0.91 | 74408.45 |
| 17 | 1.29 | 3.71 | 45.03 | 0.79 | 15.57 | 10.82 | 0.91 | 80566.17 |
| 18 | 2.62 | 4.37 | 54.21 | 0.82 | 15.35 | 11.00 | 0.93 | 78511.68 |
| 19 | 0.78 | 5.52 | 50.25 | 0.74 | 15.91 | 10.81 | 0.91 | 79490.21 |
| 20 | 7.95 | 10.93 | 48.05 | 1.36 | 15.55 | 10.70 | 0.91 | 79100.31 |
| 21 | 4.04 | 4.75 | 57.25 | 1.26 | 15.86 | 10.99 | 0.92 | 78296.22 |
| 22 | 5.82 | 4.97 | 50.34 | 1.25 | 15.10 | 11.14 | 0.91 | 78502.10 |
| 23 | 8.11 | 5.12 | 56.76 | 1.32 | 15.77 | 11.31 | 0.91 | 76916.57 |
| 監測時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 超限次數 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 有效時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 平均值 | 5.56 | 5.18 | 51.40 | 1.80 | 14.88 | 10.86 | 0.92 | 77062.21 |
| 最大值 | 9.46 | 10.93 | 62.49 | 3.79 | 16.61 | 11.73 | 0.96 | 81549.23 |
| 發生時間 | 2 | 20 | 6 | 6 | 8 | 11 | | 6 |
| 最小值 | 0.78 | 2.30 | 40.37 | 0.74 | 12.23 | 10.14 | 0.89 | 70075.43 |
| 發生時間 | 19 | 3 | 0 | 19 | 11 | 6 | | 7 |
| 零點偏移(率) | -0.22 % | -0.03 % | -0.11 % | 0.00 % | | 0.02 | | 0.00 % |
| 全幅偏移(率) | 0.01 % | -0.03 % | -0.01 % | 0.04 % | | 0.31 | | 0.20 % |
| 有效比率 | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % |
| 備註 | | | | | | | | |