

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 113年04月26日

報表日期: 113年04月26日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.92	7.88	65.47	1.35	18.10	11.71	0.99	80233.84
1	1.33	8.12	48.21	0.75	19.33	11.91	0.99	77562.58
2	3.61	8.84	65.71	0.65	17.71	12.30	0.99	75497.97
3	4.23	9.36	62.24	1.08	16.77	12.56	0.99	74385.86
4	8.41	7.13	59.40	0.97	18.50	11.30	0.98	83348.49
5	10.21	5.90	62.74	0.72	19.32	10.81	0.97	86655.04
6	9.53	5.31	57.49	0.69	18.51	11.04	0.97	85436.71
7	3.12	5.93	56.37	0.61	17.04	12.22	0.97	76764.62
8	6.63	5.37	59.96	0.60	17.38	12.00	0.99	78393.70
9	8.59	5.39	50.99	0.78	17.99	11.39	0.98	82279.07
10	7.17	5.95	61.30	0.42	17.94	11.93	0.97	78264.81
11	3.78	6.43	55.68	0.39	17.37	12.13	0.97	77098.25
12	9.54	5.56	44.74	0.64	18.23	11.10	0.98	85314.68
13	8.69	5.39	38.51	1.22	16.57	11.68	0.96	81473.97
14	10.07	9.66	34.06	2.98	15.22	12.18	0.97	78455.35
15	11.73	2.88	39.33	1.93	16.20	11.83	0.98	81171.79
16	9.16	2.84	42.45	0.80	17.78	11.60	1.01	81422.37
17	9.63	2.79	41.00	0.57	18.24	11.10	1.01	85418.71
18	9.18	3.23	47.02	0.89	17.84	11.93	0.98	78789.06
19	9.80	2.84	51.51	1.25	17.75	11.21	0.98	84803.24
20	10.25	2.75	48.27	1.28	16.83	11.35	0.98	84734.95
21	11.81	4.86	45.94	1.94	16.35	11.60	0.99	82991.82
22	10.41	6.11	59.82	1.29	16.40	11.75	0.99	81197.57
23	8.92	8.21	51.87	2.42	14.70	12.41	0.99	77413.73
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.07	5.78	52.09	1.09	17.42	11.71	0.98	80796.17
最 大 值	11.81	9.66	65.71	2.98	19.33	12.56	1.02	86655.04
發生時間	21	14	2	14	1	3		5
最 小 值	1.33	2.75	34.06	0.39	14.70	10.81	0.95	74385.86
發生時間	1	20	14	11	23	5		3
零點偏移(率)	0.00 %	-0.01 %	-0.01 %	-0.12 %		-0.11		0.00 %
全幅偏移(率)	0.00 %	1.10 %	-0.07 %	0.75 %		-0.15		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A 報表日期: 113年04月26日

報表日期: 113年04月26日

項目 單位 小時\限標	#2-HCl_C ppm	#2-CO_C ppm	#2-NOx_C ppm	#2-SO2_C ppm	#2-H2O %	#2-O2_C %	#2-OPAC %	#2-FLOW_C m3/Hour
0	6.76	4.60	49.25	1.18	18.82	10.90	1.05	80915.87
1	5.76	5.24	55.93	1.81	18.24	11.10	1.05	79596.41
2	8.67	5.04	60.50	1.71	17.10	11.42	1.05	78134.54
3	9.04	4.58	57.85	1.64	18.01	11.27	1.06	79065.66
4	9.69	5.19	50.12	1.79	17.63	11.25	1.04	79290.90
5	7.65	4.69	51.26	2.28	17.20	11.27	1.04	79513.02
6	6.13	4.39	47.63	1.33	17.85	11.16	1.02	77814.86
7	8.47	4.68	49.89	2.07	16.34	11.62	1.02	77195.42
8	2.23	4.69	49.06	1.60	16.83	11.84	1.02	75301.91
9	6.26	5.62	44.77	2.32	16.41	11.46	0.99	78182.82
10	8.92	7.25	48.15	3.34	13.80	12.36	1.02	73018.41
11	6.09	5.15	48.63	2.20	15.96	11.85	1.01	76037.62
12	2.33	8.55	63.61	2.02	14.58	13.76	1.37	61137.45
13	6.10	2.25	31.56	0.58	19.38	10.12	1.04	86412.50
14	9.88	3.50	44.05	2.19	18.15	10.95	1.02	80700.53
15	7.30	5.07	55.08	3.70	15.80	11.55	1.01	78374.45
16	8.35	3.85	61.73	1.35	19.44	10.52	0.99	83149.73
17	8.14	3.87	52.64	1.69	18.58	10.66	0.98	82561.14
18	8.32	3.88	66.73	1.68	17.98	11.18	0.98	79228.62
19	9.83	3.58	42.56	2.42	17.93	10.54	0.99	84964.03
20	9.26	3.36	43.37	1.57	19.05	10.30	0.99	85745.04
21	10.07	4.09	44.30	2.06	17.95	10.86	1.00	82283.12
22	10.19	4.99	50.78	3.37	17.76	11.26	0.99	78964.12
23	8.16	4.65	54.98	1.28	17.75	11.21	1.00	79633.15
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.65	4.70	51.02	1.97	17.44	11.27	1.03	79050.89
最 大 值	10.19	8.55	66.73	3.70	19.44	13.76	1.90	86412.50
發生時間	22	12	18	15	16	12		13
最 小 值	2.23	2.25	31.56	0.58	13.80	10.12	0.97	61137.45
發生時間	8	13	13	13	10	13		12
零點偏移(率)	-0.12 %	-0.01 %	-0.02 %	-0.14 %		-0.08		-0.10 %
全幅偏移(率)	0.14 %	-0.08 %	0.54 %	0.40 %		-0.31		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月26日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	0.98	6.68	50.47	0.20	18.80	10.56	0.99	79969.02
1	2.42	7.79	56.45	0.31	19.15	10.65	0.99	80192.93
2	1.41	8.73	60.40	0.19	16.67	12.00	1.00	70659.28
3	1.42	5.23	59.21	0.43	16.92	12.41	1.09	68217.70
4	2.29	5.34	43.21	0.21	19.06	10.21	1.00	83339.76
5	3.39	5.98	46.09	0.47	17.76	10.38	1.00	83275.72
6	5.84	2.66	54.74	0.54	17.39	10.82	1.01	81020.40
7	1.47	5.43	45.98	0.21	19.34	9.94	1.04	76070.77
8	5.00	4.68	43.54	0.27	17.79	10.52	1.03	81651.42
9	6.94	10.64	45.27	0.41	17.19	10.62	1.04	80361.10
10	1.31	8.09	38.59	0.40	15.89	10.69	1.01	76154.98
11	3.57	5.21	40.30	0.42	17.57	10.08	1.01	80009.62
12	1.18	4.90	45.01	0.18	20.45	9.61	1.04	83893.94
13	1.26	6.20	46.87	0.20	16.55	11.14	1.04	75284.79
14	1.27	10.31	45.81	0.58	16.84	11.26	1.04	75532.31
15	1.94	5.07	34.96	0.56	16.17	10.51	1.04	77856.27
16	1.84	3.72	45.18	0.39	16.57	10.86	1.04	80852.10
17	1.23	4.75	57.71	0.31	17.43	11.11	1.04	78431.68
18	1.31	2.00	45.55	0.22	18.00	10.26	1.03	84301.00
19	1.59	2.32	52.35	0.27	17.52	10.76	1.03	80089.14
20	6.57	4.44	42.60	0.48	17.75	10.23	1.04	84322.06
21	5.80	6.42	42.27	0.45	17.58	10.30	1.04	80189.58
22	7.36	9.68	42.01	0.35	18.32	9.96	1.03	77882.28
23	2.46	8.91	37.03	0.30	17.17	10.54	1.03	75617.06
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	2.91	6.05	46.73	0.35	17.66	10.64	1.03	78965.62
最 大 值	7.36	10.64	60.40	0.58	20.45	12.41	1.35	84322.06
發生時間	22	9	2	14	12	3		20
最 小 值	0.98	2.00	34.96	0.18	15.89	9.61	0.99	68217.70
發生時間	0	18	15	12	10	12		3
零點偏移(率)	-0.10 %	0.01 %	-0.05 %	-0.15 %		-0.15		-0.10 %
全幅偏移(率)	0.02 %	0.28 %	-0.52 %	0.61 %		-0.22		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								