

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月01日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.81	11.70	55.60	1.63	19.78	10.78	1.28	82941.71
1	9.23	11.78	61.73	1.92	18.75	11.09	1.29	80918.07
2	9.27	11.91	48.50	2.01	20.26	10.66	1.29	83688.89
3	9.42	13.35	33.67	2.79	18.12	10.95	1.29	81643.82
4	9.14	12.77	36.61	2.68	16.65	11.44	1.29	80275.79
5	10.19	12.81	44.03	3.26	17.15	11.32	1.29	84421.64
6	9.82	14.39	37.39	2.47	18.02	11.02	1.29	83807.93
7	9.26	14.24	31.72	2.67	17.67	11.08	1.28	83252.83
8	9.51	11.39	49.91	1.52	16.86	11.24	1.29	82759.80
9	8.81	11.64	49.64	1.14	17.62	11.24	1.29	81821.38
10	9.12	11.85	45.24	1.48	16.69	11.41	1.29	81236.12
11	9.39	11.78	54.18	1.69	15.71	11.69	1.29	79347.14
12	8.98	11.67	49.64	1.74	15.83	11.59	1.29	79484.97
13	13.86	12.07	47.43	1.93	15.56	11.47	1.29	80788.82
14	10.01	12.05	52.15	1.72	15.68	11.60	1.30	80147.03
15	10.21	12.31	55.67	3.67	13.77	11.86	1.29	78876.04
16	9.15	12.68	52.08	3.70	14.90	11.48	1.29	81044.42
17	12.42	11.65	50.36	3.28	15.87	11.27	1.30	83495.61
18	9.52	12.38	54.18	1.72	17.14	11.28	1.30	81362.51
19	10.85	11.89	63.11	1.88	17.75	10.63	1.29	86278.58
20	9.38	12.05	39.85	2.62	16.18	11.18	1.28	83435.75
21	11.16	11.83	48.75	2.78	17.38	10.88	1.28	85523.27
22	8.51	11.89	41.80	1.64	16.02	11.60	1.27	80863.62
23	9.70	12.04	49.94	2.41	16.59	11.66	1.28	78837.97
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.82	12.26	48.05	2.26	16.91	11.27	1.29	81927.24
最大值	13.86	14.39	63.11	3.70	20.26	11.86	1.33	86278.58
發生時間	13	6	19	16	2	15		19
最小值	8.51	11.39	31.72	1.14	13.77	10.63	1.27	78837.97
發生時間	22	8	7	9	15	19		23
零點偏移(率)	-0.02 %	-0.05 %	-0.07 %	-0.00 %		-0.06	-0.01	0.20 %
全幅偏移(率)	-2.14 %	-1.38 %	-0.45 %	-0.18 %		0.20	0.04	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月01日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.10	11.68	54.35	0.61	18.48	11.46	0.84	67049.22
1	9.45	10.18	54.49	0.76	18.74	11.76	0.84	63640.59
2	7.46	10.86	41.60	0.99	19.39	11.41	0.83	67895.92
3	9.24	12.40	58.01	0.86	18.64	12.15	0.84	62734.04
4	10.89	9.43	48.09	0.61	19.79	10.58	0.83	77613.37
5	9.32	15.41	56.20	1.10	17.44	11.90	0.84	70990.45
6	14.00	22.74	59.01	0.88	18.11	11.13	0.83	71043.89
7	9.88	12.03	50.27	1.16	17.70	11.71	0.81	68034.25
8	10.52	12.42	51.94	1.01	17.85	11.55	0.80	71999.60
9	13.00	10.76	52.72	1.48	17.68	11.42	0.81	72957.58
10	12.39	10.22	50.71	0.82	18.24	11.35	0.81	70729.84
11	9.47	8.74	49.87	1.08	17.96	11.45	0.81	72247.25
12	9.95	9.80	56.91	0.74	18.29	11.52	0.81	72478.61
13	9.24	9.85	51.98	0.93	18.07	11.47	0.81	72408.54
14	9.96	8.00	54.75	0.97	17.87	11.40	0.81	71377.46
15	10.19	8.71	51.08	1.04	17.63	11.48	0.81	72454.86
16	12.90	48.82	61.86	1.99	16.50	11.74	0.81	68805.95
17	12.56	12.03	50.63	1.90	15.81	11.94	0.80	68247.56
18	12.31	12.61	61.82	1.70	15.85	11.90	0.81	67224.55
19	11.20	9.77	58.76	1.24	16.39	11.34	0.83	70778.40
20	11.42	7.87	60.69	1.56	15.79	11.82	0.83	71291.90
21	9.57	8.32	62.45	0.80	17.73	11.27	0.83	70787.20
22	10.29	9.06	63.57	0.78	17.17	11.45	0.83	68292.96
23	9.47	9.87	63.54	1.10	16.82	12.02	0.82	64992.18
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.66	12.57	55.22	1.09	17.66	11.55	0.82	69836.51
最大值	14.00	48.82	63.57	1.99	19.79	12.15	0.86	77613.37
發生時間	6	16	22	16	4	3		4
最小值	7.46	7.87	41.60	0.61	15.79	10.58	0.79	62734.04
發生時間	2	20	2	0	20	4		3
零點偏移(率)	-0.12 %	-0.01 %	-0.05 %	-0.01 %		-0.11	-0.06	0.00 %
全幅偏移(率)	0.17 %	0.94 %	-0.13 %	0.35 %		-0.26	0.31	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月01日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.07	11.19	52.31	2.98	18.41	9.37	1.36	72503.28
1	9.27	11.27	53.12	2.89	20.13	8.93	1.35	74988.43
2	9.50	11.76	48.80	2.78	20.64	9.50	1.36	76556.34
3	9.69	11.87	50.80	3.27	18.22	9.80	1.36	75816.78
4	9.16	11.48	53.76	3.07	18.05	10.03	1.36	76030.91
5	8.96	11.34	53.12	3.08	18.05	9.94	1.36	76207.65
6	8.81	11.68	53.76	3.01	17.63	9.95	1.38	78575.22
7	9.82	12.94	56.52	3.00	16.87	10.32	1.36	82218.56
8	9.84	11.65	61.24	1.77	16.19	10.55	1.36	77146.03
9	9.22	11.15	61.39	1.57	17.80	9.94	1.37	78149.72
10	9.81	11.55	57.29	1.67	16.85	10.11	1.38	76164.15
11	9.00	11.32	54.68	1.65	15.52	10.25	1.36	74947.13
12	9.23	11.37	58.91	1.61	16.14	10.24	1.36	75661.07
13	8.87	11.39	60.25	1.61	16.60	10.26	1.36	76156.74
14	9.54	11.88	60.08	1.88	14.87	10.65	1.36	74323.19
15	8.53	11.87	57.41	3.05	14.69	10.21	1.38	74749.14
16	9.93	12.07	53.30	2.22	15.97	9.35	1.36	78475.27
17	10.42	10.91	50.88	2.35	16.68	8.70	1.35	77417.80
18	11.92	10.43	49.96	2.39	16.56	8.82	1.35	76112.29
19	9.22	10.22	46.51	1.88	17.34	8.84	1.36	77425.83
20	10.77	11.29	42.22	2.39	17.97	8.71	1.36	78797.34
21	9.02	11.20	40.64	2.19	18.62	8.66	1.36	79966.69
22	9.37	10.56	41.12	1.42	17.38	9.29	1.37	74888.74
23	9.16	11.44	49.72	2.89	19.20	8.98	1.37	76654.78
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.51	11.41	52.82	2.36	17.35	9.64	1.36	76663.88
最大值	11.92	12.94	61.39	3.27	20.64	10.65	1.42	82218.56
發生時間	18	7	9	3	2	14		7
最小值	8.53	10.22	40.64	1.42	14.69	8.66	1.34	72503.28
發生時間	15	19	21	22	15	21		0
零點偏移(率)	-0.01 %	0.00 %	-0.03 %	-0.00 %		-0.10	-0.01	0.10 %
全幅偏移(率)	-1.69 %	0.68 %	-0.44 %	0.32 %		0.16	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								