

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月13日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.91	1.23	64.95	3.13	19.72	11.73	1.41	71699.30
1	10.83	1.00	54.67	2.89	20.12	11.35	1.41	74485.96
2	10.57	2.04	48.78	2.86	19.82	11.22	1.41	75509.77
3	9.52	1.85	53.40	3.29	18.81	11.72	1.40	73437.22
4	10.21	2.24	60.49	3.07	19.79	11.47	1.38	74058.81
5	3.78	4.05	51.47	2.39	19.45	11.91	1.41	77068.94
6	10.19	2.89	50.87	2.32	19.59	11.49	1.41	73744.90
7	6.96	2.04	54.81	2.46	18.82	12.07	1.40	70327.59
8	9.72	1.46	55.08	2.41	19.04	11.81	1.41	72226.00
9	8.01	1.04	53.94	2.33	19.69	11.83	1.42	71318.91
10	10.84	1.74	48.35	2.21	19.31	11.29	1.40	75250.09
11	11.20	1.76	50.08	2.35	18.91	11.57	1.41	73466.58
12	7.56	4.10	47.63	2.48	17.60	11.91	1.39	71488.01
13	9.70	1.56	51.04	2.38	18.05	11.78	1.42	72047.55
14	10.31	1.91	48.57	2.52	18.12	11.63	1.41	72899.85
15	11.33	5.18	50.21	2.69	17.60	11.89	1.41	71731.98
16	11.30	6.41	51.20	2.62	17.66	11.76	1.41	72603.16
17	11.14	2.88	55.68	2.43	17.97	11.95	1.42	70842.69
18	7.83	5.00	55.26	2.27	18.70	11.76	1.43	72058.69
19	9.60	2.81	56.62	2.15	19.72	11.35	1.42	74049.34
20	7.82	3.94	58.65	2.33	19.03	11.98	1.41	69986.11
21	8.73	3.31	63.65	2.22	19.38	11.58	1.39	73176.88
22	8.58	8.45	51.57	2.61	18.06	12.34	1.39	68275.80
23	8.95	3.30	59.87	2.18	19.41	11.53	1.42	73581.68
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.36	3.01	54.04	2.52	18.93	11.70	1.41	72722.33
最大值	11.33	8.45	64.95	3.29	20.12	12.34	1.44	77068.94
發生時間	15	22	0	3	1	22		5
最小值	3.78	1.00	47.63	2.15	17.60	11.22	1.36	68275.80
發生時間	5	1	12	19	12	2		22
零點偏移(率)	-1.00 %	-0.11 %	-0.21 %	0.00 %		-0.02	0.00	0.00 %
全幅偏移(率)	0.54 %	1.44 %	0.49 %	-0.12 %		0.11	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月13日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.62	1.41	55.42	2.09	17.56	10.65	1.30	65207.99
1	10.99	3.41	54.21	2.34	17.05	10.84	1.31	64212.49
2	10.63	1.69	50.24	2.74	16.32	10.71	1.33	64447.47
3	10.09	0.96	53.42	2.19	17.95	10.62	1.34	65448.68
4	9.70	2.89	52.10	2.08	18.02	10.59	1.35	66010.14
5	10.30	3.13	50.66	2.47	17.38	10.78	1.34	64267.05
6	14.01	2.73	50.47	2.78	17.52	10.58	1.40	65923.16
7	9.59	0.75	52.97	2.35	17.11	10.72	1.39	65469.08
8	9.90	1.41	52.56	2.20	17.03	10.67	1.41	65954.35
9	9.67	1.91	48.63	2.34	16.21	10.89	1.37	64878.34
10	10.70	2.47	63.27	2.07	17.20	10.76	1.39	64855.39
11	8.76	7.38	53.59	2.39	15.32	11.17	1.37	63385.95
12	7.88	4.58	56.09	2.28	15.79	11.08	1.38	63436.46
13	16.78	6.32	61.25	2.79	15.31	11.22	1.37	62541.77
14	8.90	13.55	58.09	10.58	14.66	11.43	1.33	62005.73
15	8.96	4.53	54.18	6.65	17.47	10.22	1.33	63553.48
16	9.76	1.24	58.85	1.80	18.18	10.65	1.33	65168.07
17	9.82	2.63	51.69	1.68	18.81	10.48	1.34	65274.64
18	10.41	2.27	51.13	1.67	18.67	10.45	1.37	65688.62
19	9.30	9.48	52.78	1.84	18.45	10.38	1.38	65239.10
20	10.09	2.45	52.00	2.17	17.40	10.78	1.36	62616.76
21	12.29	3.30	51.08	2.38	17.18	10.35	1.35	65943.62
22	9.76	2.54	54.56	2.21	17.40	10.71	1.33	63124.68
23	10.77	3.22	51.58	2.19	16.85	10.60	1.34	63394.20
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.40	3.59	53.78	2.76	17.12	10.72	1.35	64501.97
最大值	16.78	13.55	63.27	10.58	18.81	11.43	1.41	66010.14
發生時間	13	14	10	14	17	14		4
最小值	7.88	0.75	48.63	1.67	14.66	10.22	1.28	62005.73
發生時間	12	7	9	18	14	15		14
零點偏移(率)	-0.81 %	-0.11 %	-0.11 %	-0.03 %		-0.02	0.00	0.00 %
全幅偏移(率)	-1.96 %	1.49 %	0.73 %	0.21 %		0.00	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月13日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.86	1.59	58.80	2.71	16.39	10.76	1.72	85115.93
1	12.68	5.87	61.84	3.25	17.43	10.71	1.72	86052.96
2	16.25	1.65	55.75	3.74	15.21	11.07	1.71	82592.12
3	11.58	1.43	62.62	3.01	16.15	10.91	1.70	84574.72
4	11.08	3.43	58.93	2.82	16.18	10.86	1.70	85871.69
5	9.06	6.20	65.56	2.73	17.22	10.79	1.70	85293.51
6	11.11	5.20	50.19	2.93	15.96	10.59	1.69	86017.83
7	9.69	1.41	52.56	2.40	16.48	10.54	1.72	86128.44
8	11.94	2.70	51.85	2.57	15.73	10.65	1.73	83934.10
9	11.13	1.87	54.97	2.84	14.95	10.91	1.77	81645.90
10	10.63	2.82	54.41	2.51	15.73	10.61	1.77	83397.55
11	9.64	1.42	54.16	2.48	15.26	10.72	1.76	82129.45
12	9.53	6.80	54.54	2.92	14.37	10.98	1.76	78305.04
13	6.99	1.10	56.86	2.57	15.12	10.79	1.76	79181.80
14	15.49	4.27	50.87	4.14	14.56	10.65	1.74	78931.35
15	13.16	4.62	54.20	5.77	14.39	11.09	1.74	79075.60
16	11.41	2.67	54.79	3.03	15.76	10.76	1.74	79154.76
17	15.70	1.29	56.70	2.41	16.87	10.50	1.76	82531.71
18	9.50	1.08	54.87	2.14	17.42	10.50	1.75	83095.81
19	10.00	3.35	51.65	2.19	17.74	10.35	1.77	85238.40
20	10.14	2.69	52.68	2.32	16.37	10.78	1.74	83659.75
21	14.75	6.77	58.24	3.48	15.28	11.33	1.74	82413.21
22	15.66	2.49	58.40	3.54	14.74	11.53	1.73	80725.93
23	12.29	2.75	54.02	3.32	15.66	10.85	1.75	80861.31
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	11.72	3.14	55.81	2.99	15.87	10.80	1.74	82747.04
最大值	16.25	6.80	65.56	5.77	17.74	11.53	1.78	86128.44
發生時間	2	12	5	15	19	22		7
最小值	6.99	1.08	50.19	2.14	14.37	10.35	1.67	78305.04
發生時間	13	18	6	18	12	19		12
零點偏移(率)	-0.42 %	-0.06 %	-0.17 %	-0.04 %		0.00	0.00	0.00 %
全幅偏移(率)	-1.47 %	1.02 %	0.00 %	0.04 %		0.02	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								