

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月04日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.11	1.47	58.85	1.89	19.73	11.27	1.47	77970.83
1	5.18	1.18	59.68	1.84	19.75	11.34	1.46	77083.73
2	8.47	1.00	61.87	1.79	20.11	10.91	1.46	79716.51
3	8.94	1.61	58.29	2.26	18.27	11.76	1.46	74722.21
4	5.99	2.14	65.55	2.34	17.94	12.47	1.50	69542.23
5	1.45	14.28	41.48	4.09	17.06	13.20	1.56	78937.52
6	7.29	3.96	53.28	3.26	19.63	11.07	1.50	79530.94
7	13.84	6.76	46.98	3.64	18.07	11.31	1.48	78337.54
8	14.16	3.24	57.15	3.74	17.72	11.47	1.48	77013.86
9	12.97	3.30	50.04	3.66	17.80	11.41	1.44	77387.23
10	10.60	1.39	49.68	3.62	17.56	11.67	1.44	76323.37
11	10.76	1.06	62.10	3.41	18.41	11.43	1.47	77360.72
12	12.04	1.64	55.59	3.52	18.38	11.50	1.49	76757.38
13	12.08	1.03	67.51	3.31	19.01	11.24	1.48	78267.49
14	12.37	8.39	54.67	3.57	18.06	11.58	1.47	76113.78
15	12.35	10.87	47.11	3.91	16.38	11.87	1.47	74639.49
16	6.56	1.15	65.35	3.55	18.82	12.05	1.50	72078.70
17	7.23	1.05	53.38	3.30	19.80	11.47	1.48	75808.65
18	7.94	0.80	51.52	2.89	20.60	10.89	1.46	79117.44
19	9.66	1.92	48.01	3.32	19.08	11.21	1.47	77976.03
20	12.00	3.11	45.32	3.38	18.68	11.22	1.48	78499.29
21	9.88	4.42	49.42	3.29	18.79	11.13	1.47	78829.43
22	11.65	1.33	60.59	3.51	18.70	11.43	1.49	76275.19
23	11.14	1.33	61.86	3.35	19.21	11.39	1.51	76212.55
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.57	3.27	55.22	3.19	18.65	11.51	1.48	76854.25
最大值	14.16	14.28	67.51	4.09	20.60	13.20	1.60	79716.51
發生時間	8	5	13	5	18	5		2
最小值	1.45	0.80	41.48	1.79	16.38	10.89	1.43	69542.23
發生時間	5	18	5	2	15	18		4
零點偏移(率)	0.00 %	-0.00 %	-0.03 %	-0.00 %		0.04	0.00	0.00 %
全幅偏移(率)	3.37 %	-0.38 %	0.01 %	0.13 %		0.42	-0.03	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月04日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.76	3.15	57.49	2.32	15.54	10.92	1.35	64910.28
1	7.39	3.80	61.66	2.04	17.68	10.58	1.34	66557.96
2	8.36	1.63	61.56	2.25	16.40	10.67	1.34	66004.53
3	10.96	4.65	61.82	2.47	16.90	10.51	1.33	67432.53
4	8.45	0.84	61.33	2.43	15.33	11.09	1.33	64720.98
5	8.96	0.81	71.24	2.08	16.61	10.76	1.33	65735.04
6	11.45	3.86	43.61	2.65	16.38	10.76	1.40	66885.60
7	12.22	5.26	57.72	2.90	14.42	11.15	1.40	64250.66
8	10.70	1.53	61.20	2.74	14.84	11.05	1.40	65123.10
9	10.61	1.40	57.98	2.89	14.13	11.43	1.39	62767.27
10	10.77	0.56	63.63	2.83	15.28	10.90	1.42	65344.57
11	11.89	2.49	59.41	3.36	14.82	11.14	1.46	63418.29
12	9.78	3.12	59.39	2.69	15.45	10.68	1.45	64088.65
13	10.18	2.80	63.34	2.57	15.92	10.82	1.45	64113.93
14	9.60	1.75	63.69	2.54	15.33	10.90	1.45	64725.51
15	9.35	0.52	61.93	2.16	16.72	10.54	1.45	66430.50
16	10.14	11.14	51.22	2.49	16.59	9.67	1.44	65023.26
17	10.83	2.22	54.31	2.31	16.68	10.68	1.45	65886.08
18	11.16	3.99	52.35	2.53	15.66	10.80	1.46	65357.34
19	9.53	1.10	55.34	2.07	16.82	10.49	1.46	65027.68
20	9.93	0.85	54.34	2.35	15.94	10.69	1.46	63968.97
21	9.06	14.06	54.55	2.38	16.00	10.22	1.46	64936.09
22	7.79	2.11	62.67	2.29	17.38	10.45	1.46	64160.13
23	10.03	3.52	49.17	2.10	17.36	9.77	1.45	65744.52
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.95	3.21	58.37	2.48	16.01	10.69	1.41	65108.89
最大值	12.22	14.06	71.24	3.36	17.68	11.43	1.48	67432.53
發生時間	7	21	5	11	1	9		3
最小值	7.39	0.52	43.61	2.04	14.13	9.67	1.33	62767.27
發生時間	1	15	6	1	9	16		9
零點偏移(率)	-0.04 %	0.00 %	-0.01 %	0.00 %		-0.01	0.00	0.00 %
全幅偏移(率)	0.61 %	0.14 %	0.27 %	0.08 %		0.33	-0.06	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月04日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.43	1.20	62.36	2.26	15.57	10.39	1.76	86367.81
1	12.78	1.47	68.58	2.63	15.76	11.25	1.75	85827.10
2	7.08	1.75	68.44	2.59	15.32	11.45	1.75	83746.96
3	9.61	1.16	59.92	2.21	16.77	10.54	1.76	87789.20
4	5.89	2.25	62.99	2.45	14.92	10.80	1.75	84215.05
5	7.29	4.59	62.09	2.12	17.72	10.21	1.75	87646.89
6	13.04	4.46	67.23	2.63	15.64	11.09	1.75	85427.22
7	9.22	6.84	62.47	2.65	14.35	11.24	1.73	82476.35
8	13.81	6.56	62.88	2.74	14.42	10.99	1.72	84480.94
9	10.04	10.09	55.02	4.22	14.02	10.90	1.72	80940.00
10	10.42	2.91	55.86	3.26	13.23	10.61	1.74	77538.39
11	12.16	1.26	63.97	3.11	14.07	11.00	1.75	78820.74
12	16.39	3.43	54.93	2.90	15.16	10.63	1.72	83607.71
13	13.13	1.56	64.65	2.87	14.64	10.67	1.73	81541.13
14	6.36	1.28	58.54	2.49	14.57	10.78	1.75	79722.83
15	9.53	4.50	62.76	2.36	15.41	10.36	1.76	83132.77
16	13.30	3.73	58.40	2.67	15.69	10.36	1.75	81659.89
17	12.07	1.85	55.77	2.42	15.52	10.24	1.75	82421.84
18	13.74	2.22	65.51	2.87	15.07	10.36	1.75	81990.35
19	11.48	6.00	63.10	3.62	12.80	11.28	1.75	77788.76
20	6.96	5.42	59.82	2.58	14.59	10.56	1.73	81217.52
21	14.46	1.76	59.30	2.78	14.61	10.62	1.75	84075.36
22	13.21	4.74	62.22	2.88	14.41	10.62	1.73	82598.62
23	10.00	2.01	61.80	2.72	14.09	10.95	1.73	80753.86
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.89	3.46	61.61	2.75	14.93	10.75	1.74	82741.14
最大值	16.39	10.09	68.58	4.22	17.72	11.45	1.80	87789.20
發生時間	12	9	1	9	5	2		3
最小值	5.89	1.16	54.93	2.12	12.80	10.21	1.72	77538.39
發生時間	4	3	12	5	19	5		10
零點偏移(率)	-0.01 %	0.00 %	-0.04 %	-0.01 %		0.01	0.00	0.00 %
全幅偏移(率)	1.32 %	-0.34 %	-0.28 %	0.02 %		0.55	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								