

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年05月22日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.88	13.55	58.14	1.40	17.92	11.86	1.10	77343.74
1	9.67	13.05	52.69	2.95	17.52	11.50	1.10	80286.20
2	6.94	13.32	52.95	2.79	18.26	11.34	1.11	81071.11
3	4.07	12.97	51.66	3.23	16.63	11.52	1.10	81212.94
4	8.81	13.53	40.70	4.55	16.31	11.90	1.09	78431.34
5	2.81	13.69	58.25	2.20	16.12	12.10	1.14	77834.90
6	13.29	13.58	59.09	3.33	15.60	12.17	1.13	76938.85
7	10.40	14.05	58.47	3.44	14.71	12.30	1.15	76283.73
8	5.48	13.48	59.43	2.45	16.24	12.02	1.16	77438.25
9	7.13	13.52	61.04	3.02	15.30	12.15	1.15	76691.25
10	5.15	13.93	51.19	2.97	14.03	12.30	1.14	75196.34
11	9.89	13.73	54.68	4.09	15.02	12.21	1.14	75484.36
12	10.00	13.56	56.18	1.63	15.00	12.21	1.13	76141.96
13	12.33	13.43	50.92	1.81	15.11	11.93	1.13	78443.11
14	2.47	13.65	64.22	1.42	15.80	12.17	1.16	74866.47
15	10.05	13.32	50.11	2.31	16.29	11.68	1.16	79847.19
16	6.86	13.31	51.66	2.06	16.03	11.90	1.15	78005.62
17	11.43	13.05	56.07	2.14	16.87	11.57	1.15	80537.16
18	9.34	13.36	47.07	2.47	14.90	11.98	1.13	78259.27
19	7.97	13.74	49.41	2.84	14.21	12.28	1.14	76254.68
20	12.50	13.28	56.46	2.35	16.68	11.61	1.14	79952.05
21	8.64	12.88	50.98	2.28	16.85	11.54	1.14	80302.46
22	9.29	13.03	49.57	2.42	15.72	11.76	1.14	79299.18
23	8.15	13.16	52.31	2.02	16.08	11.82	1.15	78314.87
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.27	13.42	53.89	2.59	15.97	11.91	1.13	78101.54
最大值	13.29	14.05	64.22	4.55	18.26	12.30	1.28	81212.94
發生時間	6	7	14	4	2	7		3
最小值	2.47	12.88	40.70	1.40	14.03	11.34	1.09	74866.47
發生時間	14	21	4	0	10	2		14
零點偏移(率)	-0.04 %	-0.02 %	-0.06 %	-0.03 %		-0.18	-0.01	0.30 %
全幅偏移(率)	0.67 %	1.92 %	0.08 %	1.07 %		-0.06	-0.06	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年05月22日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.75	11.96	36.74	1.05	19.03	10.40	1.02	81895.84
1	6.35	11.95	48.37	1.32	19.19	10.49	1.03	80803.13
2	6.05	11.89	42.80	1.60	18.48	10.40	1.02	79944.47
3	6.03	12.65	46.74	2.06	18.52	10.43	1.02	81959.54
4	6.16	12.24	56.55	1.21	18.88	10.61	1.02	80960.98
5	6.23	12.27	48.37	1.97	17.46	10.82	1.02	79108.74
6	5.93	12.28	59.23	2.37	17.14	10.96	0.99	82086.78
7	7.13	12.45	47.76	2.09	16.57	11.11	1.00	75482.76
8	7.85	11.96	49.11	2.00	16.79	10.72	1.02	77986.29
9	0.17	12.34	58.04	2.01	17.27	10.91	1.01	80841.71
10	0.13	12.06	49.91	1.72	17.18	10.69	1.01	81177.68
11	0.13	12.44	50.82	2.10	17.07	10.54	1.00	79924.51
12	0.17	12.22	56.44	2.45	15.36	10.98	1.02	80179.02
13	0.14	12.41	52.48	1.87	16.63	10.72	1.02	79362.55
14	0.32	11.98	57.17	0.99	18.74	10.65	1.01	78866.52
15	0.35	12.08	49.81	0.46	20.06	10.39	1.02	81364.87
16	0.17	12.51	60.88	1.12	17.17	11.21	1.03	78873.97
17	1.32	12.53	64.68	1.97	15.47	11.24	1.02	80625.83
18	1.37	12.26	54.76	1.91	15.80	11.20	1.04	80389.22
19	1.37	12.47	59.57	1.40	17.06	11.24	1.02	79101.08
20	1.58	11.97	64.58	1.28	17.75	10.75	1.02	82151.91
21	2.05	12.03	65.61	1.47	17.15	10.86	1.02	81578.94
22	3.97	12.18	55.00	1.07	17.73	10.95	1.02	79759.00
23	7.68	12.09	50.93	0.63	18.33	10.80	1.02	80314.75
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	3.31	12.22	53.60	1.59	17.53	10.79	1.02	80197.50
最大值	7.85	12.65	65.61	2.45	20.06	11.24	1.06	82151.91
發生時間	8	3	21	12	15	17		20
最小值	0.13	11.89	36.74	0.46	15.36	10.39	0.98	75482.76
發生時間	10	2	0	15	12	15		7
零點偏移(率)	-0.06 %	0.00 %	-0.03 %	-0.00 %		-0.12	-0.01	-0.20 %
全幅偏移(率)	0.18 %	1.07 %	0.13 %	0.76 %		-0.32	0.00	-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年05月22日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.26	12.66	45.39	1.93	19.56	10.28	1.31	72963.42
1	8.45	15.20	38.66	1.82	19.96	9.98	1.31	76493.75
2	7.91	11.47	48.47	2.04	18.69	10.11	1.31	75766.23
3	6.68	12.31	46.28	2.07	16.80	10.96	1.32	68405.80
4	6.58	11.70	40.98	1.67	17.92	10.41	1.36	71912.79
5	7.04	11.33	42.66	1.82	18.28	10.02	1.36	75628.73
6	6.89	11.48	42.58	1.75	17.72	10.24	1.36	74572.95
7	7.44	11.54	65.49	2.10	17.98	10.30	1.33	77053.95
8	7.63	11.65	61.12	1.77	17.53	10.47	1.36	72629.39
9	1.56	11.48	58.59	1.70	17.29	10.34	1.33	73418.88
10	1.48	11.24	54.86	1.82	18.09	9.98	1.36	75214.37
11	1.91	11.41	50.95	1.83	16.79	10.24	1.36	72905.38
12	6.51	11.38	54.05	1.93	17.26	10.13	1.34	73214.52
13	1.68	11.28	52.97	1.65	17.55	10.10	1.35	73590.23
14	4.33	11.58	61.63	2.07	18.21	10.29	1.34	73552.54
15	4.36	11.47	59.88	1.99	19.62	9.96	1.34	76056.07
16	4.52	11.42	51.90	1.82	20.73	9.22	1.36	78389.26
17	4.74	11.65	42.62	1.98	18.55	9.09	1.35	74817.47
18	2.50	12.14	40.45	1.93	17.96	9.36	1.31	72907.11
19	4.40	10.84	47.90	1.93	17.10	9.67	1.31	72997.53
20	2.62	11.58	65.63	1.80	17.40	10.40	1.34	72799.03
21	3.55	11.87	49.62	1.94	18.07	10.55	1.36	72166.53
22	10.81	11.58	57.17	3.07	17.42	10.35	1.36	75390.39
23	6.00	11.83	64.18	2.21	17.65	10.48	1.35	75441.65
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.29	11.75	51.83	1.94	18.09	10.12	1.34	74095.33
最大值	10.81	15.20	65.63	3.07	20.73	10.96	1.39	78389.26
發生時間	22	1	20	22	16	3		16
最小值	1.48	10.84	38.66	1.65	16.79	9.09	1.30	68405.80
發生時間	10	19	1	13	11	17		3
零點偏移(率)	-0.14 %	-0.04 %	-0.04 %	-0.00 %		-0.61	-0.01	-0.10 %
全幅偏移(率)	1.27 %	0.68 %	-0.49 %	1.14 %		0.12	0.04	-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								