

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年05月26日

| 項目 | #1-HCl_C | #1-CO_C | #1-NOx_C | #1-SO2_C | #1-H2O | #1-O2_C | #1-OPAC | #1-FLOW_C |
|---------|----------|----------|----------|----------|----------|----------|----------|-----------|
| 單位 | ppm | ppm | ppm | ppm | % | % | % | m3/Hour |
| 小時\限標 | 60.00 | 150.00 | 220.00 | 150.00 | 100.00 | 25.00 | 10.00 | 999999.00 |
| 0 | 8.29 | 2.42 | 52.25 | 2.92 | 18.01 | 11.13 | 1.33 | 68311.99 |
| 1 | 7.58 | 2.64 | 56.15 | 2.69 | 18.98 | 10.98 | 1.33 | 69563.02 |
| 2 | 8.61 | 2.51 | 63.24 | 2.98 | 18.69 | 10.83 | 1.36 | 71822.41 |
| 3 | 7.37 | 4.71 | 61.29 | 3.89 | 15.75 | 11.96 | 1.37 | 66487.27 |
| 4 | 8.16 | 5.68 | 54.41 | 3.98 | 15.48 | 11.58 | 1.34 | 67545.31 |
| 5 | 9.91 | 1.80 | 56.74 | 4.52 | 15.73 | 11.56 | 1.33 | 75320.78 |
| 6 | 7.85 | 1.93 | 54.61 | 4.04 | 16.33 | 11.09 | 1.30 | 68888.26 |
| 7 | 5.95 | 1.64 | 46.09 | 3.27 | 18.27 | 10.55 | 1.29 | 70116.72 |
| 8 | 4.23 | 1.75 | 58.99 | 2.36 | 20.04 | 10.71 | 1.34 | 72304.11 |
| 9 | 7.07 | 2.02 | 50.80 | 3.27 | 17.37 | 11.15 | 1.33 | 69233.12 |
| 10 | 8.37 | 5.92 | 43.86 | 4.49 | 15.60 | 11.65 | 1.32 | 67040.28 |
| 11 | 6.96 | 7.51 | 54.67 | 5.14 | 14.52 | 12.42 | 1.29 | 64496.23 |
| 12 | 7.92 | 2.31 | 68.25 | 3.49 | 15.91 | 11.65 | 1.32 | 69080.77 |
| 13 | 8.20 | 3.52 | 51.82 | 4.39 | 14.60 | 11.72 | 1.31 | 64953.05 |
| 14 | 8.84 | 2.77 | 51.20 | 4.65 | 16.49 | 11.34 | 1.33 | 67119.94 |
| 15 | 10.40 | 3.42 | 54.93 | 4.50 | 16.30 | 11.23 | 1.33 | 67369.28 |
| 16 | 5.95 | 2.30 | 58.64 | 3.50 | 16.22 | 11.48 | 1.33 | 66042.94 |
| 17 | 7.36 | 2.12 | 52.69 | 3.71 | 16.23 | 11.37 | 1.32 | 67336.21 |
| 18 | 8.16 | 2.35 | 54.67 | 4.06 | 16.36 | 11.24 | 1.28 | 68316.69 |
| 19 | 9.68 | 2.76 | 62.51 | 4.37 | 16.37 | 11.43 | 1.32 | 69284.50 |
| 20 | 8.53 | 2.97 | 51.85 | 4.39 | 15.76 | 11.54 | 1.33 | 69071.93 |
| 21 | 9.34 | 6.59 | 45.40 | 4.59 | 14.77 | 11.59 | 1.33 | 67122.78 |
| 22 | 9.17 | 3.01 | 55.37 | 4.17 | 15.43 | 11.43 | 1.33 | 66875.53 |
| 23 | 6.08 | 2.90 | 63.82 | 3.47 | 16.83 | 11.16 | 1.33 | 68441.16 |
| 監測時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 超限次數 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 有效時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 平均值 | 7.92 | 3.23 | 55.18 | 3.87 | 16.50 | 11.37 | 1.32 | 68422.68 |
| 最大值 | 10.40 | 7.51 | 68.25 | 5.14 | 20.04 | 12.42 | 1.41 | 75320.78 |
| 發生時間 | 15 | 11 | 12 | 11 | 8 | 11 | | 5 |
| 最小值 | 4.23 | 1.64 | 43.86 | 2.36 | 14.52 | 10.55 | 1.28 | 64496.23 |
| 發生時間 | 8 | 7 | 10 | 8 | 11 | 7 | | 11 |
| 零點偏移(率) | -0.01 % | -0.09 % | -0.04 % | -0.02 % | | -0.01 | 0.00 | 0.00 % |
| 全幅偏移(率) | 0.07 % | 0.66 % | -0.25 % | 0.35 % | | -0.06 | 0.00 | 0.20 % |
| 有效比率 | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % |
| 備註 | | | | | | | | |

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年05月26日

| 項目 | #2-HCl_C | #2-CO_C | #2-NOx_C | #2-SO2_C | #2-H2O | #2-O2_C | #2-OPAC | #2-FLOW_C |
|---------|----------|----------|----------|----------|----------|----------|----------|-----------|
| 單位 | ppm | ppm | ppm | ppm | % | % | % | m3/Hour |
| 小時\限標 | 60.00 | 150.00 | 220.00 | 150.00 | 100.00 | 25.00 | 10.00 | 999999.00 |
| 0 | 0.24 | 2.28 | 63.31 | 1.48 | 18.76 | 11.11 | 1.43 | 72353.52 |
| 1 | 0.17 | 2.19 | 43.75 | 1.10 | 20.54 | 9.90 | 1.43 | 80819.07 |
| 2 | 0.31 | 2.13 | 52.05 | 1.27 | 19.73 | 9.67 | 1.45 | 82464.83 |
| 3 | 2.04 | 2.10 | 47.10 | 1.53 | 19.31 | 9.63 | 1.46 | 81548.96 |
| 4 | 4.47 | 4.14 | 47.04 | 2.21 | 17.27 | 9.76 | 1.46 | 78449.01 |
| 5 | 2.74 | 3.06 | 45.68 | 2.16 | 17.34 | 9.55 | 1.46 | 77019.33 |
| 6 | 9.23 | 1.14 | 44.79 | 2.75 | 17.49 | 9.61 | 1.44 | 76697.14 |
| 7 | 5.37 | 1.39 | 43.33 | 1.86 | 18.95 | 9.31 | 1.42 | 78754.50 |
| 8 | 2.62 | 1.67 | 47.89 | 1.19 | 20.97 | 8.96 | 1.40 | 83343.85 |
| 9 | 1.97 | 2.17 | 33.77 | 1.60 | 19.12 | 9.17 | 1.43 | 80438.34 |
| 10 | 7.85 | 3.82 | 33.42 | 2.30 | 18.41 | 9.33 | 1.43 | 79424.59 |
| 11 | 5.10 | 2.81 | 36.95 | 2.26 | 17.55 | 9.52 | 1.41 | 77366.56 |
| 12 | 3.45 | 2.68 | 37.94 | 1.86 | 18.21 | 9.22 | 1.40 | 83131.18 |
| 13 | 5.71 | 1.46 | 51.88 | 2.60 | 16.43 | 10.25 | 1.39 | 79749.03 |
| 14 | 12.23 | 1.58 | 57.36 | 3.13 | 17.08 | 10.04 | 1.39 | 79615.27 |
| 15 | 8.98 | 1.78 | 50.52 | 2.73 | 17.34 | 10.02 | 1.39 | 80010.83 |
| 16 | 5.51 | 1.50 | 50.67 | 2.20 | 17.10 | 10.21 | 1.39 | 81471.92 |
| 17 | 8.32 | 1.78 | 58.54 | 2.41 | 16.95 | 10.35 | 1.40 | 83261.11 |
| 18 | 4.53 | 2.58 | 52.36 | 1.87 | 18.77 | 10.03 | 1.42 | 81046.09 |
| 19 | 2.70 | 1.91 | 65.69 | 2.04 | 17.65 | 10.85 | 1.43 | 76848.08 |
| 20 | 7.00 | 2.49 | 44.91 | 2.69 | 17.13 | 10.04 | 1.41 | 83317.43 |
| 21 | 4.92 | 4.61 | 49.53 | 2.83 | 17.48 | 10.00 | 1.40 | 79924.56 |
| 22 | 7.86 | 1.91 | 56.39 | 2.50 | 18.24 | 9.97 | 1.41 | 82639.10 |
| 23 | 5.34 | 2.46 | 53.21 | 1.88 | 19.36 | 9.86 | 1.42 | 81035.14 |
| 監測時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 超限次數 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 有效時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 平均值 | 4.94 | 2.32 | 48.67 | 2.10 | 18.22 | 9.85 | 1.42 | 80030.39 |
| 最大值 | 12.23 | 4.61 | 65.69 | 3.13 | 20.97 | 11.11 | 1.47 | 83343.85 |
| 發生時間 | 14 | 21 | 19 | 14 | 8 | 0 | | 8 |
| 最小值 | 0.17 | 1.14 | 33.42 | 1.10 | 16.43 | 8.96 | 1.38 | 72353.52 |
| 發生時間 | 1 | 6 | 10 | 1 | 13 | 8 | | 0 |
| 零點偏移(率) | -0.15 % | -0.11 % | -0.03 % | 0.00 % | | 0.02 | 0.00 | 0.00 % |
| 全幅偏移(率) | 0.02 % | 0.78 % | -0.30 % | 0.13 % | | -0.06 | -0.03 | 0.20 % |
| 有效比率 | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % |
| 備註 | | | | | | | | |

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年05月26日

| 項目 | #3-HCl_C | #3-CO_C | #3-NOx_C | #3-SO2_C | #3-H2O | #3-O2_C | #3-OPAC | #3-FLOW_C |
|---------|----------|----------|----------|----------|----------|----------|----------|-----------|
| 單位 | ppm | ppm | ppm | ppm | % | % | % | m3/Hour |
| 小時\限標 | 60.00 | 150.00 | 220.00 | 150.00 | 100.00 | 25.00 | 10.00 | 999999.00 |
| 0 | 8.28 | 2.83 | 64.49 | 2.46 | 19.32 | 10.43 | 1.45 | 86205.39 |
| 1 | 8.54 | 6.03 | 46.51 | 2.46 | 18.81 | 10.47 | 1.44 | 83507.75 |
| 2 | 7.40 | 5.57 | 60.44 | 3.09 | 16.33 | 11.11 | 1.44 | 78656.36 |
| 3 | 8.99 | 1.61 | 62.50 | 2.50 | 17.62 | 10.82 | 1.44 | 85720.53 |
| 4 | 8.58 | 1.62 | 57.73 | 2.32 | 17.18 | 10.96 | 1.43 | 83317.88 |
| 5 | 10.90 | 3.26 | 62.98 | 3.37 | 14.85 | 11.54 | 1.43 | 79487.88 |
| 6 | 7.34 | 1.90 | 59.46 | 2.84 | 16.07 | 11.11 | 1.43 | 82703.71 |
| 7 | 9.56 | 2.38 | 60.25 | 2.98 | 16.54 | 11.21 | 1.43 | 76300.08 |
| 8 | 7.51 | 1.61 | 66.76 | 2.68 | 17.60 | 11.19 | 1.44 | 81062.82 |
| 9 | 12.48 | 2.67 | 59.51 | 3.02 | 16.24 | 11.01 | 1.43 | 85041.38 |
| 10 | 10.81 | 3.58 | 56.55 | 2.84 | 16.47 | 10.80 | 1.43 | 81815.13 |
| 11 | 8.16 | 3.32 | 58.16 | 2.76 | 16.04 | 10.84 | 1.45 | 79945.34 |
| 12 | 10.28 | 1.81 | 55.97 | 2.66 | 16.30 | 10.74 | 1.46 | 79254.71 |
| 13 | 9.16 | 2.21 | 61.16 | 2.66 | 16.57 | 10.76 | 1.48 | 80533.45 |
| 14 | 12.77 | 2.29 | 58.26 | 3.07 | 17.68 | 10.44 | 1.45 | 81804.88 |
| 15 | 5.59 | 3.60 | 51.92 | 2.29 | 17.44 | 10.47 | 1.44 | 82268.35 |
| 16 | 6.19 | 2.73 | 59.31 | 2.53 | 16.33 | 10.79 | 1.47 | 79848.46 |
| 17 | 8.17 | 2.84 | 57.68 | 2.67 | 16.42 | 10.87 | 1.45 | 81272.32 |
| 18 | 8.97 | 2.47 | 55.20 | 2.54 | 17.62 | 10.60 | 1.40 | 81653.08 |
| 19 | 9.43 | 7.54 | 58.51 | 3.02 | 16.07 | 10.86 | 1.41 | 80865.94 |
| 20 | 9.58 | 3.46 | 58.24 | 2.70 | 17.33 | 10.69 | 1.43 | 83176.57 |
| 21 | 7.70 | 3.12 | 52.60 | 2.50 | 17.71 | 10.38 | 1.43 | 84809.86 |
| 22 | 6.80 | 2.36 | 66.74 | 2.66 | 16.91 | 10.99 | 1.41 | 80509.02 |
| 23 | 10.31 | 4.25 | 57.14 | 2.63 | 17.83 | 10.87 | 1.40 | 81305.08 |
| 監測時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 超限次數 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 有效時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 平均值 | 8.90 | 3.13 | 58.67 | 2.72 | 16.97 | 10.83 | 1.44 | 81711.08 |
| 最大值 | 12.77 | 7.54 | 66.76 | 3.37 | 19.32 | 11.54 | 1.49 | 86205.39 |
| 發生時間 | 14 | 19 | 8 | 5 | 0 | 5 | | 0 |
| 最小值 | 5.59 | 1.61 | 46.51 | 2.29 | 14.85 | 10.38 | 1.38 | 76300.08 |
| 發生時間 | 15 | 3 | 1 | 15 | 5 | 21 | | 7 |
| 零點偏移(率) | -0.01 % | -0.06 % | -0.00 % | 0.00 % | | -0.01 | 0.00 | 0.00 % |
| 全幅偏移(率) | 0.13 % | 0.35 % | -0.73 % | 0.04 % | | -0.20 | 0.02 | 0.10 % |
| 有效比率 | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % |
| 備註 | | | | | | | | |