

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 113年10月27日

報表日期: 113年10月27日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.87	5.42	69.60	1.30	18.26	12.15	1.07	75524.05
1	4.38	4.64	53.23	1.60	19.22	11.08	1.05	84121.78
2	7.76	4.56	48.18	1.28	18.52	11.28	1.05	83004.68
3	7.35	4.23	49.71	1.69	17.85	11.47	1.05	82125.73
4	8.89	4.62	47.14	1.93	17.18	11.57	1.04	81828.36
5	5.26	3.68	59.16	2.05	17.50	11.20	1.02	86871.84
6	6.25	3.47	58.99	1.53	16.90	12.01	1.02	77950.52
7	3.62	3.19	57.42	0.84	18.24	11.79	1.02	79068.27
8	5.35	3.85	51.95	0.90	18.61	11.34	1.04	82225.04
9	3.69	4.57	50.26	1.38	18.24	11.54	1.06	80694.33
10	8.65	4.40	45.32	1.47	18.27	11.20	1.02	83887.43
11	8.65	4.48	42.50	1.75	17.70	11.31	1.03	83293.75
12	6.68	4.17	42.48	1.54	17.83	11.46	1.04	81762.20
13	4.29	4.04	60.68	1.13	18.05	11.53	1.04	81347.42
14	9.91	4.08	48.86	1.96	17.44	11.48	1.04	82142.05
15	9.48	4.44	59.96	1.29	18.65	11.38	1.03	81894.40
16	6.56	4.54	63.48	0.71	19.48	11.54	1.03	80268.65
17	8.98	4.14	52.15	1.49	17.87	11.54	1.04	80981.90
18	7.24	4.34	44.90	1.34	18.22	11.72	1.05	79527.20
19	7.37	3.65	43.60	1.60	17.25	11.68	1.03	80515.38
20	4.23	4.06	47.95	1.10	17.64	11.91	1.02	78569.68
21	4.93	4.83	60.39	0.80	19.32	11.26	1.02	82577.14
22	9.41	4.38	52.06	1.30	17.84	11.25	1.02	84293.21
23	7.58	5.39	42.02	1.03	18.84	11.21	1.02	83280.27
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.60	4.30	52.17	1.38	18.12	11.50	1.04	81573.14
最 大 值	9.91	5.42	69.60	2.05	19.48	12.15	1.09	86871.84
發生時間	14	0	0	5	16	0		5
最 小 值	1.87	3.19	42.02	0.71	16.90	11.08	1.02	75524.05
發生時間	0	7	23	16	6	1		0
零點偏移(率)	-0.02 %	-0.00 %	-0.09 %	-0.13 %		-0.02		0.00 %
全幅偏移(率)	0.00 %	-0.52 %	-0.26 %	0.29 %		0.12		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年10月27日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	9.68	3.77	51.17	1.89	17.09	10.97	1.75	78948.48
1	10.78	3.85	51.17	2.10	15.93	11.47	1.79	75806.26
2	5.74	3.98	49.86	3.08	18.03	10.71	1.73	80349.97
3	3.62	4.36	47.62	1.92	17.03	10.91	1.71	79624.51
4	4.60	4.75	46.49	1.36	15.71	11.30	1.72	78168.76
5	5.16	4.02	50.03	1.29	18.59	10.55	1.74	81174.06
6	3.60	3.95	47.69	1.18	18.36	10.47	1.71	81548.87
7	11.77	2.95	50.01	1.67	16.46	11.20	1.73	79469.42
8	12.55	3.30	54.04	1.90	16.36	11.12	1.71	78768.62
9	10.24	5.11	57.90	1.57	17.54	11.01	1.69	78534.33
10	12.61	3.81	45.88	2.07	18.09	10.32	1.73	81513.82
11	8.86	5.35	41.70	2.50	17.44	10.45	1.70	76150.21
12	10.70	2.41	47.71	2.83	18.21	10.37	1.67	75597.50
13	10.50	4.02	41.10	2.12	16.68	10.90	1.68	73530.27
14	9.54	2.63	46.08	1.59	18.00	10.68	1.68	73470.31
15	9.94	2.64	45.04	1.50	18.68	10.36	1.70	74971.26
16	9.17	4.09	43.50	1.21	17.35	10.96	1.70	71889.16
17	8.93	4.10	49.23	1.58	19.21	10.49	1.69	78588.62
18	7.06	3.37	46.83	2.35	16.10	11.31	1.72	74748.35
19	10.50	3.66	58.08	1.53	16.45	11.67	1.70	73833.77
20	14.68	2.47	57.78	1.68	18.75	10.41	1.69	81650.13
21	8.30	3.17	49.28	1.51	17.56	10.98	1.69	78256.77
22	1.52	2.78	48.39	0.97	17.59	10.88	1.69	79447.11
23	7.65	3.06	55.53	1.54	17.98	11.01	1.69	77803.56
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.65	3.65	49.25	1.79	17.47	10.85	1.71	77660.17
最 大 值	14.68	5.35	58.08	3.08	19.21	11.67	1.84	81650.13
發生時間	20	11	19	2	17	19		20
最 小 值	1.52	2.41	41.10	0.97	15.71	10.32	1.67	71889.16
發生時間	22	12	13	22	4	10		16
零點偏移(率)	-0.02 %	-0.00 %	-0.03 %	-0.10 %		-0.13		0.00 %
全幅偏移(率)	0.02 %	-0.11 %	-0.86 %	0.74 %		0.27		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								