

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年04月05日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.98	3.43	53.83	2.28	17.15	12.01	1.51	69956.06
1	6.07	3.34	66.30	2.10	18.51	11.98	1.49	69118.07
2	5.30	4.26	60.30	2.58	16.92	12.61	1.48	65339.81
3	1.48	3.37	54.11	2.11	17.17	12.01	1.51	70557.82
4	1.80	3.32	59.08	2.11	17.33	11.80	1.51	72232.35
5	8.06	3.97	53.65	2.92	16.68	11.93	1.51	69515.69
6	5.30	3.30	59.54	2.69	16.63	12.14	1.52	69864.66
7	1.78	3.47	57.07	2.39	16.79	11.91	1.51	71929.28
8	0.29	3.17	60.11	1.95	18.40	11.70	1.52	72427.22
9	0.33	3.54	53.72	1.99	18.36	11.76	1.47	71832.96
10	0.23	3.57	60.37	1.87	18.37	11.81	1.51	71152.21
11	0.11	3.30	52.11	1.94	17.67	11.65	1.51	72862.15
12	0.09	3.38	46.18	2.18	17.06	11.64	1.49	73266.21
13	0.07	3.80	45.16	2.70	15.62	12.12	1.46	70701.87
14	0.62	3.88	52.88	2.33	16.95	11.77	1.46	72707.72
15	1.39	3.35	49.04	2.21	17.39	11.55	1.46	73581.50
16	1.76	3.28	60.36	2.05	18.44	11.56	1.50	72750.69
17	0.27	4.49	68.76	2.24	17.64	12.44	1.52	66677.76
18	0.16	4.25	43.25	1.98	17.96	11.86	1.45	70885.44
19	0.15	4.19	61.21	2.09	18.47	11.82	1.50	70698.99
20	1.54	3.68	53.28	2.28	17.43	11.62	1.46	73328.44
21	3.21	3.93	59.47	2.42	17.11	12.00	1.46	70462.17
22	6.57	4.82	49.71	2.53	18.65	11.16	1.46	75444.23
23	9.12	3.83	52.41	3.19	16.84	11.93	1.47	70855.23
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	2.57	3.71	55.50	2.30	17.48	11.87	1.49	71172.86
最大值	9.12	4.82	68.76	3.19	18.65	12.61	1.63	75444.23
發生時間	23	22	17	23	22	2		22
最小值	0.07	3.17	43.25	1.87	15.62	11.16	1.43	65339.81
發生時間	13	8	18	10	13	22		2
零點偏移(率)	-0.01 %	-0.04 %	-0.02 %	0.00 %		-0.04	0.00	0.00 %
全幅偏移(率)	-0.25 %	0.43 %	-0.85 %	0.40 %		-0.01	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年04月05日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.06	4.39	46.48	1.34	18.49	10.87	1.48	76508.83
1	5.24	4.06	52.73	1.38	19.42	10.54	1.49	80146.95
2	6.18	4.02	45.87	2.22	18.44	9.98	1.49	81459.56
3	4.33	7.83	48.73	2.13	17.17	10.61	1.49	77619.71
4	2.82	3.46	56.66	1.75	16.82	10.85	1.50	81266.23
5	4.34	6.96	46.96	1.93	17.21	10.28	1.51	81409.87
6	6.80	3.74	53.95	2.52	16.18	10.78	1.51	83794.61
7	6.63	3.46	53.95	2.51	15.56	11.00	1.50	80432.39
8	7.83	3.47	50.38	2.26	17.03	10.64	1.48	82048.07
9	5.16	3.92	52.59	2.12	17.26	10.56	1.49	82447.03
10	7.38	5.34	47.16	2.46	18.11	10.16	1.50	80097.72
11	2.18	7.18	47.49	1.86	16.23	10.31	1.46	77236.41
12	1.24	3.54	47.85	1.26	18.36	9.88	1.47	82057.82
13	1.37	4.90	51.06	1.94	15.52	10.71	1.51	79093.70
14	2.63	3.71	52.18	2.02	15.82	10.79	1.49	78990.53
15	2.11	4.13	47.68	1.70	16.85	10.40	1.48	79679.22
16	1.31	4.51	49.65	1.53	17.39	10.37	1.47	80818.14
17	0.75	5.31	47.56	0.92	19.85	9.81	1.50	85266.41
18	0.55	4.28	55.76	0.57	21.61	9.66	1.49	86979.77
19	3.50	15.45	45.70	3.11	19.91	9.52	1.46	84607.36
20	3.08	6.31	41.32	1.59	18.90	9.87	1.46	83762.07
21	5.01	5.35	51.20	2.08	17.59	10.40	1.46	82723.34
22	5.34	8.37	41.01	1.77	19.59	9.40	1.46	82391.92
23	6.55	6.90	43.72	2.31	17.86	9.90	1.46	82204.15
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	3.97	5.44	49.07	1.89	17.80	10.30	1.48	81376.74
最大值	7.83	15.45	56.66	3.11	21.61	11.00	1.56	86979.77
發生時間	8	19	4	19	18	7		18
最小值	0.55	3.46	41.01	0.57	15.52	9.40	1.44	76508.83
發生時間	18	4	22	18	13	22		0
零點偏移(率)	-0.01 %	-0.04 %	-0.04 %	0.00 %		-0.14	0.00	0.00 %
全幅偏移(率)	2.38 %	0.43 %	-0.72 %	0.40 %		-0.15	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年04月05日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.70	3.70	60.91	1.60	17.20	10.76	1.40	83761.15
1	4.16	7.63	54.43	1.35	19.61	10.36	1.41	86421.31
2	5.50	6.77	51.02	1.61	18.78	10.11	1.40	88049.90
3	5.22	10.78	44.33	3.01	17.14	10.41	1.40	82137.31
4	6.31	4.53	52.11	2.02	16.06	10.88	1.41	82724.48
5	9.76	6.70	53.66	4.00	15.83	10.96	1.42	82209.11
6	9.38	2.95	50.29	2.59	16.11	10.90	1.39	82322.97
7	11.27	5.31	62.33	2.30	16.12	11.12	1.41	92749.38
8	7.89	5.85	54.12	2.31	16.57	10.79	1.41	86302.41
9	3.89	2.31	55.93	1.75	17.47	10.61	1.39	84739.25
10	3.58	2.93	49.94	1.62	16.96	10.49	1.40	83890.61
11	0.90	1.74	60.94	1.52	17.28	10.66	1.39	82370.72
12	0.20	2.97	46.49	1.45	16.50	10.45	1.38	81097.67
13	0.40	5.50	52.47	1.63	16.16	10.54	1.38	80779.99
14	1.13	6.01	53.72	1.82	15.75	10.84	1.38	79077.21
15	1.98	5.32	53.18	1.69	17.00	10.54	1.38	81714.68
16	1.74	4.06	53.76	1.57	17.40	10.59	1.39	83428.47
17	1.54	6.12	49.29	1.40	18.31	10.37	1.39	85935.79
18	0.54	4.30	58.94	1.25	20.58	9.88	1.39	86981.58
19	0.54	12.27	46.69	1.50	19.84	9.27	1.38	87970.56
20	0.21	12.09	44.22	1.32	19.47	9.50	1.38	84509.51
21	1.14	1.84	39.36	2.33	17.38	10.06	1.38	84981.06
22	4.39	8.12	53.88	1.69	18.01	10.54	1.40	85372.94
23	6.63	9.03	51.29	1.91	18.80	9.91	1.38	85214.01
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	3.92	5.78	52.22	1.88	17.51	10.44	1.39	84364.25
最大值	11.27	12.27	62.33	4.00	20.58	11.12	1.43	92749.38
發生時間	7	19	7	5	18	7		7
最小值	0.20	1.74	39.36	1.25	15.75	9.27	1.37	79077.21
發生時間	12	11	21	18	14	19		14
零點偏移(率)	-0.03 %	-0.04 %	-0.01 %	-0.03 %		-0.08	0.00	0.00 %
全幅偏移(率)	3.59 %	1.30 %	-0.91 %	0.69 %		0.05	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								