

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 114年12月25日

項目 單位	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
小時\限標	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
0	6.97	15.48	40.77	3.66	14.72	12.19	1.25	77084.83
1	11.32	14.10	40.63	4.16	17.19	11.79	1.25	80232.11
2	6.75	13.53	47.13	4.35	15.42	12.14	1.23	78639.86
3	1.31	15.33	48.22	4.44	16.95	11.53	1.25	81108.41
4	8.93	13.44	40.87	0.61	16.00	11.25	1.25	82112.85
5	0.47	13.28	41.00	3.43	13.52	12.29	1.24	76190.65
6	0.33	13.57	33.30	2.90	14.85	12.20	1.22	77844.59
7	0.93	12.72	46.67	2.26	15.45	11.50	1.25	83649.12
8	1.51	11.54	44.98	1.49	15.72	11.43	1.21	83829.02
9	8.10	12.13	67.23	1.01	16.43	11.85	1.25	79330.91
10	7.42	11.32	56.36	1.08	16.37	11.16	1.25	85472.09
11	7.62	11.53	40.44	1.24	16.25	11.41	1.25	82888.19
12	7.59	11.43	55.47	0.84	17.24	11.22	1.25	83815.79
13	8.11	12.12	49.86	1.26	15.82	11.86	1.25	79716.53
14	8.58	11.65	55.93	1.27	17.06	11.29	1.25	83480.41
15	4.78	11.77	59.61	1.73	17.04	11.42	1.25	82419.12
16	0.18	12.43	50.41	1.28	17.52	10.92	1.25	86662.70
17	3.76	12.71	44.23	1.78	16.51	11.19	1.21	84791.79
18	8.07	12.79	55.65	2.18	16.29	11.31	1.20	83997.13
19	9.34	13.35	57.81	1.69	16.65	11.70	1.20	80430.30
20	7.42	13.05	43.45	1.65	16.89	11.31	1.20	83049.48
21	10.31	13.20	58.10	1.21	18.86	10.88	1.22	85072.08
22	7.21	13.25	43.75	1.60	17.04	11.13	1.23	84597.68
23	3.30	13.45	50.10	1.27	17.64	11.45	1.23	81369.76
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	5.85	12.88	48.83	2.02	16.39	11.52	1.23	81991.06
最 大 值	11.32	15.48	67.23	4.44	18.86	12.29	1.27	86662.70
發生時間	1	0	9	3	21	5		16
最 小 值	0.18	11.32	33.30	0.61	13.52	10.88	1.19	76190.65
發生時間	16	10	6	4	5	21		5
零點偏移(率)	-0.02 %	0.01 %	-0.01 %	0.01 %		-0.05	-0.01	0.30 %
全幅偏移(率)	-1.97 %	0.64 %	-1.73 %	-0.99 %		-0.04	0.10	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

