

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 113年09月21日

報表日期: 113年09月21日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.20	3.95	60.42	0.52	18.53	11.41	0.97	81754.06
1	8.67	3.40	51.64	1.09	18.84	10.88	0.97	85935.13
2	9.28	2.94	52.00	1.92	18.05	11.47	0.97	81713.42
3	6.36	2.86	63.84	1.34	17.91	11.83	0.97	78838.29
4	7.22	3.31	59.67	1.08	18.17	11.46	0.97	81504.32
5	6.46	5.50	46.26	1.77	17.41	11.79	0.97	79317.95
6	9.88	4.64	67.21	1.68	16.31	11.95	0.97	79364.07
7	8.72	4.33	57.64	1.38	16.98	11.73	0.97	80517.42
8	8.33	4.89	57.78	1.63	15.90	12.06	0.97	78510.29
9	4.63	4.82	59.14	1.79	15.47	12.33	0.97	76759.75
10	8.27	4.81	66.04	1.23	18.03	11.70	0.94	79841.56
11	8.63	4.65	56.23	1.45	16.91	11.86	0.97	79765.51
12	8.91	5.47	55.94	1.67	15.98	11.98	0.97	79770.22
13	10.24	4.82	56.75	1.45	16.32	11.87	0.97	80155.08
14	9.45	5.28	56.04	1.91	15.80	12.21	0.97	78140.42
15	7.49	4.78	62.07	1.15	16.86	11.79	0.97	79994.61
16	8.64	4.13	51.55	1.13	16.86	11.70	0.97	81207.29
17	4.98	4.20	58.01	1.07	16.32	12.02	0.96	79140.44
18	3.52	4.78	64.62	1.06	16.48	12.64	0.97	73485.23
19	5.20	4.37	50.38	0.88	16.92	12.11	0.97	77568.38
20	4.60	4.50	52.46	0.62	17.81	11.62	0.98	81433.79
21	8.00	4.14	54.87	0.85	18.03	11.47	0.98	82386.93
22	4.46	4.67	51.36	1.23	16.21	12.42	0.99	75374.66
23	2.28	5.29	62.05	1.00	16.72	12.60	0.98	73665.57
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.06	4.44	57.25	1.29	17.03	11.87	0.97	79422.68
最 大 值	10.24	5.50	67.21	1.92	18.84	12.64	1.01	85935.13
發生時間	13	5	6	2	1	18		1
最 小 值	2.28	2.86	46.26	0.52	15.47	10.88	0.92	73485.23
發生時間	23	3	5	0	9	1		18
零點偏移(率)	-0.25 %	-0.00 %	-0.01 %	-0.03 %		-0.04		0.00 %
全幅偏移(率)	0.00 %	0.01 %	0.49 %	0.89 %		0.05		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年09月21日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	9.25	2.18	54.80	0.97	16.58	11.27	1.74	77641.13
1	6.48	2.32	54.63	0.92	17.32	11.22	1.72	77127.50
2	10.45	2.65	56.46	1.61	15.79	11.44	1.71	76904.72
3	10.60	2.13	60.24	1.96	14.90	11.58	1.72	76613.39
4	8.65	2.10	60.07	2.00	14.82	11.53	1.73	76909.19
5	9.52	1.86	59.45	1.84	14.86	11.47	1.73	75704.64
6	6.68	2.12	57.85	1.79	14.76	11.33	1.74	75963.58
7	9.26	3.46	50.23	1.72	14.67	11.42	1.75	76943.35
8	9.31	3.20	54.14	1.92	14.80	11.41	1.76	74611.79
9	12.68	5.08	54.62	2.60	13.97	11.58	1.73	72854.85
10	11.85	3.55	53.81	2.25	13.98	11.63	1.75	72795.89
11	7.30	3.42	50.24	1.56	14.88	11.39	1.76	74462.55
12	8.50	4.50	52.79	1.68	14.41	11.53	1.76	72742.73
13	5.72	5.04	48.67	2.70	12.88	11.44	1.75	70456.90
14	6.60	2.70	50.76	2.01	13.69	11.32	1.75	71788.17
15	8.27	2.53	55.91	2.44	13.72	11.48	1.76	71607.85
16	7.32	2.10	55.28	1.34	15.89	11.30	1.76	76074.58
17	7.99	2.32	60.60	0.85	17.11	11.32	1.76	76258.77
18	7.45	3.27	58.72	0.85	17.51	10.85	1.76	80258.39
19	9.05	3.66	57.55	1.12	16.62	10.97	1.76	79095.41
20	5.69	5.19	55.55	1.90	14.26	11.94	1.75	71856.52
21	6.39	3.75	58.83	1.19	15.72	11.52	1.76	75880.27
22	8.69	4.43	57.63	1.49	14.77	12.04	1.76	71504.54
23	7.43	3.58	59.77	1.09	16.63	11.26	1.76	77565.43
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.38	3.21	55.77	1.66	15.19	11.43	1.75	75150.92
最 大 值	12.68	5.19	60.60	2.70	17.51	12.04	1.77	80258.39
發生時間	9	20	17	13	18	22		18
最 小 值	5.69	1.86	48.67	0.85	12.88	10.85	1.71	70456.90
發生時間	20	5	13	17	13	18		13
零點偏移(率)	-0.02 %	-0.03 %	-0.02 %	-0.03 %		-0.03		0.00 %
全幅偏移(率)	0.02 %	0.88 %	-0.29 %	0.11 %		0.25		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								