

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 113年08月08日

報表日期: 113年08月08日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.61	7.10	46.05	2.45	15.97	11.68	0.97	76921.40
1	4.27	5.54	58.17	1.22	18.76	11.89	0.97	74324.42
2	9.99	5.01	52.47	1.73	18.81	11.40	0.97	81469.57
3	7.95	5.43	42.80	1.83	17.26	11.70	0.96	80720.66
4	6.03	9.78	40.62	1.38	17.39	11.47	0.94	80185.49
5	1.06	11.05	45.99	1.76	15.81	12.36	0.92	74322.96
6	2.56	1.91	49.61	0.95	17.15	12.24	0.92	71904.38
7	2.53	3.54	56.44	0.44	20.41	10.70	0.96	85261.31
8	7.11	1.40	62.65	1.61	17.74	11.78	0.97	79206.25
9	9.30	1.55	48.54	2.20	16.74	11.95	0.94	78947.22
10	8.29	1.87	40.25	2.71	16.05	11.88	0.94	79293.21
11	12.15	1.42	35.60	2.28	16.82	11.69	0.94	79095.35
12	7.88	1.40	46.35	1.16	19.02	11.64	0.96	78091.89
13	5.40	1.49	56.85	0.55	20.47	11.20	0.97	81808.14
14	5.99	1.48	49.57	0.55	20.68	10.95	0.96	83447.01
15	7.51	5.03	40.54	1.71	18.63	11.32	0.94	82270.39
16	9.06	2.92	53.70	1.19	19.15	11.02	0.96	84512.28
17	10.89	4.52	35.40	2.59	16.98	11.39	0.96	81548.56
18	13.21	6.68	40.22	3.16	18.39	11.07	0.94	83468.72
19	12.13	3.80	35.08	2.35	17.92	11.01	0.94	81995.46
20	12.49	3.48	40.72	2.03	17.70	11.25	0.94	82212.51
21	11.51	4.97	41.96	2.58	16.33	11.68	0.93	76460.79
22	8.61	3.13	43.54	1.58	17.59	11.45	0.93	80357.93
23	9.87	3.27	44.97	1.72	17.32	11.75	0.94	78619.51
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.10	4.07	46.17	1.74	17.88	11.52	0.95	79851.89
最 大 值	13.21	11.05	62.65	3.16	20.68	12.36	1.00	85261.31
發生時間	18	5	8	18	14	5		7
最 小 值	1.06	1.40	35.08	0.44	15.81	10.70	0.91	71904.38
發生時間	5	8	19	7	5	7		6
零點偏移(率)	-0.02 %	-0.09 %	-0.09 %	0.00 %		-0.07		0.00 %
全幅偏移(率)	0.00 %	-0.58 %	-0.24 %	0.06 %		-0.01		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

