

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 113年10月02日

報表日期: 113年10月02日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.51	4.26	59.17	1.33	19.40	11.02	0.97	84687.67
1	7.48	2.85	63.60	1.30	20.76	10.98	0.97	83767.38
2	6.10	4.63	53.92	1.31	19.92	10.73	0.97	86892.01
3	7.66	3.19	54.71	1.85	18.16	11.51	0.97	81873.14
4	1.32	3.88	61.74	1.41	18.26	12.32	0.97	74758.61
5	7.21	3.49	53.15	1.34	18.87	10.92	1.01	84018.20
6	11.64	2.66	46.76	1.96	17.40	11.43	1.02	83397.60
7	16.11	2.65	50.16	2.44	16.38	11.88	1.02	80579.39
8	10.92	2.54	49.44	1.42	16.91	11.77	1.01	82333.11
9	7.51	3.00	49.48	1.15	17.24	11.74	0.99	81140.41
10	7.83	3.25	45.61	1.23	17.54	11.42	1.00	83000.98
11	8.67	3.42	46.26	1.22	17.50	11.56	1.02	82208.64
12	7.66	3.51	46.38	1.42	16.97	11.75	1.02	81062.99
13	6.86	3.79	53.99	0.76	18.00	11.20	1.01	84899.48
14	9.33	3.86	42.33	1.98	15.83	11.79	0.99	81515.31
15	8.63	3.26	47.81	1.23	17.09	11.58	1.02	82666.96
16	8.40	3.25	51.89	1.37	16.50	11.75	1.02	81210.06
17	8.59	3.39	54.80	0.93	18.32	11.19	1.02	84874.67
18	6.42	3.23	54.29	1.14	17.12	11.47	1.02	83355.74
19	8.91	4.04	41.88	1.81	16.26	11.57	1.01	83352.47
20	9.69	3.19	48.17	1.09	17.44	11.38	1.01	83721.50
21	9.72	3.31	50.63	1.39	16.47	11.81	1.02	80842.62
22	9.14	3.30	51.20	1.19	17.50	11.50	1.02	82698.51
23	9.52	3.18	57.98	1.32	17.47	11.33	1.02	84003.11
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.49	3.38	51.47	1.40	17.64	11.48	1.00	82619.19
最 大 值	16.11	4.63	63.60	2.44	20.76	12.32	1.03	86892.01
發生時間	7	2	1	7	1	4		2
最 小 值	1.32	2.54	41.88	0.76	15.83	10.73	0.97	74758.61
發生時間	4	8	19	13	14	2		4
零點偏移(率)	-0.05 %	-0.00 %	-0.28 %	-0.03 %		-0.06		0.00 %
全幅偏移(率)	0.00 %	0.08 %	0.90 %	0.64 %		0.04		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

