

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 113年07月04日

[illegible]

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 113年07月04日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.82	2.23	45.64	1.61	16.82	11.20	1.02	79798.37
1	1.47	3.86	46.08	1.28	19.08	10.56	1.02	83353.70
2	5.11	2.31	47.98	1.44	17.82	10.72	1.02	83194.00
3	3.75	2.47	42.84	1.92	16.56	11.04	1.02	81819.78
4	2.92	1.97	52.84	1.06	18.32	10.56	1.02	83812.97
5	3.49	2.90	43.39	1.83	17.17	10.88	1.02	82577.62
6	0.94	2.41	44.28	1.10	17.95	10.60	0.97	79775.75
7	0.84	2.15	47.61	1.88	16.80	11.03	0.96	81516.29
8	1.48	2.11	52.29	1.54	17.09	11.18	0.94	79712.99
9	1.54	2.33	55.61	1.12	18.11	11.05	0.94	79669.29
10	2.79	4.65	47.01	2.00	15.67	11.39	0.94	79624.41
11	1.60	6.22	48.24	2.43	14.73	11.80	0.95	76993.91
12	2.15	1.02	52.15	2.26	15.09	11.79	0.94	76263.50
13	4.27	1.65	57.54	1.79	16.07	11.57	0.94	77846.19
14	7.29	2.34	50.08	2.52	15.94	11.51	0.94	77739.84
15	4.61	3.59	50.12	2.13	16.55	11.08	0.95	80886.75
16	3.68	2.34	57.47	2.25	15.38	11.48	0.95	78769.74
17	1.18	3.73	53.25	2.07	15.99	11.27	0.95	80183.12
18	0.44	2.33	63.57	0.76	18.49	11.04	0.97	79663.76
19	0.63	2.94	54.92	1.48	17.89	10.65	0.96	82772.57
20	4.10	2.42	56.18	1.43	17.21	11.33	0.94	78272.31
21	5.63	2.69	63.28	1.45	18.20	10.87	0.94	81314.95
22	7.62	2.30	55.76	1.88	16.64	11.19	0.94	80378.61
23	5.82	2.61	56.90	1.83	16.33	11.34	0.94	78865.71
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	3.09	2.73	51.88	1.71	16.91	11.13	0.97	80200.26
最 大 值	7.62	6.22	63.57	2.52	19.08	11.80	1.05	83812.97
發生時間	22	11	18	14	1	11		4
最 小 值	0.44	1.02	42.84	0.76	14.73	10.56	0.94	76263.50
發生時間	18	12	3	18	11	1		12
零點偏移(率)	-0.23 %	-0.01 %	-0.03 %	-0.01 %		-0.05		0.00 %
全幅偏移(率)	0.13 %	-0.35 %	-0.59 %	0.26 %		0.02		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年07月04日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.25	2.47	45.04	1.14	17.40	10.34	0.98	73052.22
1	1.12	4.67	46.13	1.15	18.64	9.97	0.99	74887.06
2	1.17	5.32	45.05	1.36	16.17	10.29	0.99	72994.17
3	1.35	4.69	41.49	1.49	16.06	10.51	0.99	69930.84
4	1.19	4.65	42.15	1.47	15.60	11.00	0.98	63649.33
5	1.17	4.77	45.61	1.37	16.10	10.46	0.97	75597.65
6	1.13	2.65	51.13	1.35	16.49	10.52	0.99	76986.88
7	0.98	2.39	53.11	1.95	15.66	10.77	0.97	79217.08
8	0.07	2.02	53.31	1.37	16.41	11.09	0.99	78058.65
9	1.27	1.92	54.39	1.76	15.98	11.35	0.94	79266.49
10	1.74	2.31	51.76	1.99	15.32	11.40	0.98	78773.39
11	0.32	2.22	52.95	1.89	15.04	11.52	0.99	77652.09
12	2.17	3.25	51.03	2.68	13.92	11.46	0.96	79964.52
13	5.39	4.54	51.59	2.38	15.07	11.36	0.98	80702.39
14	3.64	1.35	53.32	2.29	14.65	11.40	0.99	78533.69
15	0.32	2.25	52.72	1.82	15.11	11.26	0.99	79552.15
16	3.50	2.21	64.94	1.87	17.16	10.52	0.99	83170.10
17	4.44	3.09	52.73	2.08	15.71	10.54	0.98	78749.62
18	2.26	2.25	52.57	1.12	16.73	10.34	0.92	76720.06
19	2.79	2.71	49.02	1.24	16.62	10.21	0.94	76650.96
20	2.62	3.84	54.60	1.25	17.06	10.30	0.98	80008.49
21	2.37	2.60	64.58	1.19	18.33	10.51	1.01	80711.62
22	2.34	2.19	53.88	1.52	18.33	10.28	0.99	83296.74
23	2.31	2.49	43.36	1.36	18.20	10.33	0.98	82580.78
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	2.00	3.04	51.10	1.63	16.32	10.74	0.98	77529.46
最 大 值	5.39	5.32	64.94	2.68	18.64	11.52	1.02	83296.74
發生時間	13	2	16	12	1	11		22
最 小 值	0.07	1.35	41.49	1.12	13.92	9.97	0.92	63649.33
發生時間	8	14	3	18	12	1		4
零點偏移(率)	-0.01 %	0.00 %	-0.01 %	0.00 %		-0.02		0.00 %
全幅偏移(率)	0.02 %	0.13 %	-0.61 %	0.05 %		0.56		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								