

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年06月15日

報表日期: 114年06月15日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.14	2.87	60.03	1.65	18.19	11.52	1.27	79514.88
1	1.40	3.05	50.28	1.90	19.08	11.29	1.28	80272.96
2	7.75	2.74	61.87	2.64	17.56	11.66	1.29	78835.93
3	8.47	2.93	62.07	3.47	17.28	11.43	1.29	81473.05
4	11.75	4.97	61.93	3.84	16.46	11.62	1.29	80417.15
5	1.57	11.04	65.28	2.27	16.18	11.70	1.29	77044.64
6	2.94	11.75	68.37	1.64	16.80	12.20	1.29	75016.69
7	19.17	12.83	51.92	2.11	17.45	11.64	1.29	79152.94
8	14.96	13.91	44.06	3.42	16.55	11.67	1.29	79516.50
9	3.32	11.09	63.57	2.47	16.11	11.85	1.29	78451.59
10	5.07	15.49	65.71	1.91	16.80	12.16	1.27	72628.73
11	2.10	4.34	55.72	1.85	17.32	11.40	1.28	79069.08
12	2.08	5.26	54.81	1.86	17.70	11.51	1.26	78702.60
13	5.62	2.63	51.31	3.19	16.54	11.48	1.26	78603.13
14	2.57	3.41	60.94	2.92	16.27	11.96	1.27	74521.48
15	5.69	4.25	53.23	2.79	17.37	11.51	1.28	79827.38
16	7.51	6.56	62.47	2.13	17.95	11.62	1.27	78379.60
17	6.31	5.73	41.49	2.68	17.41	11.12	1.27	80944.02
18	5.09	7.05	51.68	2.69	16.77	11.59	1.26	79156.85
19	7.56	3.61	49.84	3.39	16.57	11.53	1.26	79914.77
20	8.54	3.46	58.14	2.63	17.21	11.64	1.26	78112.21
21	9.50	4.11	50.84	2.82	17.62	11.28	1.25	80701.35
22	7.13	3.97	56.53	2.47	17.40	11.61	1.26	78636.27
23	6.42	5.17	48.28	2.47	17.56	11.35	1.27	81495.64
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.53	6.34	56.27	2.55	17.17	11.60	1.27	78766.23
最 大 值	19.17	15.49	68.37	3.84	19.08	12.20	1.30	81495.64
發生時間	7	10	6	4	1	6		23
最 小 值	1.40	2.63	41.49	1.64	16.11	11.12	1.25	72628.73
發生時間	1	13	17	6	9	17		10
零點偏移(率)	-0.11 %	-0.00 %	-0.02 %	0.01 %		-0.31		0.00 %
全幅偏移(率)	0.00 %	0.95 %	-0.49 %	0.75 %		-0.01		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年06月15日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.92	2.32	57.08	1.69	18.33	10.97	1.10	79492.91
1	0.55	2.65	67.73	1.72	18.84	11.28	1.10	77665.43
2	1.12	3.79	52.70	2.54	18.31	10.68	1.10	82841.37
3	5.09	4.38	52.92	2.30	18.00	10.61	1.10	81458.94
4	2.11	1.53	58.78	2.61	17.68	10.46	1.10	84006.29
5	6.02	1.59	60.98	2.56	17.65	10.49	1.10	83492.62
6	13.02	7.96	65.67	4.48	17.16	10.87	1.09	86620.23
7	1.38	11.36	62.86	2.71	16.90	11.08	1.08	80287.89
8	2.23	8.50	65.33	1.87	18.09	10.29	1.10	79167.27
9	12.32	8.98	60.17	2.06	16.77	11.40	1.09	78767.61
10	5.44	12.28	64.29	2.37	15.79	11.71	1.09	80516.62
11	3.34	8.97	56.38	1.74	17.23	11.12	1.09	79562.51
12	3.19	8.05	54.13	1.95	17.44	10.57	1.09	79534.19
13	3.72	3.52	52.04	1.67	17.08	10.44	1.09	80898.56
14	5.25	3.08	53.57	1.96	17.48	10.71	1.09	79749.91
15	4.44	3.33	58.67	1.81	18.73	10.94	1.09	76490.20
16	3.69	5.84	48.12	1.65	18.68	10.40	1.09	78325.65
17	3.67	5.20	56.16	1.49	18.00	11.05	1.08	77948.87
18	3.03	4.32	54.17	0.88	19.14	10.37	1.09	83739.05
19	3.45	4.67	51.51	1.58	18.25	10.40	1.09	85542.78
20	3.35	4.66	53.70	1.71	17.90	10.56	1.08	83170.70
21	3.35	4.48	54.66	1.58	18.01	10.57	1.09	82521.30
22	3.23	4.80	54.15	1.36	18.61	10.48	1.09	84366.54
23	3.08	4.61	54.82	1.23	19.01	10.45	1.09	82484.28
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	4.04	5.45	57.11	1.98	17.88	10.75	1.09	81193.82
最 大 值	13.02	12.28	67.73	4.48	19.14	11.71	1.11	86620.23
發生時間	6	10	1	6	18	10		6
最 小 值	0.55	1.53	48.12	0.88	15.79	10.29	1.06	76490.20
發生時間	1	4	16	18	10	8		15
零點偏移(率)	-0.14 %	-0.01 %	-0.03 %	-0.01 %		-0.09		-0.10 %
全幅偏移(率)	0.14 %	1.04 %	-0.62 %	0.50 %		-0.06		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 114年06月15日

報表日期: 114年06月15日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.11	2.12	67.92	1.73	18.12	9.36	1.37	75316.21
1	2.17	1.73	62.61	1.70	19.82	9.50	1.36	72880.70
2	2.17	14.51	61.84	1.83	18.17	9.65	1.35	73945.13
3	2.66	16.06	66.94	2.17	16.32	10.37	1.34	80538.83
4	3.64	13.90	53.32	2.06	17.20	10.61	1.34	78691.81
5	3.21	13.32	53.09	1.99	16.67	10.43	1.34	80081.72
6	4.85	11.16	57.55	2.27	16.52	10.68	1.35	77277.53
7	5.00	12.38	66.68	3.34	16.92	10.47	1.40	74303.68
8	2.62	16.30	64.71	2.94	16.53	10.28	1.38	78628.34
9	6.14	12.11	70.94	3.62	15.52	11.32	1.41	77186.00
10	6.62	11.42	60.85	3.83	15.57	11.15	1.36	81677.56
11	1.16	2.51	65.19	2.94	16.90	10.44	1.37	75425.72
12	5.14	8.22	55.88	3.23	18.45	8.83	1.39	83687.91
13	4.03	1.54	61.23	2.63	16.16	10.23	1.35	74954.46
14	3.55	1.77	61.11	2.61	17.69	10.08	1.34	79570.61
15	2.59	3.34	61.66	2.87	18.31	9.68	1.33	78911.38
16	4.27	5.52	62.82	2.80	19.31	9.14	1.33	79924.10
17	5.44	4.08	58.93	2.74	18.53	9.42	1.34	81222.68
18	4.86	4.29	51.17	2.83	18.52	9.48	1.36	81718.61
19	4.67	1.71	59.40	2.99	18.30	9.69	1.37	80506.02
20	2.15	1.85	59.96	2.83	18.43	9.62	1.37	81289.82
21	1.90	4.12	59.12	2.77	18.24	9.75	1.38	80538.33
22	2.00	5.90	58.18	2.86	18.43	9.60	1.37	81773.27
23	3.17	5.59	60.98	2.81	18.08	9.77	1.34	81667.99
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	3.59	7.31	60.92	2.68	17.61	9.98	1.36	78821.60
最 大 值	6.62	16.30	70.94	3.83	19.82	11.32	1.42	83687.91
發生時間	10	8	9	10	1	9		12
最 小 值	1.16	1.54	51.17	1.70	15.52	8.83	1.32	72880.70
發生時間	11	13	18	1	9	12		1
零點偏移(率)	-0.03 %	-0.04 %	-0.04 %	0.01 %		-0.02		-0.10 %
全幅偏移(率)	-0.12 %	0.32 %	-0.48 %	0.16 %		0.16		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								