

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月09日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.37	13.23	49.93	1.66	20.69	10.33	1.03	73777.99
1	7.11	10.83	50.94	1.73	20.63	10.55	1.04	72384.23
2	8.18	12.12	55.50	2.07	19.95	10.67	1.05	72883.92
3	11.27	14.62	52.65	3.10	16.71	11.33	1.03	69892.92
4	5.54	16.72	64.83	1.89	20.08	11.16	1.02	69364.50
5	10.06	13.87	55.92	1.60	22.13	9.35	0.99	85519.25
6	7.38	16.12	67.16	2.48	17.87	11.33	0.99	69641.29
7	5.11	14.60	54.86	1.55	20.77	10.48	0.99	72840.48
8	6.49	19.60	46.97	1.34	21.84	9.79	1.01	75597.51
9	9.66	12.19	40.64	2.44	18.01	11.11	1.02	69999.28
10	10.70	12.81	54.95	2.43	17.66	10.99	1.00	72088.05
11	8.14	18.82	53.90	2.65	16.65	11.56	1.01	68519.16
12	9.97	15.83	51.40	2.01	19.89	10.54	1.02	73229.57
13	10.33	17.62	46.06	2.41	18.11	10.83	1.02	71792.70
14	10.26	16.94	51.18	2.90	17.22	11.45	1.02	68108.25
15	9.70	14.72	57.30	1.92	20.53	10.19	1.02	74278.74
16	9.68	16.29	54.09	2.30	18.14	10.97	1.02	71011.40
17	8.35	14.16	51.54	1.73	20.32	10.44	1.01	72793.99
18	6.90	19.55	49.93	2.48	17.31	11.76	1.01	65960.56
19	6.34	8.10	79.56	1.63	20.58	10.97	1.02	69260.15
20	8.64	12.23	53.65	1.87	19.86	10.78	1.01	70295.96
21	9.46	9.76	45.58	1.48	21.37	9.60	1.01	77335.07
22	8.91	7.85	58.09	1.84	19.96	10.54	1.02	73126.87
23	7.12	16.37	59.26	0.69	23.10	9.70	0.99	76087.17
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.44	14.37	54.41	2.01	19.56	10.68	1.01	72324.54
最大值	11.27	19.60	79.56	3.10	23.10	11.76	1.05	85519.25
發生時間	3	8	19	3	23	18		5
最小值	5.11	7.85	40.64	0.69	16.65	9.35	0.98	65960.56
發生時間	7	22	9	23	11	5		18
零點偏移(率)	-0.01 %	-0.03 %	-0.02 %	-0.01 %		0.01		0.00 %
全幅偏移(率)	-0.30 %	1.32 %	0.27 %	0.99 %		-0.11		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月09日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.10	13.95	58.27	1.11	18.76	10.97	1.15	69355.57
1	0.86	13.66	40.70	0.68	20.68	9.21	1.16	82645.26
2	4.08	11.14	53.55	1.20	19.17	9.66	1.15	80656.50
3	7.85	9.46	61.44	1.35	19.79	9.53	1.15	80351.61
4	4.84	14.06	51.39	1.14	19.63	9.66	1.15	80022.54
5	1.70	16.48	48.83	0.79	20.11	9.42	1.15	79327.86
6	2.40	16.04	48.13	0.48	21.17	9.43	1.13	76727.72
7	2.74	15.12	56.14	0.51	21.00	9.72	1.14	78941.38
8	0.94	14.75	52.77	0.38	21.49	9.49	1.14	79755.10
9	1.49	14.51	45.08	0.54	21.07	9.19	1.14	85857.37
10	8.34	19.25	62.86	1.48	19.28	9.44	1.15	83671.55
11	10.03	11.03	64.75	1.56	18.68	10.12	1.15	78430.94
12	8.16	14.20	52.01	1.16	20.49	9.60	1.15	80629.96
13	8.22	18.55	60.96	1.66	18.52	9.77	1.15	79018.62
14	9.91	12.46	62.80	2.08	18.58	9.70	1.15	80117.63
15	9.55	17.23	68.04	1.92	18.69	9.77	1.15	78561.11
16	9.52	15.83	47.18	1.58	19.45	9.43	1.15	76753.82
17	4.33	16.66	56.76	1.26	18.70	10.33	1.15	73794.11
18	5.30	無效	46.32	0.96	20.70	9.32	1.15	77812.48
19	4.63	8.95	51.82	1.25	18.91	9.60	1.15	73091.99
20	7.90	9.77	51.05	1.28	18.72	9.63	1.15	75954.88
21	10.58	8.98	45.58	1.49	19.05	9.18	1.15	79929.22
22	9.30	6.47	66.19	1.29	18.94	9.78	1.15	76591.51
23	10.28	19.70	55.33	1.49	18.50	9.56	1.15	79089.77
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	23	24	24	24	24	24	24
平均值	5.96	13.84	54.50	1.19	19.59	9.65	1.15	78628.69
最大值	10.58	19.70	68.04	2.08	21.49	10.97	1.17	85857.37
發生時間	21	23	15	14	8	0		9
最小值	0.10	6.47	40.70	0.38	18.50	9.18	1.12	69355.57
發生時間	0	22	1	8	23	21		0
零點偏移(率)	-0.05 %	0.00 %	-0.06 %	-0.06 %		-0.03		-0.10 %
全幅偏移(率)	0.04 %	0.92 %	0.27 %	0.58 %		-0.16		0.00 %
有效比率	100.00 %	95.83%	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月09日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.73	11.82	59.63	2.46	17.99	10.33	0.99	81563.45
1	4.97	12.21	59.49	2.50	17.27	10.76	1.02	77534.17
2	5.33	10.36	58.30	2.56	17.15	10.54	1.05	79226.64
3	4.58	11.17	57.86	2.44	17.90	10.13	1.04	81981.69
4	4.03	12.99	61.57	2.46	18.06	10.34	1.02	79367.39
5	2.52	13.42	59.31	2.44	18.18	10.14	0.99	83132.23
6	2.64	11.77	66.32	2.57	18.62	10.09	1.00	85228.96
7	2.37	14.12	58.99	2.13	20.55	9.69	1.06	81330.27
8	4.98	14.05	56.61	2.12	17.66	9.81	1.04	85180.99
9	3.67	16.90	56.13	2.03	18.54	10.24	1.07	82507.76
10	3.49	17.80	47.34	2.05	17.99	9.51	1.01	79870.90
11	2.40	17.10	43.13	2.27	14.71	10.37	1.01	73351.16
12	3.39	14.99	53.41	2.41	16.10	10.51	1.04	74098.98
13	5.82	14.90	58.58	2.39	16.64	10.32	1.05	79249.64
14	5.68	17.41	54.15	2.34	16.73	10.32	1.05	77825.64
15	7.47	13.98	49.32	2.51	16.14	10.38	1.05	76673.28
16	3.15	14.66	70.73	2.28	17.11	10.93	1.05	71014.39
17	1.23	14.62	52.85	2.01	17.92	10.13	1.07	78867.70
18	4.27	15.58	53.26	2.21	17.47	10.26	1.06	79138.41
19	8.07	10.75	49.70	2.41	17.79	10.00	1.03	79838.07
20	6.92	3.85	62.60	2.42	16.87	10.44	0.99	75885.88
21	8.87	8.28	67.98	2.70	16.48	10.15	1.01	79623.19
22	8.75	14.02	62.05	2.71	16.68	10.50	1.05	79275.79
23	5.54	無效	71.91	2.34	18.39	10.07	1.02	82029.97
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	23	24	24	24	24	24	24
平均值	4.79	13.34	57.97	2.37	17.46	10.25	1.03	79324.86
最大值	8.87	17.80	71.91	2.71	20.55	10.93	1.08	85228.96
發生時間	21	10	23	22	7	16		6
最小值	1.23	3.85	43.13	2.01	14.71	9.51	0.99	71014.39
發生時間	17	20	11	17	11	10		16
零點偏移(率)	-0.02 %	-0.02 %	-0.19 %	-0.07 %		-0.01		0.00 %
全幅偏移(率)	0.00 %	0.96 %	-0.38 %	0.58 %		0.32		0.00 %
有效比率	100.00 %	95.83%	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								