

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月03日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.04	12.35	60.60	2.24	18.98	10.57	1.23	85266.24
1	10.08	13.33	56.00	3.14	17.32	10.78	1.23	85345.38
2	10.73	12.81	59.42	2.72	17.31	11.21	1.24	82339.71
3	6.64	13.13	58.85	1.94	18.80	10.70	1.23	85526.45
4	7.91	12.34	52.24	2.74	18.41	10.42	1.20	85508.21
5	9.17	12.23	56.12	2.00	16.95	10.93	1.21	91848.28
6	9.36	12.83	57.73	2.32	15.81	11.13	1.23	81963.34
7	4.29	13.27	56.15	3.05	15.90	11.04	1.23	82368.12
8	5.44	11.66	56.93	4.06	15.83	11.34	1.25	81795.68
9	3.07	11.57	55.36	4.01	16.40	11.21	1.23	82808.52
10	5.36	11.62	58.00	4.72	15.63	11.36	1.24	82482.68
11	3.24	12.62	65.10	4.37	15.57	12.08	1.25	76275.80
12	1.86	13.43	49.84	4.10	16.00	11.12	1.23	83811.25
13	4.05	12.93	55.18	5.07	15.28	11.39	1.22	82170.91
14	12.13	10.94	50.37	2.32	15.42	11.28	1.23	80863.62
15	9.15	13.12	53.11	0.64	14.62	11.66	1.23	80091.58
16	11.46	12.53	57.70	2.01	15.32	11.47	1.21	81219.92
17	6.14	11.77	52.55	1.58	15.32	11.49	1.24	81259.46
18	11.12	11.72	49.98	1.71	16.45	11.16	1.24	83064.07
19	9.07	12.94	49.02	2.30	16.11	11.24	1.23	82455.36
20	8.39	13.49	48.11	1.80	15.16	11.40	1.22	82039.98
21	8.74	11.65	50.66	0.56	15.86	11.34	1.23	82296.46
22	12.35	11.49	53.71	1.23	16.01	11.43	1.24	81443.64
23	3.90	11.40	55.18	2.80	17.04	11.02	1.25	83888.76
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.61	12.38	54.91	2.64	16.31	11.20	1.23	82838.89
最大值	12.35	13.49	65.10	5.07	18.98	12.08	1.25	91848.28
發生時間	22	20	11	13	0	11		5
最小值	1.86	10.94	48.11	0.56	14.62	10.42	1.20	76275.80
發生時間	12	14	20	21	15	4		11
零點偏移(率)	-0.06 %	-0.01 %	-0.01 %	0.00 %		-0.01	-0.01	0.10 %
全幅偏移(率)	0.41 %	-1.38 %	0.53 %	-0.04 %		0.13	-0.06	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月03日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.14	12.48	46.67	1.85	18.30	10.25	0.97	80295.27
1	0.15	11.93	54.06	1.97	18.52	10.36	0.97	81884.12
2	0.16	12.17	53.09	0.93	18.72	10.61	0.98	82421.28
3	0.12	12.54	57.80	1.78	17.96	10.56	0.98	81674.10
4	0.11	12.41	58.70	1.43	17.82	10.97	0.98	80882.95
5	0.10	12.67	60.71	2.02	17.17	11.19	0.97	79762.48
6	0.62	13.66	57.49	1.44	18.19	11.01	1.00	79584.54
7	0.21	13.45	55.36	1.58	17.87	10.85	1.02	82638.07
8	0.12	13.30	58.13	2.18	17.02	10.79	1.02	82870.28
9	0.14	13.53	55.21	2.08	17.14	10.69	1.02	83212.93
10	0.12	13.47	54.62	2.11	16.16	10.97	1.02	80718.92
11	0.19	14.20	52.85	2.16	15.39	10.80	1.00	79208.30
12	0.17	13.28	61.03	1.07	16.69	10.83	1.01	79138.89
13	0.15	13.40	52.09	1.39	16.29	10.65	0.99	76907.37
14	0.39	11.30	56.81	1.81	16.61	10.55	0.99	77886.47
15	0.26	12.56	63.51	2.67	15.56	10.99	0.99	77994.25
16	0.83	11.46	48.23	2.02	16.78	10.26	0.98	78617.08
17	0.59	11.69	48.98	2.40	16.56	10.23	1.00	77734.02
18	0.65	11.60	47.55	2.03	17.06	10.34	0.99	80283.53
19	0.71	11.63	51.76	2.02	16.92	10.47	1.00	80036.06
20	0.36	12.15	64.44	2.79	15.82	10.95	1.02	80473.15
21	0.67	11.90	61.43	2.25	16.27	10.83	1.02	81416.37
22	0.59	12.11	64.48	2.15	16.28	11.04	1.02	81843.22
23	0.78	11.76	48.35	1.21	18.30	10.37	1.02	79890.29
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	0.35	12.53	55.56	1.89	17.06	10.69	1.00	80307.25
最大值	0.83	14.20	64.48	2.79	18.72	11.19	1.03	83212.93
發生時間	16	11	22	20	2	5		9
最小值	0.10	11.30	46.67	0.93	15.39	10.23	0.96	76907.37
發生時間	5	14	0	2	11	17		13
零點偏移(率)	-0.14 %	0.00 %	-0.09 %	-0.01 %		-0.03	-0.01	-0.20 %
全幅偏移(率)	0.14 %	0.10 %	-0.08 %	-1.26 %		-0.04	0.00	-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月03日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.68	11.78	52.87	2.56	18.27	9.55	1.32	74278.49
1	8.91	12.27	57.02	2.71	19.08	9.51	1.31	74417.35
2	8.10	12.18	56.02	2.84	17.94	9.43	1.31	75209.81
3	8.05	11.01	51.78	2.89	19.07	9.51	1.35	74789.82
4	6.87	11.23	46.16	2.75	17.44	9.66	1.36	75502.05
5	6.14	11.30	57.77	2.70	17.83	10.02	1.36	73933.74
6	7.90	11.09	51.05	2.88	17.38	9.81	1.36	75360.08
7	9.29	10.82	52.07	3.13	18.08	9.58	1.33	73823.95
8	9.71	11.00	51.51	2.93	18.05	9.77	1.34	75014.51
9	7.99	11.04	51.39	2.77	18.23	9.79	1.32	74448.40
10	9.69	10.99	51.50	2.71	17.88	9.79	1.35	74444.68
11	8.77	11.00	50.74	2.71	17.75	9.79	1.30	75000.91
12	9.93	10.94	49.88	2.77	18.21	9.68	1.33	75479.34
13	8.67	10.94	46.84	2.55	18.61	9.41	1.34	75257.72
14	8.59	6.99	38.14	2.94	18.66	8.61	1.32	73258.34
15	7.63	5.42	40.78	2.48	18.12	8.71	1.32	72413.37
16	12.28	10.15	39.35	3.54	17.91	8.94	1.29	72740.18
17	5.96	10.81	38.03	2.36	18.36	9.22	1.31	73440.97
18	9.46	11.07	46.29	2.48	18.04	9.46	1.30	75238.75
19	7.89	11.36	44.35	3.36	17.32	9.34	1.32	73510.51
20	8.37	11.37	38.71	4.06	18.73	8.57	1.31	72273.05
21	11.11	11.08	40.62	3.04	17.26	9.03	1.31	73235.96
22	9.04	11.11	40.50	3.17	17.92	8.88	1.31	74293.17
23	9.36	10.96	42.44	2.72	17.77	9.18	1.31	72446.98
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.68	10.75	47.33	2.88	18.08	9.38	1.32	74158.84
最大值	12.28	12.27	57.77	4.06	19.08	10.02	1.39	75502.05
發生時間	16	1	5	20	1	5		4
最小值	5.96	5.42	38.03	2.36	17.26	8.57	1.27	72273.05
發生時間	17	15	17	17	21	20		20
零點偏移(率)	-0.13 %	-0.03 %	-0.03 %	-0.01 %		-0.03	-0.01	-0.10 %
全幅偏移(率)	2.05 %	1.87 %	2.21 %	0.36 %		0.37	0.04	-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								