

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 113年09月03日

報表日期: 113年09月03日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.85	5.07	56.61	1.62	16.94	11.71	0.90	80803.90
1	5.24	4.52	54.54	0.60	19.23	11.28	0.90	82466.59
2	9.77	5.26	36.51	1.72	16.74	11.54	0.90	82102.54
3	7.52	8.51	38.98	2.57	15.52	12.19	0.90	78771.99
4	6.79	7.92	50.20	1.20	16.75	12.00	0.90	79434.75
5	8.80	12.66	54.26	1.14	17.07	11.49	0.92	77562.76
6	8.41	3.20	44.03	1.10	17.42	11.68	0.92	79399.00
7	8.99	2.96	40.70	1.51	16.45	11.74	0.92	79680.63
8	8.57	2.63	44.11	1.62	17.25	11.78	0.91	80385.16
9	8.01	2.74	46.64	0.94	17.86	11.65	0.91	81153.83
10	7.79	2.65	36.56	1.35	16.28	11.98	0.91	78595.52
11	5.05	3.55	37.41	0.79	17.38	11.79	0.90	79228.93
12	4.47	3.82	47.05	0.74	16.97	11.85	0.90	79387.97
13	8.11	3.81	61.58	1.06	17.17	11.87	0.90	79396.98
14	7.90	3.86	54.84	1.12	17.68	11.49	0.90	82960.93
15	11.16	7.30	57.48	3.42	14.85	12.17	0.92	78898.98
16	7.05	3.65	57.42	3.01	16.00	12.00	0.92	79252.09
17	8.28	3.59	64.66	1.30	16.82	11.87	0.92	80606.01
18	7.80	4.62	57.37	1.38	16.68	11.73	0.92	81654.18
19	7.20	5.07	54.00	1.15	17.18	11.60	0.92	82102.62
20	7.56	9.20	60.25	2.82	15.87	11.88	0.92	80655.54
21	7.51	5.34	60.06	1.71	17.06	11.74	0.91	81237.68
22	7.32	4.59	60.26	1.31	17.03	11.73	0.91	80999.69
23	6.28	4.47	64.31	0.81	18.51	11.60	0.91	80822.60
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.73	5.04	51.66	1.50	16.95	11.77	0.91	80315.04
最 大 值	11.16	12.66	64.66	3.42	19.23	12.19	0.92	82960.93
發生時間	15	5	17	15	1	3		14
最 小 值	4.47	2.63	36.51	0.60	14.85	11.28	0.90	77562.76
發生時間	12	8	2	1	15	1		5
零點偏移(率)	0.00 %	0.00 %	-0.03 %	-0.00 %		-0.08		0.00 %
全幅偏移(率)	0.00 %	-0.13 %	-0.18 %	0.34 %		-0.03		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年09月03日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	1.45	3.45	59.98	0.41	15.70	11.40	1.85	76439.50
1	5.26	3.95	59.72	0.82	14.90	11.66	1.84	73814.53
2	4.19	3.87	55.12	0.80	15.75	11.31	1.83	74083.01
3	5.93	4.11	51.31	1.06	14.71	11.02	1.81	75171.01
4	5.64	3.64	54.21	0.40	16.49	10.68	1.78	78219.98
5	5.94	3.78	50.27	0.36	16.68	10.97	1.80	76667.79
6	7.47	3.98	53.55	1.00	17.02	10.99	1.81	77659.54
7	2.58	3.01	49.63	1.05	15.26	11.18	1.82	78516.26
8	6.11	1.00	46.88	0.42	16.96	10.78	1.86	74893.46
9	2.37	1.14	47.52	0.24	17.18	10.72	1.81	75240.36
10	4.86	2.32	53.19	0.24	18.19	10.56	1.85	76852.47
11	2.38	2.68	44.29	0.23	17.10	10.83	1.88	74653.00
12	5.13	3.65	47.39	0.21	17.96	10.55	1.88	76398.35
13	4.86	2.34	55.78	0.29	17.53	10.71	1.85	77607.92
14	5.19	2.76	53.19	0.33	17.10	11.02	1.82	79294.35
15	3.20	3.69	51.56	0.55	15.94	11.33	1.83	77387.63
16	4.38	2.63	58.66	0.67	15.92	11.26	1.86	78279.95
17	6.08	2.83	58.31	0.84	15.50	11.41	1.88	77583.08
18	2.53	5.80	58.21	0.36	17.18	11.11	1.88	78261.53
19	2.69	5.89	56.88	0.45	16.42	11.03	1.88	80173.66
20	2.85	6.52	50.32	0.70	15.57	11.33	1.88	78511.34
21	6.43	7.83	46.04	0.98	15.28	11.41	1.88	77569.35
22	2.63	9.53	50.77	0.33	16.81	11.14	1.88	78420.85
23	7.77	6.42	54.18	0.26	18.04	11.04	1.88	78279.27
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	4.50	4.03	52.79	0.54	16.47	11.06	1.85	77082.42
最 大 值	7.77	9.53	59.98	1.06	18.19	11.66	1.89	80173.66
發生時間	23	22	0	3	10	1		19
最 小 值	1.45	1.00	44.29	0.21	14.71	10.55	1.77	73814.53
發生時間	0	8	11	12	3	12		1
零點偏移(率)	-0.02 %	-0.01 %	-0.05 %	-0.00 %		-0.06		0.00 %
全幅偏移(率)	0.02 %	-0.25 %	-0.31 %	-0.17 %		0.06		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								