

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 113年12月30日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.94	2.80	46.71	0.81	15.82	11.74	1.31	79316.82
1	8.13	4.79	40.27	1.54	16.19	11.69	1.30	81107.21
2	10.72	3.66	50.65	2.10	14.32	11.96	1.29	79582.90
3	9.45	4.30	43.72	2.19	13.85	12.06	1.29	78788.99
4	11.90	3.30	52.30	2.38	14.15	12.34	1.29	75666.83
5	4.09	3.45	47.53	1.47	14.91	11.94	1.28	74370.52
6	5.45	2.95	46.71	1.30	15.71	11.79	1.28	81327.52
7	1.94	3.30	55.84	1.76	14.66	12.68	1.31	74073.14
8	8.15	3.02	48.72	1.58	15.64	12.10	1.29	78425.46
9	8.95	5.63	47.75	1.40	14.95	12.17	1.29	77935.71
10	9.56	3.16	55.82	1.00	15.60	11.66	1.28	82454.07
11	9.72	3.36	44.10	2.38	13.95	12.00	1.25	80889.20
12	11.72	4.00	43.77	2.93	13.80	12.01	1.25	80940.33
13	10.33	2.66	49.74	1.70	15.24	11.81	1.26	81500.43
14	8.15	2.82	50.13	1.48	15.00	11.90	1.25	80665.98
15	9.03	2.84	60.58	1.08	15.21	11.97	1.24	79910.59
16	7.32	3.31	50.34	2.15	13.82	12.00	1.25	80760.69
17	8.43	3.38	41.76	1.84	14.90	11.76	1.24	82227.05
18	8.40	3.00	39.37	1.40	15.22	11.49	1.23	84019.52
19	8.80	4.06	43.25	0.90	15.82	11.53	1.24	82851.86
20	8.06	2.98	48.65	0.89	16.12	11.31	1.24	84343.07
21	10.60	2.97	51.88	0.81	16.59	11.36	1.24	83337.13
22	5.61	3.08	61.75	0.75	16.20	12.00	1.25	78684.25
23	8.03	3.23	58.27	0.70	17.18	11.42	1.24	82137.57
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.40	3.42	49.15	1.52	15.20	11.86	1.27	80221.54
最大值	11.90	5.63	61.75	2.93	17.18	12.68	1.37	84343.07
發生時間	4	9	22	12	23	7		20
最小值	1.94	2.66	39.37	0.70	13.80	11.31	1.23	74073.14
發生時間	7	13	18	23	12	20		7
零點偏移(率)	-0.67 %	-0.01 %	-0.11 %	0.00 %		-0.10		0.30 %
全幅偏移(率)	0.00 %	0.71 %	0.04 %	0.63 %		-0.16		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 113年12月30日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.75	8.17	48.05	2.26	14.38	10.56	1.10	75461.79
1	6.49	5.65	47.37	2.52	16.94	10.39	1.10	75803.73
2	6.35	7.68	50.48	3.03	13.75	10.94	1.10	75865.65
3	6.69	1.61	49.19	2.89	13.69	11.10	1.10	75053.42
4	7.27	2.62	48.66	3.16	13.86	11.15	1.10	74391.05
5	4.22	2.02	51.12	1.66	15.33	11.04	1.10	73087.68
6	2.23	1.73	46.10	2.40	14.97	11.34	1.10	78966.18
7	4.53	1.71	39.31	2.79	13.70	11.34	1.10	76720.20
8	7.30	0.83	42.54	2.72	14.13	11.30	1.10	78633.01
9	6.20	7.63	50.48	2.23	14.87	10.91	1.08	77524.66
10	8.42	1.67	51.53	2.71	13.31	11.26	1.06	75247.77
11	8.55	5.87	41.51	2.80	13.47	11.19	1.04	72278.81
12	6.34	2.97	44.39	2.05	13.88	10.97	1.04	72623.51
13	5.80	15.01	46.84	2.32	13.73	11.05	1.04	76594.35
14	2.74	7.51	44.09	3.07	12.62	11.56	1.05	76946.94
15	2.68	3.00	46.27	2.33	13.04	11.17	1.05	76262.21
16	7.01	1.42	57.87	1.59	13.23	11.04	1.06	78286.52
17	5.90	3.24	46.47	1.14	13.40	10.86	1.04	76557.76
18	6.62	2.00	46.77	1.15	13.63	10.82	1.05	76831.88
19	7.21	2.81	51.12	1.04	14.47	10.88	1.06	79387.16
20	8.11	3.29	50.03	1.40	13.97	10.71	1.06	79962.34
21	9.53	3.81	55.29	2.81	14.00	10.65	1.06	77573.21
22	7.70	4.09	59.19	1.60	15.45	10.80	1.06	77076.66
23	7.99	1.52	54.52	1.97	15.26	10.91	1.07	79672.46
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.44	4.08	48.72	2.23	14.13	11.00	1.07	76533.71
最大值	9.53	15.01	59.19	3.16	16.94	11.56	1.10	79962.34
發生時間	21	13	22	4	1	14		20
最小值	2.23	0.83	39.31	1.04	12.62	10.39	1.03	72278.81
發生時間	6	8	7	19	14	1		11
零點偏移(率)	-0.05 %	-0.02 %	-0.03 %	0.00 %		-0.03		0.00 %
全幅偏移(率)	0.14 %	0.34 %	0.45 %	0.31 %		-0.10		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 113年12月30日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.07	2.24	49.40	2.14	15.48	9.73	1.52	74041.21
1	8.96	2.91	48.91	1.92	16.41	9.86	1.53	73671.92
2	8.96	5.60	42.73	2.67	14.38	10.30	1.53	74790.86
3	10.02	1.35	53.96	2.67	15.08	10.14	1.53	76761.42
4	8.08	1.07	52.88	2.69	14.25	10.45	1.55	74464.04
5	7.16	9.34	57.44	1.34	17.15	9.93	1.55	76879.74
6	9.56	5.69	50.85	2.10	16.71	9.96	1.54	76886.71
7	15.77	2.65	42.82	2.45	15.25	10.50	1.52	73984.17
8	15.24	2.03	44.76	2.71	14.75	10.42	1.52	73961.44
9	10.55	4.90	55.08	3.30	14.25	10.34	1.52	74879.04
10	5.79	1.30	51.29	1.77	14.59	10.41	1.52	72947.93
11	7.26	2.31	44.10	2.55	14.45	10.19	1.51	73079.92
12	6.81	5.71	46.93	2.69	13.23	10.52	1.50	72744.27
13	5.48	1.33	58.94	1.33	14.98	10.29	1.51	73683.03
14	7.18	7.15	51.26	1.07	15.48	10.11	1.51	75246.82
15	7.40	2.63	53.67	2.63	14.29	10.06	1.50	76018.28
16	6.16	2.74	49.50	1.92	14.72	10.24	1.51	75316.98
17	3.18	1.75	50.15	1.60	14.07	10.33	1.51	75937.97
18	5.85	1.26	52.55	1.49	14.85	10.27	1.51	77858.73
19	6.89	2.81	55.91	1.51	14.65	10.34	1.52	78441.04
20	7.20	1.93	54.07	1.69	14.21	10.46	1.52	78256.91
21	9.15	2.04	58.17	3.51	14.34	10.40	1.52	78795.04
22	6.53	2.86	55.24	3.28	13.91	10.77	1.52	75426.81
23	9.12	3.67	56.32	1.42	14.50	10.73	1.52	74312.48
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.22	3.22	51.54	2.19	14.83	10.28	1.52	75349.45
最大值	15.77	9.34	58.94	3.51	17.15	10.77	1.56	78795.04
發生時間	7	5	13	21	5	22		21
最小值	3.18	1.07	42.73	1.07	13.23	9.73	1.49	72744.27
發生時間	17	4	2	14	12	0		12
零點偏移(率)	-0.14 %	-0.01 %	-0.05 %	-0.01 %		-0.01		0.20 %
全幅偏移(率)	0.02 %	0.02 %	-0.47 %	0.02 %		0.27		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								