

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年12月11日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.94	3.47	50.48	1.15	15.81	10.80	1.79	77262.20
1	12.80	6.37	49.49	2.06	15.57	11.24	1.79	78056.22
2	11.48	4.14	60.38	2.81	13.74	11.21	1.79	74053.36
3	9.95	3.35	62.22	2.04	15.21	11.28	1.79	72470.62
4	12.12	4.34	50.99	2.19	15.21	11.22	1.78	79179.78
5	10.23	3.62	52.65	1.38	15.75	10.97	1.79	81343.42
6	11.24	4.61	51.12	2.59	14.46	11.27	1.79	80210.15
7	12.61	2.35	54.23	2.68	13.98	11.41	1.82	74415.52
8	13.18	5.93	38.34	2.50	13.03	10.87	1.83	72131.60
9	10.13	1.77	41.62	1.27	15.19	10.71	1.82	75917.89
10	9.27	1.95	45.93	1.05	15.43	10.61	1.81	77555.44
11	10.43	1.72	44.77	1.58	14.90	10.75	1.81	74840.41
12	9.05	1.77	56.94	1.20	15.48	10.87	1.81	77084.16
13	9.53	1.36	51.93	0.79	15.13	10.80	1.81	78965.94
14	9.33	2.05	50.69	1.03	14.22	10.98	1.80	78015.81
15	11.20	1.58	51.98	1.35	14.32	11.01	1.81	77787.12
16	12.09	3.65	50.48	1.23	14.69	10.78	1.81	78808.42
17	7.60	1.50	55.77	3.68	16.66	10.26	1.81	81022.41
18	9.37	2.65	50.12	1.86	15.93	10.41	1.81	81201.66
19	9.57	1.83	55.55	4.04	14.67	10.73	1.81	77142.72
20	8.90	3.33	60.86	4.65	14.39	10.98	1.81	76391.90
21	7.77	4.13	61.99	3.23	14.22	11.00	1.81	76574.98
22	7.99	3.82	66.44	3.30	14.45	11.12	1.81	76104.02
23	9.97	9.13	52.14	2.64	14.65	10.77	1.81	79343.77
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	10.24	3.35	52.80	2.18	14.88	10.92	1.81	77328.31
最 大 值	13.18	9.13	66.44	4.65	16.66	11.41	1.84	81343.42
發生時間	8	23	22	20	17	7		5
最 小 值	7.60	1.36	38.34	0.79	13.03	10.26	1.78	72131.60
發生時間	17	13	8	13	8	17		8
零點偏移(率)	-0.05 %	0.00 %	0.00 %	0.00 %		-0.01		-0.10 %
全幅偏移(率)	0.02 %	0.02 %	0.02 %	0.02 %		0.25		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								