

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月20日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.83	12.17	50.72	1.83	15.82	11.57	1.29	76947.11
1	9.19	12.39	63.62	1.85	16.46	11.27	1.29	80966.99
2	15.40	11.80	48.14	2.86	15.71	11.39	1.29	80380.13
3	8.68	12.16	44.59	2.27	15.10	11.58	1.29	77656.29
4	13.41	13.03	48.96	2.91	15.54	11.36	1.29	81810.87
5	9.11	11.69	61.07	2.82	15.09	11.63	1.35	80899.52
6	11.35	11.69	62.69	3.14	14.90	11.62	1.36	79021.71
7	10.00	11.99	63.40	3.63	14.63	11.86	1.36	76873.24
8	10.12	12.30	55.73	3.16	15.37	11.34	1.37	81618.57
9	8.50	12.74	44.90	3.49	13.09	12.16	1.36	75226.03
10	9.17	13.76	39.55	2.44	13.77	12.42	1.37	72262.44
11	9.73	12.81	59.82	2.81	14.26	12.16	1.36	73847.39
12	9.48	12.86	49.16	2.37	14.70	12.22	1.36	74189.35
13	8.71	12.28	49.27	1.86	15.39	11.91	1.33	78064.18
14	6.37	15.36	50.80	1.61	14.50	13.79	1.37	62075.64
15	7.38	14.46	43.18	1.22	14.93	13.37	1.42	65998.16
16	6.16	12.65	52.96	0.69	16.76	12.13	1.41	74654.47
17	10.19	12.19	52.81	0.42	18.98	11.48	1.36	78061.04
18	9.88	10.98	56.42	0.40	19.82	10.28	1.34	86762.23
19	8.91	11.17	48.54	0.72	17.63	10.78	1.38	84546.58
20	10.32	11.59	43.19	1.01	16.22	11.32	1.38	81869.36
21	8.95	11.73	45.38	0.98	16.46	11.45	1.36	81042.68
22	9.12	11.88	40.73	0.73	17.30	11.46	1.36	79825.67
23	9.19	12.18	58.08	1.02	18.46	11.56	1.36	77387.56
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.59	12.41	51.40	1.93	15.87	11.75	1.35	77582.80
最大值	15.40	15.36	63.62	3.63	19.82	13.79	1.47	86762.23
發生時間	2	14	1	7	18	14		18
最小值	6.16	10.98	39.55	0.40	13.09	10.28	1.29	62075.64
發生時間	16	18	10	18	9	18		14
零點偏移(率)	-0.03 %	-0.01 %	-0.03 %	-0.01 %		-0.05	-0.01	0.40 %
全幅偏移(率)	-2.22 %	-2.55 %	-1.26 %	-1.48 %		0.01	-0.06	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月20日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.64	10.87	52.17	0.72	16.08	9.79	1.05	76367.52
1	9.99	13.78	50.96	1.51	15.91	10.03	1.04	80525.67
2	10.00	11.67	51.51	1.86	14.65	10.93	1.05	75391.81
3	12.76	10.72	46.68	1.63	16.58	10.29	1.06	76124.70
4	9.26	11.00	59.08	1.95	14.27	10.98	1.06	81253.85
5	9.17	10.91	51.56	1.59	15.96	10.69	1.06	75412.57
6	8.85	12.53	53.78	2.75	15.03	11.38	1.05	73413.69
7	8.00	12.07	55.83	2.27	15.55	10.95	1.05	74430.29
8	7.74	12.00	48.01	3.04	14.20	10.91	1.04	75208.56
9	8.65	12.72	56.83	2.31	14.73	11.33	1.04	73955.27
10	12.34	11.84	52.77	1.79	14.42	10.81	1.05	79908.57
11	10.20	13.25	53.50	2.51	13.48	11.60	1.05	74680.84
12	8.60	11.94	35.87	1.67	17.31	10.33	1.02	77866.93
13	7.97	12.61	44.77	1.61	15.39	11.30	1.02	71128.91
14	8.45	12.15	46.03	1.33	16.37	10.85	1.02	74753.04
15	7.65	12.33	44.17	0.77	18.15	10.28	1.02	78815.79
16	10.48	12.37	48.63	0.84	17.98	10.19	1.02	84109.71
17	3.47	12.92	64.44	0.90	17.14	11.39	1.04	73224.85
18	8.14	12.14	46.71	0.60	18.95	10.55	1.02	79062.95
19	10.14	11.83	47.47	0.55	19.73	10.09	1.04	85301.37
20	8.40	11.66	46.87	0.62	19.46	9.97	1.04	84979.79
21	10.53	11.86	37.29	1.05	17.93	10.18	1.04	82793.64
22	8.95	12.07	45.39	0.84	17.65	10.66	1.04	79165.70
23	10.66	12.40	42.58	0.65	18.04	10.42	1.04	78295.58
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.17	12.07	49.29	1.47	16.46	10.66	1.04	77757.15
最大值	12.76	13.78	64.44	3.04	19.73	11.60	1.09	85301.37
發生時間	3	1	17	8	19	11		19
最小值	3.47	10.72	35.87	0.55	13.48	9.79	1.01	71128.91
發生時間	17	3	12	19	11	0		13
零點偏移(率)	-0.11 %	-0.01 %	-0.06 %	-0.01 %		-0.08	-0.01	0.10 %
全幅偏移(率)	-0.50 %	-0.03 %	-0.36 %	-0.31 %		0.00	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月20日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.64	10.66	54.30	0.85	15.50	8.78	1.43	71403.15
1	11.45	13.42	58.03	2.50	17.83	8.43	1.43	74063.20
2	8.26	12.19	50.69	1.82	15.88	8.91	1.43	71662.33
3	10.59	12.01	53.04	2.11	15.60	9.34	1.43	70381.08
4	8.99	12.21	62.83	1.94	16.76	9.44	1.43	74237.96
5	9.64	12.11	56.79	2.41	14.80	10.10	1.43	71479.48
6	9.43	12.00	50.76	1.99	16.06	9.88	1.43	72689.33
7	6.37	11.99	44.90	2.51	14.93	10.04	1.41	72350.47
8	10.10	11.82	62.27	2.95	14.11	10.62	1.41	68930.30
9	9.50	11.47	57.99	2.75	15.06	10.30	1.42	71690.03
10	9.62	11.18	64.10	2.61	16.69	9.30	1.41	75327.69
11	9.09	12.04	44.83	2.84	15.93	8.93	1.41	74337.21
12	7.51	11.50	45.58	2.04	16.35	9.38	1.40	69120.94
13	9.19	11.27	43.12	2.03	16.74	9.51	1.43	77246.69
14	8.16	12.48	37.57	1.76	16.09	10.42	1.42	70992.81
15	5.41	12.31	53.82	1.83	17.76	10.48	1.41	69760.96
16	6.31	11.41	39.15	1.94	19.24	9.20	1.41	77179.71
17	6.09	11.86	32.39	1.65	18.76	9.32	1.41	76161.20
18	8.52	12.22	44.62	1.53	17.29	10.39	1.40	69871.45
19	8.88	12.61	52.14	1.92	18.91	10.46	1.42	72961.59
20	9.67	9.19	40.76	2.14	20.88	8.75	1.41	80943.74
21	7.64	13.64	50.85	0.43	19.02	8.32	1.40	77766.17
22	7.66	10.08	57.34	0.15	18.98	8.83	1.40	74957.27
23	8.71	11.57	41.19	1.32	18.21	9.69	1.41	70454.27
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.56	11.80	49.96	1.92	16.97	9.53	1.42	73165.38
最大值	11.45	13.64	64.10	2.95	20.88	10.62	1.47	80943.74
發生時間	1	21	10	8	20	8		20
最小值	5.41	9.19	32.39	0.15	14.11	8.32	1.39	68930.30
發生時間	15	20	17	22	8	21		8
零點偏移(率)	-0.10 %	-0.01 %	-0.01 %	0.00 %		-0.16	-0.01	0.10 %
全幅偏移(率)	-1.82 %	0.46 %	1.35 %	0.54 %		0.06	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								