

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年01月04日

報表日期: 114年01月04日

項目 單位 小時\限標	#1-HCl_C ppm	#1-CO_C ppm	#1-NOx_C ppm	#1-SO2_C ppm	#1-H2O %	#1-O2_C %	#1-OPAC %	#1-FLOW_C m3/Hour
0	6.54	3.56	57.58	1.70	15.77	12.06	1.27	79507.33
1	8.24	3.28	60.16	1.44	16.96	11.89	1.26	80145.11
2	7.93	2.89	56.32	1.50	15.54	12.04	1.26	78892.83
3	3.99	3.34	53.85	2.76	13.66	12.40	1.25	76195.65
4	6.61	3.21	53.04	2.63	14.40	12.10	1.24	76995.05
5	4.45	9.87	43.41	2.78	14.06	無效	1.23	76876.06
6	6.83	1.91	37.57	3.30	14.14	12.07	1.23	70400.59
7	2.97	4.56	38.59	1.38	15.73	11.82	1.24	76440.79
8	6.65	2.86	39.43	1.50	15.90	11.80	1.25	77041.16
9	7.76	2.89	44.28	0.83	17.17	11.28	1.28	81205.40
10	10.74	2.80	41.66	1.56	16.23	11.53	1.29	81243.15
11	7.72	2.80	47.51	0.69	16.94	11.73	1.29	79878.90
12	6.28	2.99	51.64	0.88	15.96	12.04	1.29	78725.37
13	6.09	3.36	49.67	1.47	14.95	12.08	1.25	80033.62
14	7.34	4.81	46.67	2.10	14.34	12.22	1.25	78311.60
15	6.32	2.91	54.30	1.56	15.34	12.12	1.24	78509.95
16	9.16	6.47	47.19	2.67	13.49	12.63	1.25	76145.30
17	9.43	4.58	52.70	1.92	14.31	12.20	1.29	79363.59
18	8.69	4.15	60.35	1.05	15.48	11.94	1.29	80437.61
19	8.32	4.09	55.67	1.03	15.93	11.81	1.29	81695.05
20	8.82	5.44	58.34	1.30	15.02	11.82	1.29	81601.03
21	10.43	2.46	53.30	1.26	15.05	11.94	1.29	80245.19
22	8.67	2.76	60.31	0.69	15.86	11.73	1.29	81749.02
23	10.28	4.78	51.16	1.51	15.33	11.79	1.27	81675.66
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	23	24	24
平 均 值	7.51	3.87	50.61	1.65	15.32	11.96	1.27	78888.13
最 大 值	10.74	9.87	60.35	3.30	17.17	12.63	1.29	81749.02
發生時間	10	5	18	6	9	16		22
最 小 值	2.97	1.91	37.57	0.69	13.49	11.28	1.20	70400.59
發生時間	7	6	6	11	16	9		6
零點偏移(率)	-0.01 %	-0.00 %	-0.03 %	0.01 %		0.00		0.30 %
全幅偏移(率)	0.00 %	0.36 %	0.64 %	-0.02 %		-0.18		0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	95.83 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年01月04日

項目 單位 小時\限標	#2-HCl_C ppm	#2-CO_C ppm	#2-NOx_C ppm	#2-SO2_C ppm	#2-H2O %	#2-O2_C %	#2-OPAC %	#2-FLOW_C m3/Hour
0	8.79	3.95	52.42	2.82	14.39	11.45	1.10	78631.28
1	5.59	2.84	60.35	3.22	14.79	11.43	1.10	80968.48
2	7.28	3.04	60.57	3.08	13.50	11.70	1.10	79200.79
3	4.98	5.62	48.93	2.86	13.77	11.32	1.09	78740.36
4	4.32	4.83	50.10	3.11	13.29	11.56	1.08	76864.70
5	0.28	1.75	50.99	3.23	12.74	11.59	1.06	77699.63
6	0.19	2.96	47.39	2.79	14.14	11.24	1.08	72763.99
7	2.41	1.13	51.14	2.97	13.48	11.59	1.10	77414.06
8	2.86	1.61	46.35	2.74	14.06	11.38	1.10	77087.17
9	5.21	1.69	42.79	2.86	14.37	10.93	1.10	76044.22
10	4.90	6.21	46.43	3.09	14.06	10.85	1.10	78514.06
11	5.86	1.01	45.18	3.01	14.19	11.09	1.08	77915.27
12	4.75	1.77	49.69	2.87	13.90	11.30	1.06	78010.09
13	4.01	3.14	46.86	2.72	13.76	11.06	1.06	79806.39
14	7.19	2.88	50.42	3.33	13.58	11.23	1.06	78829.62
15	4.04	1.62	50.53	2.88	12.66	11.50	1.06	77569.01
16	6.88	1.34	51.13	3.07	13.88	11.37	1.08	78378.31
17	7.81	1.51	44.80	2.84	13.75	11.16	1.10	79233.62
18	7.06	1.32	46.22	2.54	14.44	10.94	1.10	78598.59
19	4.76	2.59	47.85	2.41	13.63	11.25	1.10	76747.22
20	6.18	3.22	58.53	2.43	14.93	10.97	1.10	79572.06
21	7.42	2.67	63.10	2.85	13.81	11.31	1.10	78780.17
22	8.85	2.83	62.97	2.67	14.32	11.13	1.10	80024.59
23	8.09	3.16	57.00	1.90	14.98	11.18	1.08	76691.98
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	5.40	2.70	51.32	2.85	13.93	11.27	1.09	78086.90
最 大 值	8.85	6.21	63.10	3.33	14.98	11.70	1.11	80968.48
發生時間	22	10	21	14	23	2		1
最 小 值	0.19	1.01	42.79	1.90	12.66	10.85	1.03	72763.99
發生時間	6	11	9	23	15	10		6
零點偏移(率)	-0.08 %	-0.01 %	0.00 %	-0.01 %		0.00		0.10 %
全幅偏移(率)	0.14 %	0.33 %	0.43 %	0.43 %		-0.25		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年01月04日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.68	5.40	62.35	1.61	15.92	10.13	1.48	76034.66
1	2.90	10.95	58.57	1.60	16.77	10.01	1.47	75491.41
2	4.94	10.13	63.06	2.57	14.40	10.43	1.48	76200.83
3	5.22	6.43	50.10	3.23	14.23	10.49	1.47	77699.56
4	4.83	4.25	46.88	2.62	13.76	10.52	1.48	77372.13
5	4.61	0.77	51.11	2.71	14.70	10.71	1.48	78108.86
6	5.42	1.18	50.18	2.52	13.88	10.97	1.48	77808.55
7	11.75	3.16	47.48	2.61	15.12	10.33	1.48	73284.06
8	11.79	2.10	50.75	2.67	15.11	10.29	1.48	78744.79
9	4.35	2.47	37.98	2.56	16.65	9.89	1.48	77488.59
10	4.11	3.98	39.87	3.42	15.04	10.50	1.47	76019.22
11	7.59	3.39	42.88	4.17	14.46	10.42	1.48	78147.50
12	2.47	3.03	50.64	3.01	14.81	10.28	1.48	77925.50
13	3.03	2.62	49.16	3.28	13.89	10.24	1.48	76594.01
14	2.16	2.95	51.05	3.03	14.00	10.41	1.48	75196.49
15	3.47	7.06	51.32	3.83	14.75	10.20	1.48	73981.15
16	4.08	2.91	54.74	3.83	15.31	10.17	1.48	73395.40
17	5.96	4.06	58.95	3.48	15.11	10.06	1.48	73760.33
18	4.31	6.24	59.30	3.21	14.86	10.02	1.48	73530.31
19	4.92	3.74	55.22	3.16	14.79	9.95	1.48	72816.88
20	2.94	1.42	63.69	2.61	16.56	9.79	1.48	73151.56
21	4.09	1.78	60.07	3.62	16.58	9.60	1.48	77974.20
22	8.45	2.40	52.79	3.75	15.34	9.94	1.49	73968.26
23	6.38	5.15	57.03	3.03	13.81	10.25	1.48	70509.20
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	5.19	4.07	52.72	3.01	14.99	10.23	1.48	75633.48
最 大 值	11.79	10.95	63.69	4.17	16.77	10.97	1.50	78744.79
發生時間	8	1	20	11	1	6		8
最 小 值	2.16	0.77	37.98	1.60	13.76	9.60	1.44	70509.20
發生時間	14	5	9	1	4	21		23
零點偏移(率)	-0.02 %	-0.01 %	-0.19 %	-0.03 %		-0.01		0.20 %
全幅偏移(率)	0.02 %	-0.01 %	0.03 %	0.03 %		0.19		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								