

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年02月19日

報表日期: 114年02月19日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.29	3.67	51.92	0.54	18.52	11.28	1.29	83102.75
1	6.93	4.18	53.67	1.08	19.54	11.39	1.29	81037.35
2	5.79	4.35	37.42	1.11	18.38	11.06	1.28	84208.90
3	8.42	3.49	37.90	1.26	17.19	11.40	1.29	81948.77
4	9.12	4.27	44.79	1.76	16.60	11.47	1.28	82586.45
5	6.76	12.36	51.32	1.65	16.70	11.53	1.24	87499.37
6	7.05	1.59	52.14	1.50	16.67	11.55	1.23	82053.48
7	6.32	1.21	52.89	1.30	15.90	11.89	1.23	78202.22
8	3.46	1.62	63.31	0.39	17.76	11.47	1.23	80805.18
9	7.22	1.44	49.86	0.43	18.65	11.02	1.23	84782.34
10	7.03	1.39	42.62	1.03	15.92	11.80	1.23	79945.79
11	9.33	10.01	34.87	2.25	15.20	11.72	1.23	79388.95
12	12.35	6.88	55.98	3.17	14.50	11.79	1.24	75452.85
13	8.17	2.07	60.23	1.08	17.10	11.58	1.26	78811.02
14	9.23	5.75	53.26	0.99	16.78	11.53	1.28	80511.19
15	8.56	5.45	50.64	1.47	16.30	11.66	1.28	78654.08
16	9.78	3.88	40.20	1.61	15.25	11.41	1.27	77803.49
17	8.88	4.94	52.15	1.35	16.50	11.47	1.28	77453.84
18	9.12	3.72	52.49	0.99	17.50	11.15	1.27	82213.95
19	7.37	3.95	49.25	1.06	16.86	11.54	1.28	78922.09
20	4.60	6.31	58.12	0.69	18.19	11.23	1.28	83680.40
21	3.80	3.94	45.50	1.02	17.14	11.46	1.28	82121.98
22	9.72	3.94	49.42	0.79	17.74	11.28	1.29	83302.59
23	8.39	5.21	46.54	0.58	18.29	11.24	1.29	82707.53
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.74	4.40	49.44	1.21	17.05	11.45	1.26	81133.19
最 大 值	12.35	12.36	63.31	3.17	19.54	11.89	1.30	87499.37
發生時間	12	5	8	12	1	7		5
最 小 值	3.46	1.21	34.87	0.39	14.50	11.02	1.23	75452.85
發生時間	8	7	11	8	12	9		12
零點偏移(率)	-0.01 %	-0.00 %	-0.01 %	0.00 %		-0.26		0.30 %
全幅偏移(率)	0.00 %	-1.24 %	-0.25 %	-0.04 %		-0.25		0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年02月19日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.26	3.17	54.84	0.22	19.89	10.00	1.52	82525.18
1	10.71	6.27	48.06	1.52	18.50	10.49	1.51	81527.80
2	10.06	4.66	45.39	0.61	16.68	10.90	1.51	79311.18
3	6.38	2.46	59.60	1.96	14.03	11.55	1.52	75026.51
4	8.59	2.90	57.29	0.47	16.05	11.23	1.52	77411.86
5	5.61	3.11	55.99	0.42	16.25	11.00	1.52	78318.68
6	8.44	2.42	58.48	0.72	15.91	11.18	1.52	78323.84
7	7.03	5.40	56.75	0.72	15.31	11.10	1.51	76728.68
8	6.90	4.79	56.40	0.58	16.90	10.69	1.50	79050.56
9	7.37	8.79	40.73	0.99	17.00	10.43	1.50	81355.23
10	10.26	5.35	43.13	0.66	16.47	11.02	1.50	79683.62
11	8.11	6.63	48.25	0.58	16.78	10.92	1.52	78531.40
12	8.02	10.01	49.82	1.13	14.85	11.09	1.52	75165.46
13	6.12	5.01	53.89	0.43	16.54	10.87	1.50	76444.92
14	0.80	4.25	54.02	0.64	14.62	11.17	1.52	74307.47
15	6.36	7.58	52.84	0.53	15.48	11.05	1.52	76388.85
16	3.31	3.63	50.82	0.68	15.56	10.81	1.52	78549.41
17	8.99	6.37	55.16	1.05	16.96	10.61	1.52	80969.40
18	3.61	2.52	50.63	0.14	17.49	10.41	1.52	80585.49
19	7.19	4.73	43.91	0.55	17.67	10.21	1.52	78127.67
20	9.77	7.38	44.02	0.51	18.01	10.04	1.52	80417.16
21	3.89	2.80	41.38	0.44	15.97	10.64	1.52	74990.50
22	5.17	2.23	49.55	0.49	16.65	10.73	1.52	76870.73
23	6.89	6.40	51.20	0.58	16.20	10.91	1.52	77207.06
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.99	4.95	50.92	0.69	16.49	10.79	1.51	78242.44
最 大 值	10.71	10.01	59.60	1.96	19.89	11.55	1.54	82525.18
發生時間	1	12	3	3	0	3		0
最 小 值	0.80	2.23	40.73	0.14	14.03	10.00	1.49	74307.47
發生時間	14	22	9	18	3	0		14
零點偏移(率)	-0.14 %	-0.07 %	-0.05 %	-0.00 %		-0.15		-0.10 %
全幅偏移(率)	0.61 %	0.16 %	0.30 %	0.39 %		-0.30		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								