

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年04月01日

報表日期: 114年04月01日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.98	2.88	53.48	0.28	19.52	10.11	1.29	81495.47
1	7.85	3.01	51.61	1.09	19.50	10.16	1.29	85539.78
2	8.90	2.62	59.77	1.13	18.64	10.39	1.29	83929.29
3	8.80	2.59	66.92	0.76	18.78	10.44	1.29	82421.31
4	9.14	2.65	56.24	0.79	18.81	10.27	1.28	83786.46
5	6.77	4.42	51.37	1.07	17.81	10.61	1.28	81782.88
6	7.07	2.76	51.99	1.32	17.70	10.60	1.28	81423.93
7	4.52	2.61	57.29	0.82	18.99	10.35	1.29	80086.85
8	6.53	4.13	50.35	0.93	19.34	9.78	1.28	83203.64
9	5.55	3.19	60.34	0.86	19.55	10.22	1.29	80495.76
10	7.77	5.65	49.37	1.52	18.74	10.16	1.29	83882.79
11	9.07	4.76	46.52	2.38	16.58	11.25	1.29	81530.81
12	6.07	2.62	53.67	1.71	16.78	11.42	1.29	78746.78
13	6.83	2.72	56.47	1.19	18.54	10.72	1.28	82680.29
14	8.19	5.19	56.20	1.06	18.75	9.98	1.28	82560.29
15	7.62	6.31	60.42	0.82	20.03	9.79	1.29	83799.25
16	3.76	2.91	67.96	0.37	21.31	9.41	1.29	84182.84
17	5.64	5.77	62.48	0.25	22.16	9.13	1.29	85440.87
18	8.60	5.24	59.27	0.86	21.15	9.43	1.29	86805.94
19	9.87	5.69	43.63	1.33	19.97	9.69	1.29	84610.59
20	12.01	4.71	48.97	1.19	19.86	9.74	1.29	83050.87
21	8.95	4.65	59.63	0.56	20.72	9.47	1.29	85498.23
22	7.00	5.13	48.58	1.07	18.27	9.98	1.29	81732.35
23	8.92	5.15	47.93	1.39	17.66	10.16	1.29	79772.49
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.48	4.06	55.02	1.03	19.13	10.14	1.29	82852.49
最 大 值	12.01	6.31	67.96	2.38	22.16	11.42	1.30	86805.94
發生時間	20	15	16	11	17	12		18
最 小 值	3.76	2.59	43.63	0.25	16.58	9.13	1.27	78746.78
發生時間	16	3	19	17	11	17		12
零點偏移(率)	-0.31 %	0.00 %	-0.01 %	-0.00 %		0.00		0.30 %
全幅偏移(率)	0.24 %	1.14 %	-0.08 %	0.14 %		0.16		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年04月01日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.32	3.39	51.57	1.49	18.16	10.37	1.06	86327.06
1	5.26	7.52	53.27	2.28	18.53	9.96	1.06	88762.98
2	11.57	4.54	69.69	2.61	17.02	10.50	1.05	86349.54
3	16.79	1.41	58.22	2.94	16.53	10.67	1.05	84582.58
4	16.17	2.24	59.71	2.36	16.70	10.51	1.04	84992.53
5	15.95	2.36	57.45	2.88	16.09	10.72	1.04	83066.34
6	16.27	4.18	61.10	3.21	16.24	10.49	1.06	88286.75
7	15.53	1.43	50.91	3.47	15.49	10.92	1.06	82863.81
8	4.60	1.91	42.78	2.92	15.34	11.12	1.06	80554.93
9	10.43	2.77	51.34	3.51	14.76	11.03	1.06	82443.71
10	9.35	3.73	49.01	3.24	14.30	10.85	1.07	80236.62
11	9.23	7.19	55.02	2.66	16.07	10.46	1.08	84763.91
12	8.33	2.14	49.07	2.19	16.70	10.06	1.07	83825.46
13	8.99	3.05	45.60	2.17	16.93	10.05	1.09	84407.58
14	8.67	4.78	54.02	2.00	15.98	10.49	1.11	83486.67
15	9.44	2.43	56.65	1.82	16.67	10.66	1.10	85344.41
16	9.37	2.76	59.58	1.71	16.97	10.30	1.09	87283.25
17	8.51	3.42	64.45	1.32	17.48	10.86	1.08	82761.23
18	9.00	3.54	62.85	0.78	18.60	10.76	1.08	82723.07
19	10.22	7.45	59.15	1.96	17.33	9.98	1.06	90365.98
20	8.91	8.02	57.50	2.00	17.26	10.17	1.07	86413.79
21	9.03	5.07	54.82	1.89	16.96	10.03	1.10	87545.71
22	8.56	4.21	49.13	1.83	17.07	10.47	1.09	82629.60
23	8.91	4.02	48.67	1.43	16.79	10.59	1.08	83698.75
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	10.18	3.90	55.07	2.28	16.67	10.50	1.07	84738.18
最 大 值	16.79	8.02	69.69	3.51	18.60	11.12	1.14	90365.98
發生時間	3	20	2	9	18	8		19
最 小 值	4.60	1.41	42.78	0.78	14.30	9.96	1.04	80236.62
發生時間	8	3	8	18	10	1		10
零點偏移(率)	-0.03 %	-0.05 %	-0.02 %	0.00 %		0.01		0.10 %
全幅偏移(率)	0.14 %	1.77 %	0.21 %	0.11 %		0.14		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年04月01日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.69	12.69	55.27	0.33	19.93	9.06	1.49	83881.10
1	1.79	9.31	51.44	0.39	20.34	9.12	1.50	86859.78
2	2.03	7.88	52.01	4.58	17.49	9.57	1.51	84127.67
3	5.08	3.16	58.47	0.95	16.44	10.31	1.51	81670.51
4	3.57	4.36	62.37	0.67	16.90	10.13	1.52	83071.34
5	4.69	3.56	60.78	0.89	15.83	10.41	1.51	81318.99
6	4.43	2.14	62.35	0.83	15.76	10.49	1.50	81665.38
7	1.33	2.89	61.71	0.93	15.63	10.50	1.52	78143.15
8	4.69	1.37	60.58	0.94	15.51	10.44	1.52	76123.05
9	3.93	2.70	56.75	0.86	16.46	10.31	1.52	78516.40
10	11.73	4.24	49.81	1.79	15.61	10.39	1.52	80590.05
11	11.15	3.68	53.80	1.80	15.58	10.46	1.52	81149.40
12	8.31	1.52	66.57	1.33	15.25	11.25	1.52	74562.74
13	7.84	4.41	57.71	1.10	16.67	10.16	1.51	79849.10
14	7.46	5.87	55.98	1.23	14.94	10.61	1.52	83801.54
15	6.32	2.20	59.76	0.84	16.49	10.12	1.52	85516.65
16	9.53	7.95	60.01	0.66	17.30	9.68	1.53	85328.61
17	7.01	1.90	62.87	0.54	16.46	10.76	1.53	79595.02
18	6.05	3.63	64.04	0.51	18.26	10.12	1.53	81956.62
19	9.35	3.29	52.16	0.79	18.40	8.96	1.52	87489.42
20	9.31	3.17	51.45	0.90	17.63	9.16	1.52	85030.82
21	4.39	3.76	54.81	0.94	16.08	9.41	1.52	82970.58
22	11.99	3.05	60.41	1.64	16.37	9.76	1.52	83992.99
23	10.89	2.84	57.76	1.34	16.23	9.87	1.52	78911.41
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.44	4.23	57.87	1.12	16.73	10.04	1.52	81921.76
最 大 值	11.99	12.69	66.57	4.58	20.34	11.25	1.56	87489.42
發生時間	22	0	12	2	1	12		19
最 小 值	1.33	1.37	49.81	0.33	14.94	8.96	1.48	74562.74
發生時間	7	8	10	0	14	19		12
零點偏移(率)	-0.06 %	0.01 %	-0.22 %	-0.08 %		0.04		0.00 %
全幅偏移(率)	0.01 %	-0.15 %	0.08 %	0.04 %		0.35		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								