

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月24日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.62	13.07	58.48	1.96	18.82	11.32	1.24	79947.47
1	11.02	12.72	56.62	2.80	19.99	10.87	1.23	82550.07
2	8.50	12.61	61.75	2.52	19.03	10.89	1.22	83332.30
3	9.27	12.58	49.93	2.61	19.02	10.88	1.22	83274.22
4	9.02	12.46	53.13	2.88	18.93	10.79	1.24	83851.15
5	5.15	13.01	50.65	2.58	17.27	11.40	1.20	84080.00
6	8.42	12.93	56.38	2.94	16.15	11.47	1.20	81286.41
7	7.61	13.22	56.13	2.46	16.73	11.63	1.20	79260.41
8	15.91	12.92	59.71	2.37	17.38	11.35	1.20	81619.81
9	5.33	12.66	63.93	1.84	19.13	10.93	1.20	83083.32
10	9.59	12.60	53.18	2.62	17.75	11.06	1.20	83212.42
11	13.28	13.06	62.02	2.81	17.79	11.26	1.21	81618.10
12	6.38	13.11	51.91	2.42	16.95	11.47	1.21	80226.51
13	9.20	12.86	53.21	3.07	16.53	11.42	1.20	81040.42
14	11.08	12.93	54.55	3.05	16.62	11.44	1.20	80564.19
15	9.82	13.27	50.71	3.37	16.18	11.44	1.20	81155.55
16	14.33	13.07	56.76	3.74	16.46	11.58	1.19	80081.71
17	8.70	13.05	53.32	2.38	16.71	11.21	1.19	82544.86
18	14.66	13.68	50.58	2.43	15.81	11.55	1.21	80435.28
19	7.39	13.43	54.08	1.81	16.10	11.68	1.22	79515.00
20	11.96	13.47	55.48	2.05	15.48	11.91	1.23	78199.71
21	5.60	13.21	53.32	1.87	15.71	11.71	1.23	79716.80
22	8.30	13.36	62.34	1.65	17.30	11.51	1.21	79683.16
23	9.51	13.11	51.33	1.73	16.72	11.55	1.20	80117.77
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.32	13.02	55.40	2.50	17.27	11.35	1.21	81266.53
最大值	15.91	13.68	63.93	3.74	19.99	11.91	1.25	84080.00
發生時間	8	18	9	16	1	20		5
最小值	3.62	12.46	49.93	1.65	15.48	10.79	1.18	78199.71
發生時間	0	4	3	22	20	4		20
零點偏移(率)	-0.46 %	0.00 %	-0.02 %	-0.01 %		-0.02	-0.01	0.10 %
全幅偏移(率)	-1.46 %	1.03 %	-0.47 %	0.21 %		-0.23	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月24日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.71	13.20	42.19	1.05	20.95	10.34	1.02	83842.17
1	6.00	13.19	47.15	0.74	21.11	10.20	1.02	84076.06
2	9.93	13.71	51.88	0.95	19.52	10.87	1.03	81801.10
3	5.17	13.93	56.39	1.06	19.51	10.97	1.03	80452.39
4	11.63	13.36	50.01	1.94	19.69	10.44	1.02	84958.56
5	10.66	13.62	56.16	1.79	18.40	10.86	1.02	82416.05
6	6.42	12.42	57.66	1.68	18.62	11.02	1.01	81194.18
7	6.85	12.44	54.36	1.79	17.59	11.08	1.00	81405.30
8	8.15	12.41	56.96	1.17	20.40	10.46	1.02	83615.30
9	6.95	12.17	50.42	1.50	19.51	10.58	1.02	83198.15
10	8.44	12.18	50.03	2.20	18.16	10.74	1.02	83283.06
11	8.67	12.51	47.11	2.56	16.86	11.18	1.02	80570.14
12	8.25	12.38	46.54	2.18	18.64	10.85	1.01	82107.26
13	7.73	12.23	44.94	2.56	18.27	10.76	0.99	83178.92
14	9.99	12.60	53.86	3.29	17.00	11.00	1.01	81915.62
15	10.22	12.73	57.86	2.54	17.13	11.24	1.01	79647.56
16	7.12	12.47	49.99	2.63	18.02	11.00	0.99	80789.29
17	12.24	14.43	42.89	4.13	17.29	10.98	1.02	82305.85
18	5.29	12.39	46.66	3.55	17.81	10.98	1.00	81917.92
19	4.66	12.78	46.61	3.11	16.84	11.21	1.02	80349.85
20	2.82	12.64	49.00	2.71	16.39	11.35	1.02	79526.82
21	4.76	12.46	47.31	2.73	16.76	11.18	0.99	81031.32
22	3.50	12.48	50.49	2.27	17.48	11.12	1.00	80519.62
23	4.22	12.46	53.31	1.99	17.73	11.10	1.01	80297.84
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.52	12.80	50.41	2.17	18.32	10.90	1.01	81850.01
最大值	12.24	14.43	57.86	4.13	21.11	11.35	1.04	84958.56
發生時間	17	17	15	17	1	20		4
最小值	2.82	12.17	42.19	0.74	16.39	10.20	0.97	79526.82
發生時間	20	9	0	1	20	1		20
零點偏移(率)	-0.15 %	-0.09 %	-0.05 %	-0.00 %		-0.05	-0.01	-0.10 %
全幅偏移(率)	-2.06 %	-1.09 %	0.43 %	0.26 %		-0.10	-0.06	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月24日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.18	12.11	53.89	2.57	20.16	9.37	1.29	73116.54
1	5.22	12.31	52.60	2.79	20.67	9.24	1.34	73416.75
2	7.07	12.33	52.84	3.36	19.39	9.33	1.32	73630.66
3	5.47	13.06	52.63	2.88	18.70	9.56	1.31	73957.98
4	5.52	12.52	58.53	2.99	20.17	9.46	1.31	76383.22
5	6.96	12.82	47.87	2.72	19.56	9.14	1.29	77329.85
6	8.53	10.84	58.23	1.05	18.33	9.49	1.29	75396.77
7	2.05	10.69	48.22	1.64	18.30	9.19	1.28	76102.64
8	5.35	10.68	61.00	2.86	20.05	9.08	1.31	80009.82
9	3.64	11.51	61.77	2.94	19.62	10.03	1.29	74655.81
10	7.76	11.25	63.31	2.91	18.45	9.80	1.31	76251.46
11	4.96	11.29	52.88	2.67	16.32	10.03	1.27	73897.50
12	8.64	11.67	57.86	3.15	16.08	10.11	1.29	74198.76
13	3.04	11.63	64.39	2.60	16.56	10.48	1.30	73383.47
14	10.77	11.32	62.37	2.91	17.46	10.11	1.27	74800.09
15	4.84	11.76	57.76	2.72	16.55	10.22	1.27	75009.12
16	10.33	11.43	64.23	3.09	16.89	10.30	1.30	75800.22
17	6.85	11.49	67.77	2.90	17.87	10.25	1.30	74685.93
18	11.45	11.66	60.62	2.93	16.81	10.40	1.27	73724.38
19	10.52	11.65	63.09	3.05	16.34	10.44	1.30	73500.73
20	4.07	11.21	54.52	2.51	17.13	10.07	1.30	73710.21
21	9.49	11.26	59.15	2.95	17.26	9.87	1.27	75443.81
22	5.04	11.11	63.37	2.86	17.68	9.80	1.26	73575.04
23	9.80	10.99	60.86	2.90	17.83	9.80	1.27	75009.21
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.90	11.61	58.32	2.75	18.09	9.82	1.29	74874.58
最大值	11.45	13.06	67.77	3.36	20.67	10.48	1.36	80009.82
發生時間	18	3	17	2	1	13		8
最小值	2.05	10.68	47.87	1.05	16.08	9.08	1.25	73116.54
發生時間	7	8	5	6	12	8		0
零點偏移(率)	-0.05 %	0.00 %	-0.04 %	0.00 %		-0.05	-0.01	-0.20 %
全幅偏移(率)	-2.05 %	0.51 %	0.57 %	0.53 %		0.30	0.00	-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								