

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 113年01月16日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.32	2.98	63.63	0.90	16.66	12.23	1.09	76959.93
1	8.12	7.93	42.06	0.68	18.48	11.37	1.09	83164.62
2	9.66	8.71	42.98	1.48	15.13	11.86	1.10	82012.02
3	9.39	7.67	45.11	1.39	15.39	11.81	1.10	81837.69
4	9.03	8.79	55.93	0.90	16.12	11.84	1.10	80688.33
5	10.54	13.98	37.40	2.12	14.10	12.06	1.10	80921.65
6	9.33	7.75	51.40	1.06	16.01	11.82	1.09	81193.01
7	9.26	9.05	43.63	2.32	13.74	11.99	1.09	81269.01
8	10.82	10.03	41.41	2.11	14.96	11.63	1.09	80929.92
9	8.42	11.58	42.68	1.12	15.25	11.69	1.09	80128.78
10	8.79	6.20	45.59	1.65	14.05	12.00	1.07	78581.32
11	5.37	9.82	57.19	1.22	14.66	12.17	1.06	78553.97
12	12.15	11.43	60.76	1.91	14.11	12.17	1.08	77945.92
13	7.15	13.77	55.08	1.19	15.04	11.88	1.10	78805.74
14	7.61	11.87	69.32	1.47	15.53	11.86	1.12	76529.59
15	9.22	10.92	53.11	0.92	16.31	11.49	1.11	81413.07
16	8.10	10.81	58.56	0.68	17.01	11.68	1.10	81726.97
17	5.16	12.07	42.99	0.83	16.33	11.89	1.09	80220.42
18	2.71	7.56	56.62	0.77	17.12	12.37	1.12	75499.45
19	9.41	2.61	36.98	0.98	15.86	11.82	1.06	81378.12
20	9.41	3.09	34.37	1.89	15.58	11.57	1.06	84231.82
21	9.16	3.08	40.14	1.36	16.67	11.68	1.06	81440.57
22	9.68	3.09	47.58	0.69	17.41	11.43	1.06	83157.84
23	8.04	2.50	46.19	0.58	17.66	11.26	1.08	84439.16
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.45	8.22	48.78	1.26	15.80	11.82	1.09	80542.87
最 大 值	12.15	13.98	69.32	2.32	18.48	12.37	1.25	84439.16
發生時間	12	5	14	7	1	18		23
最 小 值	2.71	2.50	34.37	0.58	13.74	11.26	1.06	75499.45
發生時間	18	23	20	23	7	23		18
零點偏移(率)	-0.01 %	-0.01 %	-0.34 %	-0.02 %		-0.05		0.30 %
全幅偏移(率)	0.02 %	0.72 %	0.13 %	0.52 %		0.07		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年01月16日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	3.08	2.81	39.14	0.43	17.20	9.47	1.06	77967.60
1	2.73	4.84	49.24	0.56	17.58	9.82	1.08	80171.77
2	3.34	3.04	50.82	0.60	16.85	10.27	1.09	80405.75
3	2.98	4.59	49.18	0.81	15.78	10.28	1.09	80299.89
4	5.29	3.67	49.99	1.19	16.30	10.15	1.09	80127.83
5	3.68	4.69	51.28	0.97	15.86	10.42	1.09	79620.17
6	2.83	4.99	50.91	0.87	16.57	10.06	1.09	79971.18
7	2.75	3.45	44.98	1.04	15.46	10.03	1.08	76691.60
8	1.42	3.54	43.85	1.18	14.79	10.31	1.08	77625.72
9	0.81	2.38	48.43	0.74	16.22	10.15	1.09	80694.91
10	0.46	3.64	49.11	0.56	17.06	9.97	1.09	83471.95
11	0.07	6.20	47.80	1.01	14.96	10.54	1.09	78252.64
12	0.25	1.18	49.44	0.93	15.70	10.27	1.09	80007.56
13	0.56	3.91	51.48	1.06	14.73	10.56	1.09	78402.37
14	1.76	4.15	49.42	1.26	14.61	10.56	1.09	78767.94
15	1.66	2.87	51.50	1.12	14.89	10.56	1.09	77415.00
16	0.68	2.33	54.12	0.64	16.85	10.89	1.09	72875.51
17	1.83	5.05	35.27	0.67	16.80	10.07	1.09	82519.60
18	3.76	2.53	37.92	0.71	16.33	10.46	1.09	81762.18
19	6.85	9.47	38.12	1.85	14.48	10.63	1.09	79876.73
20	6.32	3.82	38.91	2.74	12.96	10.92	1.10	77184.52
21	7.62	1.32	42.47	1.87	14.14	10.80	1.09	77843.13
22	7.10	1.09	38.89	1.15	15.57	10.40	1.09	78881.41
23	5.19	1.83	40.69	0.84	16.83	10.23	1.09	78935.53
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	3.04	3.64	45.96	1.03	15.77	10.33	1.09	79157.19
最 大 值	7.62	9.47	54.12	2.74	17.58	10.92	1.11	83471.95
發生時間	21	19	16	20	1	20		10
最 小 值	0.07	1.09	35.27	0.43	12.96	9.47	1.06	72875.51
發生時間	11	22	17	0	20	0		16
零點偏移(率)	-0.17 %	-0.00 %	-0.04 %	-0.02 %		0.04		-0.10 %
全幅偏移(率)	0.02 %	0.14 %	-0.54 %	-0.08 %		0.12		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								