

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 114年02月25日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.68	4.16	48.72	1.52	16.61	11.77	1.28	80510.01
1	4.19	3.14	71.13	0.68	17.81	12.14	1.28	76470.67
2	8.84	4.05	59.58	0.55	16.35	11.89	1.29	80100.97
3	7.00	3.07	52.45	0.78	16.34	11.79	1.29	80656.42
4	6.40	2.90	51.39	0.70	17.22	11.45	1.30	82494.40
5	7.47	4.65	55.55	1.45	14.89	11.97	1.33	86182.79
6	6.98	5.51	52.37	1.15	15.25	12.30	1.34	76904.26
7	9.50	5.25	53.88	1.31	14.70	12.23	1.34	78174.71
8	9.04	4.05	48.73	1.58	14.59	12.09	1.33	79302.31
9	8.66	2.87	51.53	0.72	15.73	11.99	1.29	79320.02
10	8.87	3.01	53.07	0.93	15.63	12.06	1.31	78528.84
11	6.05	2.96	59.76	0.58	16.11	12.23	1.33	76720.09
12	4.23	2.64	56.15	0.63	16.71	11.72	1.30	80205.34
13	6.21	2.87	49.36	0.79	17.02	11.52	1.33	81490.31
14	6.54	2.89	47.65	1.47	15.46	11.71	1.29	80972.24
15	7.92	6.34	57.40	1.18	15.74	12.00	1.29	78585.15
16	9.47	3.38	50.23	1.40	16.18	11.59	1.33	81932.89
17	8.77	2.98	56.78	0.61	17.69	11.26	1.31	83205.63
18	9.47	4.55	52.06	1.31	16.36	11.48	1.30	82565.82
19	7.47	4.91	55.86	1.14	17.14	11.66	1.34	80206.04
20	8.84	3.36	50.11	1.21	16.82	11.45	1.33	82410.77
21	9.99	3.04	55.61	1.03	16.29	11.61	1.33	81157.37
22	10.37	4.66	51.68	1.98	14.75	12.04	1.31	78647.44
23	7.67	1.51	55.51	0.56	17.13	12.06	1.32	76994.99
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.78	3.70	54.02	1.05	16.19	11.83	1.31	80155.81
最 大 值	10.37	6.34	71.13	1.98	17.81	12.30	1.34	86182.79
發生時間	22	15	1	22	1	6		5
最 小 值	4.19	1.51	47.65	0.55	14.59	11.26	1.27	76470.67
發生時間	1	23	14	2	8	17		1
零點偏移(率)	-0.03 %	-0.03 %	-0.03 %	0.00 %		-0.35		0.30 %
全幅偏移(率)	0.00 %	0.00 %	-0.04 %	0.00 %		-0.10		0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年02月25日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.10	3.13	57.24	2.57	15.40	11.42	1.12	79199.53
1	7.35	4.62	60.04	2.16	16.16	11.42	1.11	78099.78
2	8.80	3.39	54.02	1.75	16.73	10.72	1.12	83239.55
3	8.30	3.16	53.15	1.70	16.74	10.79	1.14	83546.35
4	8.50	3.11	53.71	1.73	16.39	10.88	1.16	82530.03
5	8.57	3.28	53.36	1.96	15.76	11.08	1.17	81331.04
6	8.37	3.95	58.41	2.48	12.74	11.86	1.18	77248.25
7	8.00	2.79	55.71	2.16	15.49	10.98	1.18	82675.32
8	8.35	2.70	52.45	1.98	15.12	11.05	1.18	81731.85
9	8.03	2.68	55.91	2.24	15.13	11.21	1.17	81403.86
10	7.66	2.83	54.85	2.12	15.50	11.23	1.15	80479.34
11	7.64	3.24	51.03	2.11	15.13	11.04	1.18	81800.32
12	7.24	6.69	56.52	2.84	14.44	11.25	1.15	80612.40
13	7.95	2.51	55.95	2.71	13.80	11.45	1.18	78753.86
14	8.19	4.95	51.80	2.55	13.54	11.52	1.15	78148.95
15	8.58	3.80	53.95	2.68	13.70	11.37	1.14	78783.47
16	8.94	8.40	52.75	2.86	12.95	11.56	1.18	78994.08
17	8.49	5.23	54.38	2.63	15.03	11.03	1.16	82005.41
18	8.45	6.61	56.24	2.74	15.72	10.94	1.13	83067.53
19	9.57	7.30	50.96	3.03	15.42	10.83	1.17	82972.29
20	8.86	1.83	36.29	2.60	13.93	11.37	1.19	79527.67
21	9.14	1.90	45.51	2.97	13.62	11.49	1.18	79102.38
22	10.03	6.13	50.33	2.83	13.43	11.49	1.18	77004.45
23	8.79	8.98	50.98	2.17	14.67	11.39	1.18	77823.68
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.41	4.30	53.15	2.40	14.86	11.22	1.16	80420.06
最 大 值	10.03	8.98	60.04	3.03	16.74	11.86	1.19	83546.35
發生時間	22	23	1	19	3	6		3
最 小 值	7.24	1.83	36.29	1.70	12.74	10.72	1.10	77004.45
發生時間	12	20	20	3	6	2		22
零點偏移(率)	0.00 %	-0.00 %	-0.06 %	0.00 %		-0.21		0.10 %
全幅偏移(率)	0.14 %	-0.01 %	0.26 %	0.42 %		-0.17		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

