

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 113年11月21日

項目 單位 小時\限標	#1-HCl_C ppm	#1-CO_C ppm	#1-NOx_C ppm	#1-SO2_C ppm	#1-H2O %	#1-O2_C %	#1-OPAC %	#1-FLOW_C m3/Hour
0	8.90	6.68	59.30	2.70	12.94	12.54	1.06	77140.42
1	6.84	1.88	64.03	1.06	16.33	12.15	1.06	77945.42
2	7.25	1.82	47.01	1.76	13.79	12.39	1.06	78054.42
3	7.87	1.83	51.30	1.49	14.28	12.25	1.06	79868.01
4	9.03	2.97	61.11	1.47	14.44	12.26	1.06	79232.02
5	10.86	3.59	53.40	1.66	13.37	12.62	1.08	77235.89
6	9.22	2.59	60.95	0.72	15.15	12.38	1.09	77685.92
7	7.49	2.46	49.87	0.94	15.03	12.22	1.09	78416.63
8	8.08	2.69	46.80	1.79	14.15	12.24	1.10	78978.04
9	9.98	2.41	48.35	1.87	14.61	11.89	1.10	82159.33
10	9.72	2.42	49.08	2.41	13.68	12.21	1.09	79634.95
11	9.11	2.20	52.65	1.86	14.24	12.05	1.07	80831.09
12	8.70	2.60	50.84	2.15	13.33	12.54	1.07	77525.51
13	8.67	3.25	46.35	2.18	13.06	12.47	1.07	78107.63
14	10.31	3.96	46.56	2.32	13.15	12.49	1.06	77632.33
15	10.86	3.52	52.45	2.59	13.11	12.22	1.06	79565.77
16	9.19	2.54	62.16	0.72	15.39	11.78	1.07	81835.04
17	7.48	3.15	51.25	2.54	13.02	12.57	1.09	76534.57
18	7.18	5.36	56.84	2.94	12.22	13.10	1.09	72833.90
19	6.87	2.82	62.10	1.42	13.90	12.63	1.09	75686.25
20	10.01	4.69	56.68	2.43	13.05	12.86	1.10	74300.51
21	10.21	0.96	68.38	1.50	14.30	12.16	1.10	79691.89
22	8.10	5.16	69.31	1.30	14.46	12.22	1.10	78853.91
23	9.00	4.53	60.99	1.86	14.16	12.32	1.09	78081.89
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.79	3.17	55.32	1.82	13.97	12.36	1.08	78242.97
最 大 值	10.86	6.68	69.31	2.94	16.33	13.10	1.13	82159.33
發生時間	5	0	22	18	1	18		9
最 小 值	6.84	0.96	46.35	0.72	12.22	11.78	1.06	72833.90
發生時間	1	21	13	6	18	16		18
零點偏移(率)	-0.40 %	0.00 %	-0.32 %	-0.08 %		-0.01		0.00 %
全幅偏移(率)	0.00 %	0.02 %	0.18 %	0.80 %		0.05		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								



